

TANJUNG PANDAN BULUH TUMBANG, Indonesia

WMO: 962490

Lat: 2.7525S

Lon: 107.7530E

Elev: 44

StdP: 100.80

Time Zone: 7.00 (E07)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 11	(b) 22.3	(c) 22.6	(d) 19.3	(e) 14.1	(f) 31.5	(g) 20.2	(h) 15.0	(i) 29.9	(j) 8.3	(k) 28.5	(l) 6.3	(m) 28.3	(n) 0.6	(o) 170	(p) 0.304

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 9	(b) 8.4	(c) 33.1	(d) 24.5	(e) 32.6	(f) 24.8	(g) 32.1	(h) 25.1	(i) 26.9	(j) 30.3	(k) 26.7	(l) 29.9	(m) 26.4	(n) 29.6	(o) 5.6	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.6	28.5	25.7	21.1	28.1	25.6	20.9	27.9	85.0	30.4	83.8	30.2	82.8	29.9	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.0	(b) 7.8	(c) 6.5	(e) 20.7	(f) 34.5	(g) 0.9	(h) 0.9	(i) 20.1	(j) 35.2	(k) 19.5	(l) 35.7	(m) 19.0	(n) 36.2	(o) 18.3	(p) 36.9		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			20.7	28.1	1.1	0.8	18.9	28.6	18.3	29.1	17.7	29.6	16.9	30.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	26.6	26.8	27.1	27.1	27.5	27.4	27.2	27.5	27.6	27.3	26.8	26.5
	DBStd	0.99	0.83	0.86	0.82	0.83	0.96	1.02	1.00	0.99	1.00	1.03	0.84	0.89
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6246	515	470	529	514	542	523	534	542	529	535	503	511
	CDD18.3	3204	257	237	271	264	283	273	276	283	279	277	253	252
	CDH23.3	27576	2151	1976	2354	2126	2521	2444	2471	2651	2637	2319	1901	2028
	CDH26.7	8167	426	456	633	556	775	793	847	990	1041	786	463	401
(14) Wind	WSAvg	2.0	2.6	2.6	1.8	1.3	1.6	1.9	2.3	3.0	2.6	1.6	1.2	1.9
(15) Precipitation	PrecAvg	3250	295	189	257	353	316	213	153	122	127	316	429	477
	PrecMax	4229	660	504	456	470	599	552	457	362	405	613	774	930
	PrecMin	2036	36	0	117	200	105	20	3	0	0	42	168	249
	PrecStd	616	129	119	93	81	138	125	126	118	120	164	146	160
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	31.4	32.0	32.2	32.7	32.8	32.7	33.2	34.1	34.1	32.3	31.1
		MCWB	25.8	25.4	25.5	26.2	26.0	25.8	25.4	24.4	23.6	23.7	25.6	26.0
	2%	DB	30.1	30.5	31.1	31.4	32.1	32.1	32.0	32.4	33.1	33.0	31.1	30.2
		MCWB	25.7	25.3	25.5	26.1	26.1	25.7	25.2	24.5	23.9	24.3	25.8	25.8
	5%	DB	29.5	29.9	30.5	30.7	31.5	31.6	31.4	31.9	32.5	32.0	30.3	29.5
		MCWB	25.5	25.3	25.5	26.1	26.1	25.7	25.1	24.6	24.2	24.9	25.7	25.7
	10%	DB	28.9	29.3	29.8	29.8	30.7	30.9	30.7	31.3	31.8	30.8	29.4	28.9
		MCWB	25.4	25.2	25.5	26.0	26.1	25.6	25.0	24.5	24.4	25.3	25.7	25.6
	0.4%	WB	26.6	26.5	26.7	27.2	27.3	27.1	26.6	26.4	26.4	26.7	26.7	26.7
		MCDB	29.3	29.4	29.6	30.2	30.7	30.6	30.5	30.2	30.6	30.5	29.8	29.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.2	26.1	26.3	26.7	26.9	26.6	26.1	25.9	25.9	26.2	26.4	26.3
		MCDB	28.8	28.9	29.2	29.8	30.4	30.2	30.1	29.9	30.0	29.8	29.4	28.8
	5%	WB	25.9	25.8	26.1	26.4	26.6	26.3	25.7	25.5	25.5	25.9	26.1	26.1
		MCDB	28.5	28.5	29.0	29.4	29.9	29.8	29.6	29.5	29.4	29.3	29.1	28.5
	10%	WB	25.6	25.5	25.7	26.1	26.2	26.0	25.4	25.2	25.1	25.6	25.8	25.8
		MCDB	28.0	28.0	28.5	28.9	29.4	29.5	29.1	29.1	29.0	28.7	28.4	28.0
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	5.4	6.1	6.4	6.7	6.8	7.2	7.8	8.4	7.6	6.2	5.0
		MCDBR	5.6	6.2	6.9	7.2	7.8	8.0	8.1	8.8	9.8	9.6	7.3	6.0
		MCWBR	2.1	2.1	2.3	2.8	2.9	2.7	2.5	2.4	2.5	2.8	2.9	2.5
	5% WB	MCDBR	5.3	5.6	6.1	6.6	6.8	7.0	7.1	7.4	7.7	7.3	6.5	5.3
		MCWBR	2.3	2.3	2.5	2.9	3.0	2.9	2.7	2.7	2.7	3.1	2.9	2.5
(40) Clear-Sky Solar Irradiance	taub		0.435	0.452	0.442	0.419	0.423	0.430	0.437	0.462	0.515	0.541	0.469	0.424
	taud		2.426	2.357	2.388	2.456	2.460	2.456	2.424	2.324	2.142	2.077	2.298	2.449
	Ebn at Noon		901	886	885	883	854	835	835	834	810	800	863	906
	Edh at Noon		122	132	126	114	110	108	112	129	159	172	137	118
(44) All-Sky Solar Radiation	RadAvg		4.59	5.12	5.21	4.84	4.75	4.62	4.89	5.38	5.37	4.83	4.32	3.99
	RadStd		0.32	0.45	0.34	0.22	0.29	0.34	0.37	0.38	0.39	0.44	0.28	0.38

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page