

BENGKULU PADANG KEMILING, Indonesia

WMO: 962530

Lat: 3.8583S

Lon: 102.3360E

Elev: 52

StdP: 14.67

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	72.0	72.7	67.8	102.2	79.2	69.0	106.7	79.3	21.0	80.7	18.5	82.1	2.4	50	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.6	90.6	78.8	89.8	78.6	89.1	78.4	80.8	87.7	80.1	87.0	79.9	86.6	10.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.9	150.1	84.6	78.3	147.1	84.0	77.9	145.3	83.7	44.4	88.2	43.9	87.6	43.5	86.9	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.8	16.5	14.3	DB	67.4	94.7	4.1	3.2	64.5	97.0	62.1	98.9	59.9	100.7	56.9	103.1	
			WB	67.6	82.5	1.3	1.4	66.6	83.5	65.9	84.3	65.1	85.1	64.1	86.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.1	80.6	81.1	81.6	81.7	82.3	81.7	80.8	80.8	80.7	81.0	80.8	80.6
	DBStd	1.62	1.76	1.71	1.74	1.36	1.38	1.34	1.50	1.44	1.41	1.53	1.42	1.67
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11360	948	872	978	951	1000	950	955	953	921	962	923	947
	CDD65	5885	483	452	513	501	535	500	490	488	471	497	473	482
	CDH74	55363	4354	4277	5034	4999	5544	5000	4569	4502	4178	4491	4161	4254
(13)	CDH80	18312	1359	1459	1780	1746	2012	1775	1526	1448	1283	1400	1253	1271
(14)	Wind	WSAvg	4.9	4.7	4.5	4.4	4.1	4.4	4.9	6.3	6.4	5.5	4.6	4.9
(15) Precipitation	PrecAvg	132.5	14.3	11.9	12.6	11.7	8.9	6.5	7.2	7.0	7.2	10.5	16.6	18.1
	PrecMax	166.4	24.3	23.2	19.6	21.4	20.1	15.2	18.8	18.4	15.3	21.4	27.8	31.5
	PrecMin	51.6	5.8	4.7	6.2	6.5	1.5	1.2	0.1	0.3	0.1	0.0	3.7	5.7
	PrecStd	25.9	5.0	4.3	4.3	3.3	4.7	3.8	4.2	4.7	4.5	6.5	5.9	5.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.3	91.3	91.0	90.7	91.3	90.7	90.1	89.9	89.5	90.0	89.6	89.9
		MCWB	78.1	78.6	79.0	79.4	79.9	78.6	78.1	77.7	78.1	78.2	78.7	78.5
	2%	DB	88.7	89.6	89.6	89.5	89.9	89.5	89.0	88.6	88.2	88.9	88.2	88.3
		MCWB	77.8	78.1	78.7	79.1	79.5	78.4	77.9	77.5	77.7	78.1	78.2	78.1
	5%	DB	87.5	88.3	88.7	88.5	89.1	88.7	88.0	87.7	87.3	87.8	87.3	87.2
		MCWB	77.7	77.9	78.4	78.8	79.2	78.3	77.7	77.3	77.4	78.0	78.0	77.8
	10%	DB	86.4	87.2	87.6	87.5	88.1	87.7	87.0	86.6	86.3	86.6	86.2	86.1
		MCWB	77.5	77.8	78.1	78.5	79.0	78.2	77.4	77.1	77.2	77.8	77.9	77.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.8	80.6	80.9	81.0	81.5	80.9	80.1	80.0	79.9	80.0	80.1	80.1
		MCDB	87.2	87.8	88.3	88.1	88.7	87.8	87.2	87.0	86.5	87.0	87.0	86.8
	2%	WB	79.4	79.7	80.0	80.1	80.7	80.0	79.2	79.0	79.1	79.2	79.4	79.3
		MCDB	85.8	86.8	87.1	86.9	87.6	86.9	86.3	86.1	85.8	86.1	86.0	85.7
	5%	WB	78.7	79.0	79.4	79.7	80.1	79.4	78.6	78.3	78.4	78.7	78.9	78.8
		MCDB	85.1	86.0	86.3	86.3	86.7	86.1	85.7	85.1	85.0	85.6	85.3	85.0
	10%	WB	78.1	78.4	78.8	79.1	79.6	78.8	78.0	77.8	77.9	78.2	78.3	78.1
		MCDB	84.3	84.9	85.6	85.6	86.1	85.5	84.8	84.3	84.2	84.5	84.3	84.0
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	12.6	12.8	12.2	12.6	12.8	13.1	12.5	12.2	11.8	11.6	11.3
		MCDBR	13.2	14.1	14.0	13.3	13.6	13.8	14.4	13.8	13.4	13.3	12.8	13.0
		MCWBR	5.5	5.6	5.3	5.2	5.3	5.3	5.5	5.1	4.7	4.6	4.8	5.0
	5% WB	MCDBR	12.1	13.0	13.2	12.5	12.5	12.9	13.3	12.5	12.4	12.1	11.7	12.0
		MCWBR	5.4	5.6	5.6	5.4	5.3	5.5	5.6	5.2	4.9	4.8	4.9	5.0
(40) Clear-Sky Solar Irradiance	taub		0.426	0.457	0.455	0.435	0.452	0.459	0.484	0.527	0.598	0.630	0.509	0.423
	taud		2.421	2.326	2.336	2.400	2.352	2.340	2.256	2.111	1.906	1.821	2.168	2.433
	Ebn at Noon		289	280	277	275	262	256	251	247	237	232	263	288
	Edh at Noon		39	43	42	38	38	38	42	50	64	70	50	38
(44) All-Sky Solar Radiation	RadAvg		1543	1582	1670	1634	1574	1518	1498	1578	1608	1546	1525	1460
(45)	RadStd		110	97	98	55	60	68	83	89	87	96	75	82

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page