

BENGKULU PADANG KEMILING, Indonesia

WMO: 962530

Lat: 3.8583S

Lon: 102.3360E

Elev: 16

StdP: 101.13

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.2	22.6	19.9	14.6	26.2	20.5	15.2	26.3	9.4	27.1	8.3	27.9	1.1	50	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.0	32.5	26.0	32.1	25.9	31.7	25.8	27.1	31.0	26.7	30.6	26.6	30.4	4.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	29.2	25.7	21.0	28.9	25.5	20.8	28.7	85.5	31.2	84.3	30.9	83.2	30.5	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.4	6.4	19.7	34.9	2.3	1.8	18.1	36.1	16.7	37.2	15.5	38.2	13.8	39.5		
(5)			19.8	28.1	0.7	0.8	19.2	28.6	18.8	29.1	18.4	29.5	17.8	30.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	27.0	27.3	27.5	27.6	27.9	27.6	27.1	27.1	27.1	27.2	27.1	27.0		
	DBStd	0.90	0.98	0.95	0.97	0.75	0.77	0.74	0.83	0.80	0.78	0.85	0.79	0.93		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6311	527	484	543	528	556	528	531	529	512	534	513	526		
	CDD18.3	3269	268	251	285	278	297	278	272	271	262	276	263	268		
	CDH23.3	30757	2419	2376	2797	2777	3080	2778	2538	2501	2321	2495	2312	2363		
	CDH26.7	10173	755	811	989	970	1118	986	848	804	713	778	696	706		
(14) Wind	WSAvg	2.2	2.1	2.0	2.0	1.8	1.8	1.9	2.2	2.8	2.9	2.4	2.1	2.2		
(15) Precipitation	PrecAvg	3366	363	302	321	296	227	165	183	179	182	267	421	460		
	PrecMax	4227	618	589	498	544	511	385	477	467	389	544	705	800		
	PrecMin	1311	147	120	157	165	37	30	2	7	2	0	95	144		
	PrecStd	657	128	108	109	83	120	97	107	119	115	164	151	139		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.4	33.0	32.8	32.6	33.0	32.6	32.3	32.1	32.0	32.2	32.0	32.2		
		MCWB	25.6	25.9	26.1	26.4	26.6	25.9	25.6	25.4	25.6	25.7	26.0	25.8		
	2%	DB	31.5	32.0	32.0	31.9	32.2	32.0	31.7	31.5	31.2	31.6	31.2	31.3		
		MCWB	25.4	25.6	25.9	26.2	26.4	25.8	25.5	25.3	25.4	25.6	25.7	25.6		
	5%	DB	30.8	31.3	31.5	31.4	31.7	31.5	31.1	30.9	30.7	31.0	30.7	30.7		
		MCWB	25.4	25.5	25.8	26.0	26.2	25.7	25.4	25.1	25.2	25.5	25.5	25.4		
	10%	DB	30.2	30.7	30.9	30.8	31.2	30.9	30.5	30.3	30.2	30.3	30.1	30.1		
		MCWB	25.3	25.4	25.6	25.8	26.1	25.6	25.2	25.0	25.1	25.4	25.5	25.4		
	0.4%	WB	27.1	27.0	27.2	27.2	27.5	27.2	26.7	26.7	26.6	26.7	26.7	26.7		
		MCDB	30.7	31.0	31.3	31.1	31.5	31.0	30.7	30.6	30.3	30.5	30.6	30.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.3	26.5	26.7	26.7	27.1	26.7	26.2	26.1	26.1	26.2	26.3	26.3		
		MCDB	29.9	30.4	30.6	30.5	30.9	30.5	30.2	30.0	29.9	30.1	30.0	29.8		
	5%	WB	25.9	26.1	26.3	26.5	26.7	26.3	25.9	25.7	25.8	26.0	26.1	26.0		
		MCDB	29.5	30.0	30.2	30.2	30.4	30.1	29.8	29.5	29.5	29.8	29.6	29.4		
	10%	WB	25.6	25.8	26.0	26.2	26.5	26.0	25.6	25.4	25.5	25.6	25.7	25.6		
		MCDB	29.0	29.4	29.8	29.8	30.1	29.7	29.3	29.1	29.0	29.2	29.0	28.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	7.0	7.1	6.8	7.0	7.1	7.3	7.0	6.8	6.6	6.4	6.3		
		MCDBR	7.4	7.8	7.8	7.4	7.6	7.7	8.0	7.7	7.4	7.4	7.1	7.2		
		MCWBR	3.0	3.1	3.0	2.9	3.0	3.0	3.1	2.9	2.6	2.6	2.7	2.8		
	5% WB	MCDBR	6.7	7.2	7.4	7.0	6.9	7.2	7.4	7.0	6.9	6.7	6.5	6.6		
		MCWBR	3.0	3.1	3.1	3.0	2.9	3.0	3.1	2.9	2.7	2.7	2.7	2.8		
(40) Clear-Sky Solar Irradiance	taub		0.426	0.457	0.455	0.435	0.452	0.459	0.484	0.527	0.598	0.630	0.509	0.423		
	taud		2.421	2.326	2.336	2.400	2.352	2.340	2.256	2.111	1.906	1.821	2.168	2.433		
	Ebn at Noon		911	882	874	867	826	806	791	778	746	732	829	909		
	Edh at Noon		123	136	133	121	121	120	132	159	202	222	157	120		
(44) All-Sky Solar Radiation	RadAvg		4.87	4.99	5.27	5.15	4.96	4.79	4.72	4.97	5.07	4.87	4.81	4.60		
	RadStd		0.35	0.30	0.31	0.17	0.19	0.21	0.26	0.28	0.27	0.30	0.24	0.26		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page