

TANJUNG KARANG RADIN INTEN II, Indonesia

WMO: 962950

Lat: 5.2397S

Lon: 105.1745E

Elev: 289

StdP: 14.54

Time Zone: 7.00 (E07)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 70.9	(c) 72.0	(d) 63.6	(e) 89.1	(f) 84.1	(g) 65.7	(h) 95.7	(i) 82.8	(j) 18.2	(k) 83.6	(l) 16.5	(m) 83.5	(n) 2.2	(o) 230	(p) 0.306

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 10	(b) 16.6	(c) 93.7	(d) 75.4	(e) 92.4	(f) 76.1	(g) 91.3	(h) 76.6	(i) 80.1	(j) 87.4	(k) 79.7	(l) 87.1	(m) 79.2	(n) 86.5	(o) 10.4	(p) 130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.2	148.2	83.5	77.7	145.6	83.1	77.3	143.4	82.7	44.0	87.9	43.5	87.5	43.0	87.0	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	13.8	12.0	68.9	95.6	1.6	2.0	67.7	97.1	66.7	98.2	65.8	99.3	64.7	100.8
			66.3	82.4	2.1	2.7	64.8	84.3	63.6	85.9	62.5	87.4	61.0	89.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.8	80.9	81.1	81.7	82.3	82.3	81.4	80.6	81.0	82.1	83.2	82.6	81.9
	DBStd	1.72	1.57	1.49	1.33	1.54	1.48	1.63	1.33	1.49	1.54	1.61	1.94	1.58
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11589	959	872	983	968	1000	941	949	961	962	1029	977	988
	CDD65	6114	494	452	518	518	535	491	484	496	512	564	527	523
	CDH74	58733	4304	3983	4746	5030	5422	4710	4481	4811	5204	5984	5222	4836
(14) Wind	WSAvg	3.7	3.6	3.7	3.2	3.1	3.3	3.4	3.9	4.6	4.8	4.4	3.4	3.3
	PrecAvg	86.0	12.8	11.7	11.9	7.5	5.4	3.8	3.6	2.9	3.0	3.9	7.5	12.0
	PrecMax	125.2	21.6	16.7	26.1	12.8	11.2	12.9	10.2	11.0	7.8	10.2	14.6	22.7
	PrecMin	58.4	6.5	6.7	6.7	3.1	2.0	0.4	0.1	0.0	0.0	0.0	2.0	5.7
	PrecStd	14.6	3.6	2.6	4.2	2.2	2.2	2.8	2.4	2.7	2.5	2.6	3.4	4.2
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.7	90.5	91.3	92.3	91.8	91.0	90.6	92.0	94.3	96.2	95.1	91.9
		MCWB	78.1	78.7	78.3	78.4	78.2	78.3	76.1	75.4	74.0	73.1	76.3	77.5
	2%	DB	89.0	89.2	89.9	90.8	90.7	90.0	89.6	90.8	92.7	94.3	93.0	90.3
		MCWB	77.8	78.2	78.3	78.4	78.2	77.9	76.5	75.5	74.9	74.7	76.7	77.6
	5%	DB	87.5	88.0	88.8	89.6	89.6	89.0	88.5	89.7	91.4	92.5	90.9	88.9
		MCWB	77.6	78.1	78.2	78.6	78.3	77.7	76.4	75.5	75.3	75.4	77.0	77.6
	10%	DB	86.1	86.5	87.4	88.2	88.4	87.7	87.3	88.4	90.1	90.8	89.0	87.4
		MCWB	77.4	77.7	78.0	78.3	78.3	77.7	76.4	75.6	75.5	76.1	77.2	77.5
	0.4%	WB	79.9	80.0	80.6	80.8	80.9	80.1	79.2	78.9	78.8	78.9	79.5	79.8
		MCDB	87.0	87.2	88.0	87.8	87.8	87.7	86.6	86.6	87.2	88.3	87.9	86.9
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	79.0	79.2	79.7	79.9	80.0	79.4	78.5	78.0	78.0	78.2	78.9	79.0
		MCDB	85.9	86.3	86.9	87.2	87.2	86.8	86.0	85.9	86.6	87.4	87.1	86.7
	5%	WB	78.3	78.7	79.0	79.3	79.4	78.9	77.9	77.3	77.3	77.6	78.2	78.3
		MCDB	84.8	85.6	86.1	86.6	86.5	86.2	85.2	85.3	86.1	86.7	86.3	85.8
	10%	WB	77.8	78.1	78.3	78.8	78.9	78.3	77.3	76.7	76.7	77.1	77.7	77.9
		MCDB	84.1	84.5	85.0	86.2	85.9	85.2	84.3	84.6	85.5	86.1	85.6	85.0
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	12.0	13.0	13.2	13.1	13.3	14.3	15.8	16.8	16.6	14.0	12.5
		MCDBR	13.2	13.4	14.5	14.7	14.7	15.0	16.0	17.5	18.8	19.4	17.1	14.3
		MCWBR	4.6	4.6	5.0	5.0	5.0	5.3	5.6	5.7	5.6	5.1	4.7	4.6
	5% WB	MCDBR	12.2	12.4	13.2	13.3	13.0	13.2	13.6	14.7	15.6	15.6	13.8	12.7
		MCWBR	4.7	4.8	5.1	5.1	5.1	5.2	5.5	5.4	5.4	4.9	4.8	4.7
(40) Clear-Sky Solar Irradiance	taub		0.447	0.476	0.467	0.467	0.488	0.497	0.530	0.557	0.586	0.599	0.542	0.462
	taud		2.336	2.251	2.279	2.282	2.207	2.169	2.057	1.967	1.888	1.859	2.033	2.297
	Ebn at Noon		283	275	274	266	251	244	237	239	239	240	255	278
	Edh at Noon		43	47	45	43	44	45	51	58	65	68	57	44
(44) All-Sky Solar Radiation	RadAvg		1562	1555	1652	1612	1510	1413	1466	1628	1710	1659	1555	1503
	RadStd		98	97	80	78	77	93	111	82	95	109	73	63

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.86	+1.10	N/A	+0.76	N/A	N/A	N/A	N/A	+238	+238

Nomenclature: See separate page