

KALIMARAU, Indonesia

WMO: 965290

Lat: 2.1439N

Lon: 117.4328E

Elev: 85

StdP: 14.65

Time Zone: 8.00 (E08)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	72.1	72.7	70.4	112.2	80.8	71.4	116.1	78.9	12.2	85.8	9.9	85.6	0.8	N/A	0.284

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	16.7	94.3	79.9	93.4	79.9	92.4	79.9	82.2	90.4	81.7	89.7	81.0	89.1	4.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	156.2	86.9	79.4	152.8	86.0	79.0	150.8	85.5	46.1	90.6	45.4	90.1	44.9	89.6	92.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	9.2	7.5	65.8	97.5	4.9	2.4	62.2	99.2	59.4	100.6	56.6	101.9	53.0	103.7		
(5)			66.3	84.8	4.3	2.8	63.3	86.8	60.8	88.4	58.4	90.0	55.3	92.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	82.0	80.7	80.8	81.3	82.5	82.9	82.3	82.1	82.6	82.7	82.5	82.1	81.6	(6)
(7)		DBStd	2.00	1.99	1.85	1.99	1.96	1.67	1.98	1.75	1.79	1.95	1.78	1.88	1.92	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11681	952	862	970	974	1019	969	994	1010	981	1008	962	980	(10)
(11)		CDD65	6206	487	442	505	524	554	519	529	545	531	543	512	515	(11)
(12)		CDH74	57278	4037	3679	4393	4909	5347	4933	4956	5344	5182	5193	4694	4611	(12)
(13)		CDH80	22093	1300	1266	1574	1856	2065	1949	2022	2306	2242	2133	1736	1644	(13)
(14)	Wind	WSAvg	1.7	1.3	1.4	1.5	1.6	1.7	1.8	2.0	2.3	2.2	1.9	1.4	1.5	(14)
(15)	Precipitation	PrecAvg	97.9	10.0	8.6	8.7	7.6	8.8	7.8	6.4	5.6	7.4	8.1	9.1	9.8	(15)
(16)		PrecMax	129.0	21.3	16.8	19.7	13.1	17.4	18.3	10.9	10.9	17.2	21.3	17.5	14.9	(16)
(17)		PrecMin	64.4	4.5	3.5	1.9	1.9	3.3	2.0	1.7	0.4	0.6	2.4	3.5	6.3	(17)
(18)		PrecStd	17.6	3.5	3.4	3.9	2.9	3.1	3.3	2.5	2.4	4.0	3.9	3.3	2.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.1	92.2	93.1	94.4	94.2	94.4	94.1	94.8	95.3	94.8	93.9	93.8	(19)
(20)			MCWB	79.9	79.6	80.0	80.2	81.2	80.9	79.5	79.2	79.1	79.6	80.2	80.2	(20)
(21)		2%	DB	90.2	90.7	91.3	92.5	92.6	92.8	92.3	93.3	93.6	93.1	92.1	91.5	(21)
(22)			MCWB	79.9	79.5	79.5	80.3	81.1	80.7	79.3	79.2	79.2	79.7	80.3	80.4	(22)
(23)		5%	DB	88.6	89.1	89.8	90.8	91.2	91.2	90.9	91.9	92.2	91.6	90.5	89.7	(23)
(24)			MCWB	79.6	79.2	79.5	80.3	80.8	80.3	79.2	79.1	79.2	79.6	80.1	80.2	(24)
(25)		10%	DB	86.8	87.3	88.0	89.1	89.5	89.4	89.4	90.3	90.6	90.0	88.6	88.0	(25)
(26)			MCWB	79.3	78.9	79.3	80.1	80.5	80.0	79.1	79.0	79.2	79.5	79.9	79.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.6	81.4	81.7	82.4	82.8	82.8	81.7	81.7	82.1	81.9	82.0	82.2	(27)
(28)			MCD B	88.4	89.3	89.5	90.6	90.7	91.4	89.3	90.3	91.0	90.6	89.5	89.9	(28)
(29)		2%	WB	80.7	80.5	80.8	81.4	81.9	81.6	80.7	80.7	80.9	81.0	81.1	81.0	(29)
(30)			MCD B	88.0	88.1	88.6	89.5	89.9	90.0	88.9	89.7	89.9	89.7	88.7	88.6	(30)
(31)		5%	WB	80.0	79.9	80.1	80.8	81.2	80.8	80.0	80.0	80.1	80.5	80.6	80.5	(31)
(32)			MCD B	86.7	86.9	87.4	88.7	89.0	88.9	88.1	88.8	88.9	89.1	88.3	87.9	(32)
(33)		10%	WB	79.4	79.2	79.5	80.1	80.6	80.1	79.5	79.4	79.5	79.8	80.0	79.9	(33)
(34)			MCD B	85.5	85.7	86.2	87.4	88.3	87.5	87.3	87.8	88.0	87.8	87.0	86.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.7	13.6	14.1	14.7	14.9	15.1	15.7	16.4	16.7	15.9	14.4	13.8	(35)
(36)			MCDBR	15.8	16.8	16.9	17.0	17.4	17.5	17.7	18.5	19.0	18.4	17.1	16.4	(36)
(37)			MCWBR	6.3	6.7	6.2	6.1	6.5	6.5	6.1	5.9	6.2	6.4	6.2	6.5	(37)
(38)		5% WB	MCDBR	14.1	14.6	14.9	15.4	15.8	16.1	16.1	16.7	17.1	16.4	15.2	14.8	(38)
(39)			MCWBR	6.3	6.6	6.3	6.3	6.7	6.8	6.5	6.4	6.8	6.7	6.3	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.397	0.408	0.410	0.408	0.399	0.399	0.405	0.471	0.514	0.544	0.426	0.398	(40)	
(41)		taud	2.514	2.473	2.464	2.463	2.506	2.508	2.482	2.271	2.143	2.052	2.415	2.518	(41)	
(42)		Ebn at Noon	295	292	290	285	280	277	276	263	257	251	284	293	(42)	
(43)		Edh at Noon	35	37	37	36	34	33	34	43	50	56	38	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1338	1471	1500	1558	1551	1470	1524	1609	1579	1504	1437	1393	(44)	
(45)		RadStd	70	97	106	104	71	69	104	87	97	83	67	73	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page