

KALIMARAU, Indonesia

WMO: 965290

Lat: 2.1439N

Lon: 117.4328E

Elev: 26

StdP: 101.01

Time Zone: 8.00 (E08)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.3	22.6	21.3	16.0	27.1	21.9	16.6	26.1	5.5	29.9	4.4	29.8	0.4	N/A	0.284

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	9.3	34.6	26.6	34.1	26.6	33.6	26.6	27.9	32.4	27.6	32.1	27.2	31.7	2.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	30.5	26.3	21.8	30.0	26.1	21.5	29.7	89.3	32.6	87.7	32.3	86.5	32.0	33.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.1	4.1	3.4	DB	18.8	36.4	2.7	1.3	16.8	37.3	15.2	38.1	13.7	38.8	11.7	39.8	(4)
			WB	19.1	29.3	2.4	1.6	17.4	30.4	16.0	31.3	14.7	32.2	12.9	33.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	27.1	27.1	27.4	28.0	28.3	27.9	27.8	28.1	28.2	28.1	27.8	27.6
	DBStd	1.11	1.10	1.03	1.10	1.09	0.93	1.10	0.97	0.99	1.08	0.99	1.05	1.07
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6489	529	479	539	541	566	538	552	561	545	560	534	544
	CDD18.3	3448	271	246	281	291	308	288	294	303	295	302	284	286
	CDH23.3	31821	2243	2044	2441	2727	2971	2741	2753	2969	2879	2885	2608	2562
CDH26.7	12274	722	703	874	1031	1147	1083	1123	1281	1246	1185	964	913	
Wind	WSAvg	0.8	0.6	0.6	0.7	0.7	0.7	0.8	0.9	1.1	1.0	0.9	0.6	0.7
Precipitation	PrecAvg	2486	255	218	222	194	224	198	162	141	189	206	230	249
	PrecMax	3276	540	426	500	333	441	464	276	276	436	540	445	379
	PrecMin	1636	114	90	48	47	84	50	42	9	14	61	89	161
	PrecStd	448	90	86	98	74	78	84	64	60	101	98	84	65
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.4	33.5	33.9	34.7	34.6	34.7	34.5	34.9	35.1	34.9	34.4	34.3
		MCWB	26.6	26.4	26.7	26.8	27.3	27.2	26.4	26.2	26.2	26.4	26.8	26.8
	2%	DB	32.4	32.6	32.9	33.6	33.7	33.8	33.5	34.1	34.2	33.9	33.4	33.1
		MCWB	26.6	26.4	26.4	26.8	27.3	27.0	26.3	26.2	26.2	26.5	26.8	26.9
	5%	DB	31.5	31.7	32.1	32.7	32.9	32.9	32.7	33.3	33.4	33.1	32.5	32.1
		MCWB	26.5	26.2	26.4	26.9	27.1	26.8	26.2	26.1	26.2	26.4	26.7	26.8
	10%	DB	30.5	30.7	31.1	31.7	31.9	31.9	31.9	32.4	32.5	32.2	31.4	31.1
		MCWB	26.3	26.1	26.3	26.7	26.9	26.7	26.2	26.1	26.2	26.4	26.6	26.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	27.4	27.6	28.0	28.2	28.2	27.6	27.6	27.8	27.7	27.8	27.9
		MCDB	31.3	31.9	32.0	32.6	32.6	33.0	31.9	32.4	32.8	32.6	32.0	32.2
	2%	WB	27.0	26.9	27.1	27.5	27.7	27.6	27.1	27.1	27.2	27.2	27.3	27.2
		MCDB	31.1	31.2	31.5	31.9	32.2	32.2	31.6	32.1	32.2	32.1	31.5	31.4
	5%	WB	26.7	26.6	26.7	27.1	27.4	27.1	26.7	26.7	26.7	27.0	27.0	26.9
		MCDB	30.4	30.5	30.8	31.5	31.7	31.6	31.1	31.5	31.6	31.7	31.3	31.0
	10%	WB	26.3	26.2	26.4	26.7	27.0	26.7	26.4	26.3	26.4	26.6	26.7	26.6
		MCDB	29.7	29.9	30.1	30.8	31.3	30.8	30.7	31.0	31.1	31.0	30.5	30.3
Mean Daily Temperature Range	5% DB	MDBR	7.1	7.6	7.8	8.2	8.3	8.4	8.7	9.1	9.3	8.8	8.0	7.6
		MCDBR	8.8	9.3	9.4	9.5	9.7	9.7	9.9	10.3	10.5	10.2	9.5	9.1
		MCWBR	3.5	3.7	3.5	3.4	3.6	3.6	3.4	3.3	3.4	3.6	3.5	3.6
	5% WB	MCDBR	7.8	8.1	8.3	8.6	8.8	9.0	8.9	9.3	9.5	9.1	8.4	8.2
MCWBR	3.5	3.7	3.5	3.5	3.7	3.8	3.6	3.6	3.8	3.7	3.5	3.5	3.6	
Clear-Sky Solar Irradiance	taub	0.397	0.408	0.410	0.408	0.399	0.399	0.405	0.471	0.514	0.544	0.426	0.398	
	taud	2.514	2.473	2.464	2.463	2.506	2.508	2.482	2.271	2.143	2.052	2.415	2.518	
	Ebn at Noon	929	922	914	898	884	872	871	830	811	792	894	923	
	Edh at Noon	110	116	117	115	106	104	108	137	159	175	120	108	
All-Sky Solar Radiation	RadAvg	4.22	4.64	4.73	4.91	4.89	4.63	4.80	5.07	4.98	4.74	4.53	4.39	
	RadStd	0.22	0.30	0.33	0.33	0.22	0.22	0.33	0.28	0.31	0.26	0.21	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page