

SUSILO, Indonesia

WMO: 965590

Lat: 0.0657N

Lon: 111.4770E

Elev: 30

StdP: 100.97

Time Zone: 7.00 (E07)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.1	22.5	20.8	15.5	26.6	21.4	16.1	25.9	7.3	26.5	5.4	26.5	0.8	N/A	0.288

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.4	34.5	27.1	34.0	27.1	33.5	27.0	29.0	33.0	28.5	32.5	28.1	31.9	1.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.8	23.9	32.2	27.4	23.4	31.7	27.0	22.8	31.3	94.7	33.2	92.6	32.6	90.7	32.1	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.8	3.9	3.3	18.7	35.7	3.5	0.6	16.2	36.1	14.1	36.4	12.2	36.7	9.7	37.2		
(5)			20.0	29.0	2.6	1.0	18.2	29.8	16.7	30.4	15.2	31.0	13.4	31.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	27.3	27.5	27.8	28.1	28.4	28.2	27.9	28.0	28.0	27.8	27.7	27.4	
	DBStd	1.10	0.99	1.09	1.07	1.16	1.03	1.21	1.21	1.09	1.06	0.99	0.88	0.91	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD10.0	6511	537	490	553	544	569	545	556	557	539	550	531	541	
	CDD18.3	3469	278	257	294	294	311	295	297	298	289	292	281	282	
	CDH23.3	32811	2386	2318	2732	2828	3163	2975	2923	2976	2879	2708	2538	2385	
CDH26.7	12989	844	849	1059	1141	1289	1238	1238	1254	1194	1059	956	867		
Wind	WSAvg	1.0	1.0	0.9	1.0	1.0	0.9	1.0	1.1	1.1	1.0	1.0	1.1	1.0	
Precipitation	PrecAvg	3229	298	267	284	291	250	201	221	190	226	310	331	359	
	PrecMax	4574	485	590	498	545	423	369	657	498	407	659	492	800	
	PrecMin	2228	111	95	71	183	94	25	16	36	44	18	223	201	
	PrecStd	517	101	130	100	81	87	83	148	128	104	123	67	145	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.5	34.0	34.3	34.6	34.8	34.9	35.0	34.8	34.6	34.0	33.7	33.6	
		MCWB	26.9	26.7	27.1	27.1	27.5	27.1	27.6	26.4	26.9	26.9	27.3	27.6	
	2%	DB	32.6	33.0	33.4	33.7	34.0	33.9	34.0	33.7	33.7	33.1	32.9	32.6	
		MCWB	26.7	26.6	27.0	27.1	27.3	27.2	27.2	26.8	26.8	27.0	27.0	27.0	
	5%	DB	31.8	32.1	32.5	33.0	33.2	33.1	33.0	33.0	33.0	32.4	32.2	31.8	
		MCWB	26.5	26.4	26.9	27.0	27.1	27.0	26.6	26.5	26.6	26.9	26.9	26.5	
	10%	DB	30.8	31.1	31.6	32.1	32.2	32.2	32.0	32.2	32.1	31.6	31.3	30.9	
		MCWB	26.2	26.3	26.7	26.8	27.0	26.8	26.2	26.3	26.4	26.7	26.7	26.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.4	28.4	28.9	29.1	29.5	29.2	29.4	28.8	28.8	28.7	28.8	28.6
			MCDB	32.2	32.2	32.9	33.2	33.5	33.4	33.8	33.2	33.1	32.5	32.7	32.5
2%		WB	27.6	27.6	28.1	28.3	28.5	28.4	28.3	28.2	28.1	28.1	28.2	27.7	
		MCDB	31.2	31.4	31.7	32.1	32.2	32.3	32.4	32.4	32.3	31.9	31.8	31.5	
5%		WB	26.9	27.0	27.5	27.6	27.7	27.7	27.4	27.5	27.5	27.6	27.6	27.1	
		MCDB	30.5	30.8	31.1	31.4	31.5	31.4	31.4	31.4	31.4	31.2	31.0	30.6	
10%		WB	26.4	26.5	26.8	26.9	27.1	27.0	26.6	26.6	26.7	26.8	26.8	26.5	
		MCDB	29.9	30.1	30.5	30.9	31.1	31.0	30.7	30.6	30.6	30.3	30.1	30.0	
Mean Daily Temperature Range	5% DB	MDBR	7.7	8.0	8.3	8.5	8.4	8.6	8.9	8.8	8.7	8.3	8.2	7.9	
		MCDBR	8.8	9.3	9.5	9.6	9.6	9.6	10.0	9.8	9.8	9.3	9.2	8.7	
		MCWBR	3.7	3.7	3.8	3.7	3.7	3.7	3.8	3.9	3.9	3.9	3.9	3.5	
	5% WB	MCDBR	8.1	8.4	8.8	8.9	8.8	8.9	9.3	9.1	8.8	8.6	8.5	8.2	
		MCWBR	3.9	4.0	4.3	4.3	4.2	4.3	4.6	4.6	4.5	4.4	4.5	4.0	
Clear-Sky Solar Irradiance	taub	0.402	0.425	0.425	0.404	0.404	0.402	0.423	0.518	0.629	0.610	0.448	0.400		
	taud	2.477	2.387	2.385	2.453	2.457	2.464	2.393	2.109	1.809	1.850	2.330	2.485		
	Ebn at Noon	928	909	901	899	876	865	851	790	723	743	877	925		
	Edh at Noon	115	127	127	115	111	108	117	160	222	215	132	113		
All-Sky Solar Radiation	RadAvg	4.68	4.83	5.04	5.03	4.92	4.88	4.93	5.00	4.70	4.64	4.73	4.71		
	RadStd	0.26	0.20	0.22	0.18	0.22	0.26	0.24	0.26	0.49	0.57	0.25	0.14		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page