

SAMARINDA TEMINDUNG, Indonesia

WMO: 966070

Lat: 0.4826S

Lon: 117.1564E

Elev: 230

StdP: 98.59

Time Zone: 8.00 (E08)

Period: 03-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	23.6	21.3	16.4	29.2	21.8	16.9	28.2	6.4	29.7	5.5	29.7	0.8	N/A	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.3	33.8	26.0	33.3	26.0	32.8	26.0	27.2	31.4	26.9	31.2	26.7	30.8	3.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	22.1	29.0	25.8	21.6	28.6	25.6	21.5	28.5	87.3	31.6	86.0	31.5	85.0	31.1	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.7	4.9	4.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	27.8	28.2	28.3	28.2	28.2	27.8	27.5	27.9	28.2	28.1	28.1	28.0		
	DBStd	1.08	1.08	1.26	1.21	1.14	0.99	0.99	0.92	0.91	1.05	1.02	1.09	1.04		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6577	552	508	567	545	565	534	544	555	545	560	543	559		
	CDD18.3	3536	294	275	308	295	307	284	286	297	295	302	293	301		
	CDH23.3	35851	2884	2853	3201	2998	3214	2832	2741	2979	3031	3110	2991	3017		
	CDH26.7	11686	921	1018	1136	981	1058	851	792	927	1018	1033	978	973		
(14) Wind	WSAvg	1.2	1.1	1.3	1.3	1.1	1.1	1.1	1.3	1.6	1.4	1.2	1.1	1.0		
(15) Precipitation	PrecAvg	2278	201	176	233	263	207	175	158	120	137	162	219	227		
	PrecMax	2902	337	408	448	440	435	359	404	290	262	372	487	460		
	PrecMin	1493	0	0	2	116	23	30	22	1	0	0	44	98		
	PrecStd	429	85	103	96	106	89	84	96	70	82	86	113	87		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.8	34.2	34.4	33.9	33.4	33.0	32.6	33.1	33.9	33.6	34.0	33.9		
		MCWB	26.0	25.9	26.0	26.3	26.4	26.1	25.5	25.5	25.7	25.9	26.2	26.1		
	2%	DB	32.7	33.4	33.4	33.0	32.6	32.1	31.7	32.2	32.9	32.7	32.9	32.9		
		MCWB	25.9	26.0	25.9	26.3	26.2	26.0	25.5	25.4	25.6	25.9	26.1	26.1		
	5%	DB	31.9	32.6	32.6	32.2	31.9	31.4	31.0	31.5	32.1	31.9	32.1	32.0		
		MCWB	25.8	26.0	25.9	26.2	26.2	25.9	25.5	25.3	25.6	25.9	26.0	26.0		
	10%	DB	31.0	31.7	31.7	31.3	31.2	30.6	30.4	30.8	31.2	31.2	31.1	30.9		
		MCWB	25.8	25.8	25.9	26.1	26.1	25.8	25.4	25.3	25.5	25.8	25.9	25.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	27.2	27.1	27.5	27.5	27.2	26.7	26.7	27.0	27.2	27.1	27.2		
		MCDB	31.5	31.7	32.2	31.9	31.2	30.9	30.2	30.6	31.6	31.4	31.9	31.6		
	2%	WB	26.4	26.7	26.7	27.0	27.0	26.7	26.3	26.2	26.5	26.7	26.6	26.7		
		MCDB	30.9	31.3	31.3	31.4	30.7	30.4	29.9	30.1	30.8	30.8	31.0	31.0		
	5%	WB	26.1	26.3	26.3	26.6	26.7	26.4	26.0	25.9	26.1	26.3	26.4	26.3		
		MCDB	30.3	30.7	30.6	30.6	30.2	29.8	29.6	29.7	30.2	30.1	30.4	30.2		
	10%	WB	25.9	26.0	26.1	26.2	26.4	26.1	25.7	25.6	25.8	26.0	26.1	26.1		
		MCDB	29.8	30.3	30.1	29.8	29.7	29.2	29.0	29.2	29.5	29.7	29.8	29.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	6.8	6.8	6.4	6.3	5.9	5.9	6.2	6.6	6.7	6.4	6.5		
		MCDBR	7.9	8.2	8.1	7.8	7.3	7.1	6.9	7.2	7.9	7.9	7.9	7.8		
		MCWBR	2.4	2.4	2.3	2.6	2.2	2.2	2.1	2.0	2.1	2.4	2.3	2.4		
	5% WB	MCDBR	7.0	7.4	7.1	6.8	6.6	6.2	6.1	6.4	6.8	7.0	6.9	7.0		
		MCWBR	2.5	2.6	2.4	2.5	2.4	2.4	2.3	2.1	2.4	2.5	2.3	2.5		
(40) Clear-Sky Solar Irradiance	taub		0.390	0.399	0.401	0.396	0.395	0.397	0.403	0.455	0.494	0.525	0.438	0.396		
	taud		2.518	2.483	2.470	2.488	2.504	2.507	2.485	2.311	2.187	2.085	2.366	2.506		
	Ebn at Noon		940	933	922	906	884	869	869	842	828	810	887	929		
	Edh at Noon		110	116	117	111	106	103	107	131	152	170	127	110		
(44) All-Sky Solar Radiation	RadAvg		4.42	4.96	4.91	4.81	4.63	4.35	4.55	4.81	4.91	4.71	4.51	4.47		
	RadStd		0.30	0.56	0.39	0.31	0.17	0.24	0.38	0.39	0.34	0.34	0.20	0.30		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page