

PANGKALAN BUN ISKANDAR, Indonesia

WMO: 966450

Lat: 2.7044S

Lon: 111.6700E

Elev: 25

StdP: 101.03

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.8	22.3	20.3	15.0	26.4	21.0	15.7	25.5	6.4	29.1	5.7	28.8	0.3	320	0.280

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.4	33.2	27.1	32.8	27.1	32.4	27.0	28.7	32.0	28.2	31.6	28.0	31.4	2.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.7	23.7	31.4	27.2	23.1	30.9	27.0	22.7	30.7	93.2	32.3	91.3	31.9	89.8	31.5	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.0	5.1	4.4	DB	19.6	34.8	1.8	0.9	18.3	35.5	17.2	36.0	16.2	36.5	14.9	37.1	
			WB	19.4	29.4	1.7	1.2	18.2	30.3	17.2	30.9	16.2	31.6	15.0	32.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	27.4	27.5	27.5	27.6	27.8	27.4	26.9	27.0	27.3	27.6	27.5	27.2
	DBStd	0.95	0.90	0.99	0.94	0.87	0.96	1.01	0.89	0.91	0.84	0.82	0.87	0.98
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6341	538	489	541	528	551	522	523	526	521	544	525	534
	CDD18.3	3299	279	256	283	278	292	272	264	267	271	286	275	276
	CDH23.3	28735	2329	2183	2372	2450	2751	2498	2266	2336	2471	2572	2330	2178
(14) Wind	WSAvg	1.3	1.2	1.1	1.0	1.0	1.2	1.2	1.5	1.7	1.7	1.2	1.1	1.2
	PrecAvg	2654	221	245	263	247	267	167	157	147	167	182	282	306
	PrecMax	3741	350	510	490	404	486	347	347	307	470	667	637	615
	PrecMin	1538	9	80	85	125	100	8	0	12	0	0	83	80
	PrecStd	594	97	118	113	80	109	88	108	89	134	146	139	125
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	33.3	33.6	33.2	33.3	33.1	32.4	32.7	33.6	33.6	33.5	33.1
		MCWB	27.0	27.1	27.1	27.5	27.7	27.9	27.2	26.6	25.5	27.2	27.1	27.3
	2%	DB	32.3	32.6	32.6	32.5	32.6	32.3	31.7	32.0	32.6	32.7	32.5	32.2
		MCWB	26.8	26.8	27.3	27.4	27.6	27.4	26.6	26.4	26.1	26.9	27.1	27.1
	5%	DB	31.4	31.8	31.7	31.8	31.9	31.6	31.1	31.3	32.0	32.0	31.7	31.2
		MCWB	26.6	26.7	27.1	27.3	27.3	27.1	26.4	26.2	26.1	26.7	27.0	26.8
	10%	DB	30.6	30.9	30.7	31.0	31.2	30.9	30.4	30.7	31.3	31.1	30.7	30.3
		MCWB	26.4	26.5	26.8	27.1	27.0	26.8	26.1	25.9	26.1	26.5	26.8	26.6
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.7	28.7	28.9	28.7	28.9	29.0	28.2	28.1	28.3	28.4	28.5	28.6
		MCDB	31.8	32.3	32.3	32.0	32.3	32.2	31.3	31.6	31.7	32.3	32.0	32.0
	2%	WB	27.8	27.9	28.2	28.2	28.3	28.2	27.6	27.3	27.7	27.9	28.0	27.8
		MCDB	31.1	31.4	31.5	31.5	31.7	31.5	30.9	31.0	31.3	31.7	31.5	31.1
	5%	WB	27.3	27.3	27.6	27.8	27.8	27.6	27.1	26.9	27.1	27.4	27.5	27.3
		MCDB	30.3	30.6	30.7	31.0	31.2	30.8	30.3	30.5	30.8	31.0	30.7	30.3
	10%	WB	26.7	26.7	26.9	27.2	27.3	27.1	26.5	26.3	26.6	26.8	26.9	26.7
		MCDB	29.6	29.8	29.8	30.2	30.3	30.1	29.5	29.7	30.1	30.2	29.8	29.5
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	7.6	7.5	7.5	7.4	7.2	7.5	7.8	8.4	8.1	7.6	7.2
		MCDBR	8.3	8.7	8.6	8.5	8.3	8.2	8.4	8.9	9.5	9.3	8.8	8.4
		MCWBR	3.7	3.7	4.1	3.9	3.8	4.0	4.0	4.0	4.0	4.1	4.0	3.8
	5% WB	MCDBR	7.8	8.1	8.1	7.9	7.9	7.9	7.9	8.2	8.6	8.7	8.2	7.9
		MCWBR	4.2	4.3	4.5	4.3	4.3	4.4	4.4	4.4	4.5	4.6	4.4	4.3
(40) Clear-Sky Solar Irradiance	taub		0.419	0.441	0.433	0.414	0.421	0.424	0.448	0.523	0.650	0.669	0.555	0.424
	taud		2.450	2.362	2.393	2.455	2.440	2.430	2.349	2.093	1.749	1.714	2.009	2.436
	Ebn at Noon		916	896	894	887	856	840	825	783	709	703	788	906
	Edh at Noon		119	131	126	115	112	110	121	162	236	247	183	119
	RadAvg		4.78	4.95	5.05	4.88	4.90	4.73	4.76	5.12	5.05	4.80	4.85	4.58
(45) All-Sky Solar Radiation	RadStd		0.19	0.23	0.21	0.18	0.20	0.29	0.32	0.34	0.40	0.35	0.24	0.22

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page