

PALANGKA RAYA TJILIK RIWUT, Indonesia

WMO: 966550

Lat: 2.2281S

Lon: 113.9461E

Elev: 89

StdP: 14.65

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	71.7	72.7	66.5	97.8	88.0	68.4	104.5	85.5	17.2	84.6	14.3	84.6	1.9	180	0.306

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.2	93.2	78.0	92.3	78.0	91.6	78.0	80.9	88.3	80.4	87.8	80.0	87.3	5.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.1	151.5	83.6	78.5	148.4	83.1	78.1	146.5	82.7	44.6	88.9	44.0	88.3	43.6	87.6	88.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.6	11.3	9.6	DB	68.5	95.1	3.9	1.0	65.7	95.8	63.4	96.3	61.2	96.8	58.4	97.5	(4)
(5)			WB	68.3	84.0	3.0	2.4	66.2	85.7	64.4	87.1	62.8	88.4	60.6	90.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.1	81.5	81.9	82.1	82.5	82.9	82.3	81.4	81.7	82.1	82.5	82.4	81.8
	DBStd	1.81	1.86	1.95	1.99	1.82	1.80	1.66	1.65	1.45	1.60	1.76	1.79	1.72
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11708	977	893	994	974	1020	968	973	982	964	1008	971	984
	CDD65	6233	512	473	529	524	555	518	508	517	514	543	521	519
	CDH74	60531	4708	4454	5023	5199	5832	5162	4783	5000	5068	5435	5094	4773
CDH80	22389	1580	1543	1768	1864	2196	1934	1793	2038	2083	2143	1832	1615	
Wind	WSAvg	3.5	3.3	3.4	3.3	3.0	3.1	3.0	3.6	4.1	3.7	3.7	3.7	3.8
Precipitation	PrecAvg	118.3	12.3	10.8	13.5	15.9	10.0	7.5	4.5	3.7	5.2	8.5	13.0	13.3
	PrecMax	183.5	19.7	20.4	22.4	21.9	19.0	18.5	13.9	13.0	16.8	30.9	23.0	23.9
	PrecMin	78.2	5.2	2.8	2.8	10.8	3.1	0.1	0.2	0.2	0.0	0.9	2.3	7.0
	PrecStd	22.1	3.4	4.8	4.8	2.2	4.1	4.5	3.9	3.6	4.3	6.8	4.6	4.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.4	93.1	93.3	93.2	93.1	92.6	92.2	92.7	93.5	93.7	94.0	92.7
		MCWB	78.1	78.2	78.4	79.2	79.9	79.0	77.9	76.4	76.4	77.0	77.6	78.6
	2%	DB	90.9	91.3	91.5	91.6	91.7	91.2	90.7	91.4	92.1	92.3	92.2	90.8
		MCWB	78.2	78.0	78.6	79.1	79.3	78.4	77.6	76.6	76.4	77.4	78.2	78.5
	5%	DB	89.4	89.8	90.1	90.3	90.6	90.0	89.6	90.4	90.9	91.0	90.6	89.3
		MCWB	78.0	78.1	78.6	79.0	79.1	78.3	77.2	76.6	76.5	77.6	78.5	78.3
	10%	DB	87.7	88.1	88.5	88.8	89.3	88.8	88.2	89.1	89.6	89.6	88.9	87.8
		MCWB	77.9	78.1	78.5	78.9	79.0	78.1	77.0	76.5	76.6	77.8	78.5	78.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.6	80.8	81.3	81.8	81.0	80.1	79.7	80.0	80.3	80.7	80.7
		MCDB	87.7	87.8	88.1	88.9	89.2	87.7	87.7	88.0	88.5	88.4	88.5	87.8
	2%	WB	79.3	79.8	80.0	80.5	80.9	80.0	79.2	78.8	79.1	79.6	79.9	79.8
		MCDB	86.4	86.9	87.1	87.9	88.3	87.3	87.0	87.4	87.7	87.7	87.6	87.0
	5%	WB	78.9	79.1	79.4	79.9	80.2	79.5	78.6	78.2	78.5	79.0	79.3	79.1
		MCDB	85.8	86.1	86.4	87.0	87.4	86.7	86.4	86.3	86.8	87.1	86.8	86.2
	10%	WB	78.3	78.6	78.9	79.3	79.7	79.0	78.0	77.6	77.9	78.4	78.8	78.6
		MCDB	84.7	85.3	85.8	86.1	86.4	86.0	85.2	85.3	85.7	86.1	86.2	85.4
Mean Daily Temperature Range	5% DB	MDBR	12.7	12.9	13.1	13.1	13.2	13.5	14.1	15.6	15.8	14.8	13.5	12.8
		MCDBR	15.1	15.2	15.3	15.0	14.7	15.1	15.9	17.2	17.7	17.0	16.2	15.0
		MCWBR	4.4	4.5	4.6	4.7	4.3	4.5	4.5	4.7	4.5	4.6	4.5	4.6
	5% WB	MCDBR	13.2	13.5	13.5	13.7	13.6	13.8	14.2	15.1	15.0	14.9	13.9	13.3
		MCWBR	4.7	4.7	4.9	4.9	4.8	4.9	4.8	4.8	4.8	4.9	4.8	4.9
Clear-Sky Solar Irradiance	taub	0.413	0.437	0.431	0.411	0.416	0.427	0.496	0.685	0.739	0.721	0.570	0.427	
	taud	2.464	2.382	2.398	2.468	2.456	2.407	2.183	1.665	1.566	1.607	1.966	2.430	
	Ebn at Noon	292	285	284	283	273	266	249	210	206	211	246	286	
	Edh at Noon	37	41	40	36	35	36	45	79	90	87	61	38	
All-Sky Solar Radiation	RadAvg	1525	1530	1584	1592	1584	1514	1530	1626	1595	1542	1553	1501	
	RadStd	52	73	46	63	49	84	97	88	147	139	56	57	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page