

PALANGKA RAYA TJILIK RIWUT, Indonesia

WMO: 966550

Lat: 2.2281S

Lon: 113.9461E

Elev: 27

StdP: 101.00

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 22.1	(c) 22.6	(d) 19.2	(e) 14.0	(f) 31.1	(g) 20.2	(h) 14.9	(i) 29.7	(j) 7.7	(k) 29.2	(l) 6.4	(m) 29.2	(n) 0.8	(o) 180	(p) 0.306

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 7.3	(c) 34.0	(d) 25.6	(e) 33.5	(f) 25.5	(g) 33.1	(h) 25.5	(i) 27.2	(j) 31.3	(k) 26.9	(l) 31.0	(m) 26.6	(n) 30.7	(o) 2.4	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 26.2	(b) 21.6	(c) 28.7	(d) 25.8	(e) 21.2	(f) 28.4	(g) 25.6	(h) 20.9	(i) 28.2	(j) 85.9	(k) 31.6	(l) 84.5	(m) 31.3	(n) 83.4	(o) 30.9	(p) 31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.1	5.1	4.3	20.3	35.0	2.2	0.5	18.7	35.4	17.5	35.7	16.2	36.0	14.7	36.4	
			20.2	28.9	1.7	1.3	19.0	29.8	18.0	30.6	17.1	31.3	15.9	32.3	
			DB												
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	27.5	27.7	27.8	28.0	28.3	27.9	27.4	27.6	27.8	28.1	28.0	27.6
	DBStd	1.01	1.03	1.08	1.11	1.01	1.00	0.92	0.92	0.81	0.89	0.98	0.99	0.95
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6504	543	496	552	541	567	538	541	546	536	560	539	547
	CDD18.3	3463	284	263	294	291	308	288	282	287	286	302	289	288
	CDH23.3	33628	2616	2474	2791	2888	3240	2868	2657	2778	2816	3019	2830	2652
	CDH26.7	12438	878	857	982	1036	1220	1074	996	1132	1157	1191	1018	897
Wind	WSAvg	1.6	1.5	1.5	1.5	1.4	1.4	1.3	1.6	1.8	1.7	1.6	1.7	1.7
Precipitation	PrecAvg	3006	313	275	344	404	253	190	115	95	131	216	329	339
	PrecMax	4662	500	518	568	556	482	469	353	330	426	786	584	608
	PrecMin	1987	131	70	70	274	79	3	6	4	1	22	58	177
	PrecStd	561	86	122	121	56	103	115	99	91	109	173	117	118
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	34.0	34.0	34.0	33.9	33.7	33.4	33.7	34.2	34.3	34.4	33.7
		MCWB	25.6	25.7	25.8	26.2	26.6	26.1	25.5	24.7	24.7	25.0	25.4	25.9
	2%	DB	32.7	33.0	33.1	33.1	33.2	32.9	32.6	33.0	33.4	33.5	33.4	32.7
		MCWB	25.6	25.6	25.9	26.2	26.3	25.8	25.4	24.8	24.7	25.2	25.7	25.8
	5%	DB	31.9	32.1	32.3	32.4	32.6	32.2	32.0	32.4	32.7	32.8	32.6	31.8
		MCWB	25.6	25.6	25.9	26.1	26.2	25.7	25.1	24.8	24.7	25.3	25.8	25.7
	10%	DB	31.0	31.2	31.4	31.6	31.9	31.6	31.2	31.7	32.0	32.0	31.6	31.0
		MCWB	25.5	25.6	25.8	26.0	26.1	25.6	25.0	24.7	24.8	25.5	25.8	25.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	27.0	27.1	27.4	27.7	27.2	26.7	26.5	26.7	26.8	27.1	27.1
		MCDB	31.0	31.0	31.2	31.6	31.8	30.9	30.9	31.1	31.4	31.3	31.4	31.0
	2%	WB	26.3	26.5	26.7	26.9	27.2	26.7	26.2	26.0	26.2	26.4	26.6	26.6
		MCDB	30.2	30.5	30.6	31.0	31.3	30.7	30.6	30.8	31.0	31.0	30.9	30.5
	5%	WB	26.0	26.2	26.3	26.6	26.8	26.4	25.9	25.7	25.8	26.1	26.3	26.2
		MCDB	29.9	30.0	30.2	30.6	30.8	30.4	30.2	30.2	30.5	30.6	30.4	30.1
	10%	WB	25.7	25.9	26.1	26.3	26.5	26.1	25.6	25.3	25.5	25.8	26.0	25.9
		MCDB	29.3	29.6	29.9	30.1	30.2	30.0	29.6	29.6	29.8	30.1	30.1	29.7
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.2	7.3	7.3	7.3	7.5	7.9	8.7	8.8	8.2	7.5	7.1
		MCDBR	8.4	8.5	8.5	8.3	8.2	8.4	8.8	9.6	9.8	9.4	9.0	8.3
		MCWBR	2.5	2.5	2.5	2.6	2.4	2.5	2.5	2.6	2.5	2.6	2.5	2.6
	5% WB	MCDBR	7.4	7.5	7.5	7.6	7.6	7.7	7.9	8.4	8.3	8.3	7.7	7.4
		MCWBR	2.6	2.6	2.7	2.7	2.7	2.7	2.6	2.7	2.7	2.7	2.6	2.7
Clear-Sky Solar Irradiance	taub	0.413	0.437	0.431	0.411	0.416	0.427	0.496	0.685	0.739	0.721	0.570	0.427	
	taud	2.464	2.382	2.398	2.468	2.456	2.407	2.183	1.665	1.566	1.607	1.966	2.430	
	Ebn at Noon	921	899	895	891	861	837	784	663	648	666	776	903	
	Edh at Noon	117	128	125	113	110	113	143	249	284	275	191	120	
All-Sky Solar Radiation	RadAvg	4.81	4.82	4.99	5.02	4.99	4.77	4.82	5.13	5.03	4.86	4.90	4.73	
	RadStd	0.17	0.23	0.15	0.20	0.16	0.26	0.31	0.28	0.46	0.44	0.17	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page