

BANJARMASIN SYAMSUDIN NOOR, Indonesia

WMO: 966850

Lat: 3.4388S

Lon: 114.7525E

Elev: 66

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	71.5	72.6	64.1	89.9	88.7	66.2	96.8	86.7	17.6	84.0	14.5	84.8	0.8	200	0.310

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	17.1	95.2	76.6	93.6	77.3	92.8	77.5	81.0	88.8	80.5	88.2	80.0	87.4	8.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.3	83.9	78.7	149.5	83.6	78.2	146.9	83.1	44.8	89.7	44.2	89.0	43.7	88.1	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.1	12.1	10.5	DB	69.1	97.7	1.3	2.1	68.2	99.2	67.4	100.5	66.7	101.6	65.7	103.2	(4)
(5)			WB	67.2	83.3	2.0	2.2	65.8	85.0	64.6	86.3	63.5	87.5	62.1	89.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	82.4	81.4	81.8	82.2	83.0	83.3	82.4	81.6	82.1	82.9	83.6	82.9	81.5	(6)
(7)		DBStd	2.06	2.01	2.00	2.00	1.84	1.85	1.86	1.90	1.77	1.72	2.13	1.99	2.04	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11820	975	890	998	989	1032	971	979	996	987	1042	986	975	(10)
(11)		CDD65	6345	510	470	533	539	567	521	514	531	537	577	536	510	(11)
(12)		CDH74	62060	4699	4472	5204	5451	5920	5062	4742	5186	5515	5992	5224	4593	(12)
(13)		CDH80	22759	1417	1388	1702	1897	2197	1858	1771	2210	2481	2594	1886	1358	(13)
(14)	Wind	WSAvg	3.7	4.1	3.8	3.8	3.6	3.5	3.3	3.4	3.7	4.1	4.0	3.8	3.9	(14)
(15)	Precipitation	PrecAvg	104.7	15.2	12.7	12.7	8.9	8.3	5.1	5.3	3.9	3.7	5.7	9.9	13.6	(15)
(16)		PrecMax	130.2	23.2	20.7	24.3	18.2	19.0	9.4	16.3	15.2	9.6	11.3	18.2	26.8	(16)
(17)		PrecMin	72.7	5.0	5.0	5.9	2.2	1.9	0.3	0.2	0.2	0.0	1.1	4.2	1.0	(17)
(18)		PrecStd	17.0	4.7	4.5	4.0	3.5	3.9	2.2	3.8	3.2	2.6	3.2	4.1	5.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.9	92.6	92.8	93.4	93.6	93.4	93.2	95.0	96.6	97.7	95.4	93.0	(19)
(20)			MCWB	79.7	79.2	79.9	79.8	79.7	78.8	77.9	76.3	75.8	75.0	78.0	79.5	(20)
(21)		2%	DB	89.9	90.4	91.0	91.6	92.3	91.7	91.5	93.3	94.7	95.4	93.1	90.1	(21)
(22)			MCWB	79.0	78.8	79.2	79.5	79.5	78.2	77.6	76.5	75.6	76.0	78.6	79.3	(22)
(23)		5%	DB	88.2	89.0	89.5	90.1	91.0	90.4	89.9	91.7	93.1	93.5	91.1	88.6	(23)
(24)			MCWB	78.8	78.7	78.9	79.3	79.2	78.0	77.3	76.2	75.7	76.6	78.8	79.1	(24)
(25)		10%	DB	86.7	87.4	87.9	88.6	89.5	89.0	88.6	90.0	91.5	91.6	89.1	86.7	(25)
(26)			MCWB	78.5	78.5	78.8	79.1	78.9	78.1	77.2	76.2	75.8	77.0	78.7	78.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.8	80.8	81.1	81.5	81.8	80.9	80.3	79.9	80.0	80.4	81.0	81.0	(27)
(28)			MCD B	88.0	88.0	88.7	89.7	89.9	88.7	88.6	89.6	89.0	89.3	89.3	88.7	(28)
(29)		2%	WB	79.9	79.9	80.1	80.6	80.8	80.0	79.4	78.9	78.9	79.6	80.1	80.0	(29)
(30)			MCD B	86.6	86.6	87.1	88.2	88.5	87.8	87.4	88.1	87.8	88.4	88.0	87.1	(30)
(31)		5%	WB	79.3	79.2	79.7	80.0	80.1	79.4	78.7	78.1	78.2	78.9	79.6	79.4	(31)
(32)			MCD B	85.4	85.5	86.4	87.0	87.3	86.9	86.6	87.0	87.0	87.7	87.2	85.9	(32)
(33)		10%	WB	78.9	78.9	79.1	79.4	79.5	78.8	78.1	77.3	77.4	78.3	79.0	78.9	(33)
(34)			MCD B	84.6	84.9	85.4	86.0	86.4	86.0	85.4	86.0	86.1	86.3	86.3	84.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.7	11.7	12.2	12.9	13.6	14.1	14.7	17.2	18.1	17.1	14.3	11.9	(35)
(36)			MCDBR	13.9	13.9	14.2	14.6	15.4	16.1	17.1	19.8	21.0	20.4	17.1	14.4	(36)
(37)			MCWBR	4.9	4.6	4.8	4.7	4.8	5.0	5.6	5.9	5.7	5.3	5.2	5.0	(37)
(38)		5% WB	MCD BR	12.7	12.4	12.9	13.5	14.1	14.2	15.0	16.4	16.6	16.3	14.8	13.0	(38)
(39)			MCWBR	5.0	4.7	4.9	4.9	4.9	5.2	5.5	5.8	5.5	5.3	5.3	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.423	0.441	0.431	0.415	0.414	0.415	0.437	0.505	0.574	0.586	0.509	0.435	(40)	
(41)		taud	2.437	2.378	2.403	2.458	2.458	2.464	2.383	2.144	1.937	1.915	2.158	2.402	(41)	
(42)		Ebn at Noon	289	285	284	281	273	269	264	252	242	243	263	285	(42)	
(43)		Edh at Noon	38	41	40	36	35	34	37	49	62	64	50	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1454	1485	1569	1590	1585	1479	1525	1709	1735	1651	1557	1434	(44)	
(45)		RadStd	69	83	56	65	69	136	163	151	138	120	56	81	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page