

SERANG, Indonesia

WMO: 967370

Lat: 6.1116S

Lon: 106.1319E

Elev: 131

StdP: 14.63

Time Zone: 7.00 (E07)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	71.3	72.4	66.0	96.5	83.2	67.4	101.2	82.5	17.5	83.0	14.3	84.6	0.2	250	0.309

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	15.3	92.8	77.9	91.8	78.0	91.0	78.0	81.0	88.5	80.5	88.0	80.0	87.4	6.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	151.2	84.8	78.3	147.8	84.1	78.0	146.3	83.8	44.8	89.1	44.2	88.5	43.7	87.8	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	10.3	8.9	68.6	95.1	1.7	1.4	67.4	96.1	66.4	97.0	65.4	97.8	64.2	98.8		
(5)			66.1	83.3	2.6	2.0	64.2	84.7	62.7	85.9	61.2	87.0	59.4	88.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	82.0	81.2	81.4	81.8	82.6	82.8	82.0	81.4	81.6	82.2	83.0	82.6	81.9	(6)
(7)		DBStd	1.70	1.90	1.65	1.62	1.56	1.54	1.53	1.34	1.41	1.33	1.50	1.83	1.84	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11698	968	879	987	979	1017	959	973	979	967	1023	978	989	(10)
(11)		CDD65	6223	503	459	522	529	552	509	508	514	517	558	528	524	(11)
(12)		CDH74	63146	4835	4430	5267	5520	5833	5147	4970	5190	5384	5953	5392	5225	(12)
(13)		CDH80	23223	1442	1349	1738	1999	2222	1921	1894	2065	2336	2529	2043	1685	(13)
(14)	Wind	WSAvg	2.5	3.3	2.6	2.8	2.6	2.0	1.8	2.0	2.3	2.3	2.3	3.1	(14)	
(15)	Precipitation	PrecAvg	64.5	12.2	9.8	6.7	5.7	4.6	2.4	2.8	2.6	2.4	3.6	5.2	6.9	(15)
(16)		PrecMax	86.7	25.5	22.9	12.1	10.9	13.9	7.7	7.6	6.7	8.5	7.8	12.0	11.1	(16)
(17)		PrecMin	40.5	2.6	1.7	2.3	1.1	1.2	0.0	0.0	0.0	0.0	0.0	1.1	1.3	(17)
(18)		PrecStd	11.5	5.2	5.0	3.1	2.2	3.0	2.0	2.1	2.2	2.4	2.6	2.9	3.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.2	90.8	91.7	92.6	92.3	91.5	91.2	91.5	93.4	94.5	94.3	92.2	(19)
(20)			MCWB	78.5	78.5	79.0	79.5	79.6	78.7	77.2	77.2	76.6	77.3	77.7	78.8	(20)
(21)		2%	DB	89.6	89.4	90.0	91.1	91.0	90.3	89.9	90.2	91.9	92.6	92.1	90.4	(21)
(22)			MCWB	78.3	79.2	78.8	79.6	79.4	78.5	77.0	77.0	76.5	77.6	77.8	78.4	(22)
(23)		5%	DB	88.1	88.1	88.7	89.8	89.9	89.3	89.0	89.3	90.8	91.4	90.7	89.1	(23)
(24)			MCWB	77.9	78.7	78.6	79.1	79.2	78.3	77.0	76.8	76.5	77.4	77.9	78.1	(24)
(25)		10%	DB	86.5	86.7	87.4	88.6	88.9	88.2	87.9	88.3	89.7	90.1	89.2	87.5	(25)
(26)			MCWB	77.7	78.4	78.4	79.0	78.9	78.0	76.9	76.4	76.5	77.3	77.8	77.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.6	81.0	81.6	81.8	81.7	80.9	80.1	79.9	80.1	80.7	80.7	80.5	(27)
(28)			MCDWB	88.0	87.9	88.8	89.6	88.9	88.2	87.3	88.5	88.8	89.3	89.3	88.7	(28)
(29)		2%	WB	79.6	80.1	80.3	80.8	80.7	80.0	79.3	78.9	79.1	79.7	79.7	79.6	(29)
(30)			MCDWB	86.6	86.8	87.1	88.4	88.2	87.5	86.6	87.1	87.9	88.3	88.1	87.4	(30)
(31)		5%	WB	78.9	79.5	79.6	80.1	80.0	79.5	78.6	78.2	78.3	79.0	79.0	79.0	(31)
(32)			MCDWB	85.7	85.9	86.2	87.3	87.3	86.8	85.9	86.0	87.0	87.6	87.1	86.5	(32)
(33)		10%	WB	78.3	78.9	79.0	79.5	79.5	78.9	78.0	77.6	77.7	78.3	78.4	78.3	(33)
(34)			MCDWB	84.4	85.0	85.3	86.4	86.5	86.0	85.0	85.2	86.2	86.6	86.0	85.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.8	11.1	11.8	12.5	13.2	13.4	14.5	15.2	16.3	15.3	13.7	11.4	(35)
(36)			MCDBR	13.1	13.0	13.6	14.2	14.4	14.7	15.7	16.0	17.8	17.3	16.1	13.6	(36)
(37)			MCWBR	4.3	4.9	4.9	5.1	4.8	4.9	5.2	5.2	5.6	5.1	4.7	4.5	(37)
(38)		5% WB	MCDWB	11.6	11.9	12.4	13.2	13.3	13.3	13.4	14.5	15.3	14.9	13.9	12.2	(38)
(39)			MCWBR	4.5	5.0	5.3	5.3	5.0	5.1	5.1	5.3	5.5	5.3	4.8	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.464	0.492	0.498	0.532	0.561	0.563	0.589	0.617	0.643	0.671	0.625	0.506	(40)	
(41)		taud	2.324	2.238	2.218	2.105	2.004	1.979	1.906	1.827	1.768	1.713	1.826	2.185	(41)	
(42)		Ebn at Noon	279	271	265	248	231	225	222	224	226	223	234	266	(42)	
(43)		Edh at Noon	43	47	48	51	54	54	59	67	73	79	70	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1496	1490	1597	1590	1530	1464	1552	1730	1823	1717	1544	1470	(44)	
(45)		RadStd	134	120	97	78	86	105	119	83	124	146	97	92	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.86	+1.10	N/A	+0.76	N/A	N/A	N/A	N/A	+238	+238

Nomenclature: See separate page