

CURUG BUDIARTO, Indonesia

WMO: 967390

Lat: 6.2871S

Lon: 106.5630E

Elev: 151

StdP: 14.62

Time Zone: 7.00 (E07)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	70.4	71.6	64.2	90.3	88.3	66.3	97.5	85.0	19.7	86.5	16.0	82.9	1.0	220	0.301

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	17.7	93.4	76.5	92.3	76.9	91.4	77.2	81.0	87.8	80.3	87.5	79.9	87.0	6.5	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.3	152.7	84.3	78.5	148.5	83.6	78.0	146.1	83.1	44.9	88.1	44.1	87.8	43.5	87.3	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	13.5	11.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	64.2	83.5	3.9	1.5	61.3	84.6	59.0	85.4	56.8	86.3	54.0	87.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.7	80.3	80.2	81.4	82.4	82.5	81.8	81.1	81.6	82.1	82.8	82.0	81.3
	DBStd	1.79	1.97	2.00	1.61	1.58	1.39	1.61	1.37	1.22	1.29	1.39	1.81	1.82
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11554	941	846	975	973	1008	954	965	981	964	1018	960	969
	CDD65	6079	476	426	510	523	543	504	500	516	514	553	510	504
	CDH74	56187	3961	3485	4505	4873	5278	4754	4663	5061	5075	5509	4602	4421
CDH80	20853	1073	948	1471	1738	2004	1793	1834	2150	2246	2512	1691	1393	
Wind	WSAvg	3.5	5.2	3.9	4.3	3.5	2.3	2.4	2.4	2.6	2.9	3.3	3.7	5.2
Precipitation	PrecAvg	129.0	15.6	15.5	12.7	12.9	11.5	7.8	6.4	6.3	6.6	10.1	12.7	11.1
	PrecMax	157.3	28.1	24.9	20.4	18.4	15.6	17.8	15.2	17.6	19.5	19.4	17.9	20.0
	PrecMin	96.3	7.5	7.2	6.3	4.1	6.2	2.0	1.1	1.5	1.0	2.5	5.5	3.9
	PrecStd	16.8	5.0	3.9	3.9	3.5	2.6	3.4	3.9	4.1	4.1	5.0	3.1	3.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.3	90.5	92.3	92.6	92.6	92.2	91.8	92.7	94.4	95.7	94.3	92.0
		MCWB	78.6	78.7	77.9	78.8	78.4	78.2	76.0	74.6	74.6	74.8	77.2	78.4
	2%	DB	89.1	88.6	90.4	91.2	91.1	90.8	90.7	91.4	92.5	93.5	92.0	90.1
		MCWB	78.2	78.6	78.5	79.1	78.6	78.2	76.2	75.3	75.6	76.1	77.7	78.3
	5%	DB	87.3	87.2	88.8	89.9	90.0	89.7	89.6	90.3	91.3	92.0	90.4	88.5
		MCWB	78.1	78.4	78.5	79.0	78.6	78.2	76.5	75.8	76.0	76.5	77.9	78.2
	10%	DB	85.6	85.7	87.3	88.5	88.8	88.5	88.3	89.2	89.9	90.6	88.6	86.9
		MCWB	77.7	78.2	78.2	78.8	78.6	78.0	76.6	76.1	76.3	76.7	77.9	77.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.8	81.5	81.8	81.3	81.9	81.4	80.0	79.5	80.0	80.1	81.0	80.8
		MCDB	87.2	86.8	86.6	88.6	88.6	88.2	86.0	87.3	88.5	88.7	88.1	87.6
	2%	WB	79.6	79.9	80.1	80.4	80.7	80.1	79.1	78.4	78.9	79.1	79.7	79.7
		MCDB	85.9	85.9	87.0	88.1	87.7	87.1	86.0	86.4	87.6	88.1	87.5	86.8
	5%	WB	78.8	79.1	79.3	79.8	79.9	79.5	78.4	77.9	78.1	78.4	78.9	79.0
		MCDB	85.0	85.1	86.1	87.2	86.7	86.5	85.6	86.0	86.7	87.3	87.2	86.2
	10%	WB	78.1	78.3	78.6	79.2	79.2	78.8	77.8	77.2	77.4	77.7	78.2	78.3
		MCDB	83.7	83.9	85.2	86.1	85.9	85.8	84.9	85.5	85.9	86.6	85.8	84.9
Mean Daily Temperature Range	5% DB	MDBR	11.0	11.0	13.0	13.7	14.3	14.7	16.2	17.2	17.5	17.7	14.4	12.4
		MCDBR	13.5	13.6	15.4	15.5	15.7	16.2	17.9	18.3	19.5	19.8	17.2	14.9
		MCWBR	5.0	5.4	5.8	5.1	5.2	5.6	6.0	5.6	5.8	5.3	5.3	5.3
	5% WB	MCDBR	11.9	12.3	13.7	14.2	14.2	14.8	15.1	16.5	16.3	16.8	14.8	13.1
		MCWBR	5.2	5.7	5.9	5.4	5.5	6.0	5.6	5.7	5.7	5.7	5.6	5.4
Clear-Sky Solar Irradiance	taub	0.480	0.508	0.517	0.551	0.573	0.571	0.590	0.621	0.647	0.686	0.650	0.530	
	taud	2.264	2.177	2.148	2.039	1.961	1.949	1.895	1.809	1.752	1.678	1.763	2.101	
	Ebn at Noon	274	266	260	243	228	223	221	223	225	220	228	259	
	Edh at Noon	46	50	51	55	56	56	60	68	75	82	75	54	
All-Sky Solar Radiation	RadAvg	1437	1414	1544	1544	1505	1459	1544	1703	1793	1673	1505	1447	
	RadStd	130	110	85	76	79	105	121	82	124	143	89	99	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+0.86	+1.10	N/A	+0.76	N/A	N/A	N/A	N/A	N/A	+238	+238

Nomenclature: See separate page