

JAKARTA TANJUNG PRIOK, Indonesia

WMO: 967410

Lat: 6.1078S

Lon: 106.8805E

Elev: 7

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	75.4	76.2	65.9	95.6	86.2	67.5	101.1	85.1	18.8	84.1	17.6	84.1	4.1	270	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	10.2	92.7	78.3	91.8	78.5	91.2	78.5	81.0	89.4	80.8	89.0	80.3	88.4	9.2	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	149.8	86.1	78.3	146.9	85.7	78.0	145.6	85.5	44.8	90.0	44.3	89.4	43.9	88.9	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.6	12.9	11.6	DB	72.4	96.4	4.4	2.7	69.2	98.4	66.6	99.9	64.1	101.4	60.9	103.3	(4)
(5)			WB	67.8	82.8	3.3	1.5	65.4	83.9	63.5	84.7	61.6	85.6	59.2	86.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	84.2	82.6	82.5	83.6	84.8	85.3	84.5	84.0	84.3	84.9	85.3	84.6	83.6
	DBStd	1.90	2.19	1.92	1.74	1.64	1.57	1.65	1.45	1.16	1.34	1.57	1.77	1.81
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12474	1009	909	1043	1045	1093	1035	1053	1064	1046	1095	1039	1043
	CDD65	6999	544	489	578	595	628	585	588	599	596	630	589	578
	CDH74	84900	6074	5447	6825	7362	7988	7265	7137	7335	7452	8028	7246	6741
CDH80	34672	2028	1804	2588	3181	3604	3091	2873	3013	3232	3652	3086	2520	
Wind	WSAvg	4.8	6.1	4.8	4.7	4.6	4.4	4.5	4.7	4.9	4.5	4.2	4.2	5.8
Precipitation	PrecAvg	74.9	15.8	12.6	8.9	5.4	4.8	3.6	1.9	2.4	2.2	4.0	5.2	7.7
	PrecMax	111.4	32.5	33.5	17.8	13.4	10.0	15.5	5.5	8.5	7.4	11.1	11.3	14.9
	PrecMin	51.0	5.2	3.9	2.0	1.6	0.2	0.0	0.0	0.0	0.0	0.0	1.1	2.8
	PrecStd	13.1	7.2	6.3	3.9	2.6	2.1	3.5	1.7	2.6	2.1	3.2	2.3	3.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.6	90.9	91.8	93.2	93.3	92.4	92.2	92.2	93.4	93.6	93.3	92.7
		MCWB	78.4	79.8	79.9	80.4	79.7	79.1	77.4	75.9	75.9	76.7	78.8	78.3
	2%	DB	89.8	89.4	90.4	91.6	91.9	91.1	90.8	90.7	91.5	91.9	91.5	90.8
		MCWB	78.7	79.5	79.7	80.0	79.4	78.8	77.0	76.5	76.6	77.6	79.0	79.1
	5%	DB	88.6	88.3	89.4	90.7	91.0	90.2	89.7	89.8	90.5	91.0	90.6	89.5
		MCWB	78.6	79.2	79.4	79.7	79.2	78.6	77.1	76.6	76.9	78.0	78.9	79.1
	10%	DB	87.2	87.2	88.4	89.8	90.1	89.4	88.7	88.9	89.6	90.0	89.7	88.3
		MCWB	78.4	78.9	79.1	79.5	79.1	78.4	77.0	76.7	77.2	78.2	78.7	78.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.9	80.9	81.3	81.8	81.6	81.0	80.0	79.8	80.0	80.4	80.9	81.3
		MCDB	88.6	88.3	89.3	90.8	90.4	89.1	88.3	87.9	88.9	89.4	89.3	89.6
	2%	WB	80.1	80.1	80.7	81.0	80.9	80.4	79.2	79.1	79.2	79.9	80.1	80.4
		MCDB	87.4	87.2	88.7	89.6	89.3	88.4	87.2	87.0	88.1	88.8	88.8	88.5
	5%	WB	79.5	79.7	80.1	80.5	80.3	79.9	78.8	78.4	78.7	79.2	79.7	79.8
		MCDB	86.5	86.6	87.7	88.9	88.5	87.7	86.6	86.3	87.5	88.1	88.4	87.6
	10%	WB	78.9	79.2	79.5	79.9	79.9	79.3	78.2	78.0	78.2	78.9	79.2	79.2
		MCDB	85.6	85.7	86.8	88.0	87.8	86.9	85.9	85.9	86.8	87.7	87.9	86.6
Mean Daily Temperature Range	5% DB	MDBR	8.7	8.9	9.6	10.2	10.0	10.0	10.4	10.5	10.6	10.2	10.2	9.4
		MCDBR	10.3	10.2	10.7	11.1	10.9	10.9	11.5	11.2	11.6	10.9	11.3	10.9
		MCWBR	4.4	4.3	4.4	4.4	3.8	3.8	3.9	3.8	4.0	4.0	4.5	4.7
	5% WB	MCDBR	9.4	9.5	10.0	10.6	10.2	10.0	10.1	10.3	10.3	10.1	10.5	10.0
		MCWBR	4.5	4.2	4.5	4.5	4.0	4.1	3.8	3.9	4.3	4.3	4.6	4.7
Clear-Sky Solar Irradiance	taub	0.489	0.513	0.517	0.536	0.549	0.549	0.562	0.590	0.616	0.658	0.629	0.532	
	taud	2.245	2.173	2.160	2.099	2.042	2.024	1.984	1.898	1.834	1.745	1.821	2.104	
	Ebn at Noon	272	265	260	247	234	229	228	230	232	226	233	259	
	Edh at Noon	47	50	50	51	52	52	55	62	69	76	71	53	
All-Sky Solar Radiation	RadAvg	1446	1427	1570	1570	1523	1467	1564	1732	1833	1709	1528	1453	
	RadStd	131	115	82	81	80	108	124	87	126	148	97	104	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (6 neighbors)	+0.86	+1.10	N/A	+0.76	N/A	N/A	N/A	N/A	+238	+238

Nomenclature: See separate page