

JAKARTA TANJUNG PRIOK, Indonesia

WMO: 967410

Lat: 6.1078S

Lon: 106.8805E

Elev: 2

StdP: 101.30

Time Zone: 7.00 (E07)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.1	24.5	18.8	13.7	30.1	19.7	14.4	29.5	8.4	28.9	7.9	29.0	1.8	270	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	5.6	33.7	25.7	33.2	25.8	32.9	25.8	27.2	31.9	27.1	31.7	26.8	31.3	4.1	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	30.1	25.7	21.0	29.9	25.6	20.8	29.7	86.4	32.2	85.3	31.9	84.3	31.6	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
6.5	5.8	5.2	22.5	35.8	2.5	1.5	20.7	36.9	19.2	37.7	17.9	38.6	16.1	39.6		
			19.9	28.2	1.8	0.8	18.6	28.8	17.5	29.3	16.5	29.8	15.1	30.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	29.0	28.1	28.0	28.7	29.3	29.6	29.2	28.9	29.1	29.4	29.6	29.2	28.7
	DBStd	1.05	1.22	1.07	0.97	0.91	0.87	0.92	0.81	0.65	0.75	0.87	0.98	1.01
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6930	561	505	579	581	607	575	585	591	581	608	577	579
	CDD18.3	3888	302	272	321	331	349	325	327	333	331	350	327	321
	CDH23.3	47167	3374	3026	3792	4090	4438	4036	3965	4075	4140	4460	4026	3745
	CDH26.7	19262	1127	1002	1438	1767	2002	1717	1596	1674	1796	2029	1714	1400
Wind	WSAvg	2.1	2.7	2.1	2.1	2.0	2.0	2.0	2.1	2.2	2.0	1.9	1.9	2.6
Precipitation	PrecAvg	1903	402	321	226	137	121	92	47	61	57	101	133	196
	PrecMax	2830	825	850	453	340	255	394	139	217	189	282	286	379
	PrecMin	1296	133	98	51	40	5	0	0	0	0	0	27	70
	PrecStd	332	183	160	99	66	54	89	44	66	54	81	58	91
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	32.7	33.2	34.0	34.1	33.6	33.4	33.5	34.1	34.2	34.0	33.7
		MCWB	25.8	26.6	26.6	26.9	26.5	26.1	25.2	24.4	24.4	24.9	26.0	25.7
	2%	DB	32.1	31.9	32.5	33.1	33.3	32.8	32.7	32.6	33.1	33.3	33.1	32.7
		MCWB	25.9	26.4	26.5	26.7	26.3	26.0	25.0	24.7	24.8	25.4	26.1	26.2
	5%	DB	31.4	31.3	31.9	32.6	32.8	32.4	32.1	32.1	32.5	32.8	32.6	32.0
		MCWB	25.9	26.2	26.3	26.5	26.2	25.9	25.0	24.8	25.0	25.6	26.1	26.2
	10%	DB	30.7	30.7	31.3	32.1	32.3	31.9	31.5	31.6	32.0	32.2	32.0	31.3
		MCWB	25.8	26.0	26.1	26.4	26.2	25.8	25.0	24.8	25.1	25.6	26.0	26.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.2	27.4	27.7	27.6	27.2	26.7	26.6	26.7	26.9	27.2	27.4
		MCDB	31.4	31.3	31.9	32.7	32.4	31.7	31.3	31.1	31.6	31.9	31.8	32.0
	2%	WB	26.7	26.7	27.1	27.2	27.1	26.9	26.2	26.1	26.2	26.6	26.7	26.9
		MCDB	30.8	30.7	31.5	32.0	31.8	31.4	30.7	30.6	31.2	31.5	31.5	31.4
	5%	WB	26.4	26.5	26.7	26.9	26.8	26.6	26.0	25.8	26.0	26.2	26.5	26.6
		MCDB	30.3	30.3	31.0	31.6	31.4	30.9	30.3	30.2	30.9	31.2	31.3	30.9
	10%	WB	26.1	26.2	26.4	26.6	26.6	26.3	25.7	25.6	25.6	26.1	26.2	26.2
		MCDB	29.8	29.8	30.5	31.1	31.0	30.5	30.0	29.9	30.5	31.0	31.0	30.3
Mean Daily Temperature Range	5% DB	MDBR	4.9	4.9	5.3	5.7	5.6	5.5	5.8	5.9	5.9	5.6	5.7	5.2
		MCDBR	5.7	5.7	5.9	6.2	6.1	6.1	6.4	6.2	6.4	6.1	6.3	6.1
		MCWBR	2.5	2.4	2.5	2.4	2.1	2.1	2.2	2.1	2.2	2.2	2.5	2.6
	5% WB	MCDBR	5.2	5.3	5.6	5.9	5.7	5.6	5.6	5.7	5.7	5.6	5.9	5.6
		MCWBR	2.5	2.3	2.5	2.5	2.2	2.3	2.1	2.2	2.4	2.4	2.5	2.6
Clear-Sky Solar Irradiance	taub	0.489	0.513	0.517	0.536	0.549	0.549	0.562	0.590	0.616	0.658	0.629	0.532	
	taud	2.245	2.173	2.160	2.099	2.042	2.024	1.984	1.898	1.834	1.745	1.821	2.104	
	Ebn at Noon	856	836	821	778	738	721	720	725	731	713	736	815	
	Edh at Noon	147	159	159	162	164	163	172	195	216	241	223	168	
All-Sky Solar Radiation	RadAvg	4.56	4.50	4.95	4.95	4.80	4.63	4.93	5.46	5.78	5.39	4.82	4.58	
	RadStd	0.41	0.36	0.26	0.26	0.25	0.34	0.39	0.27	0.40	0.47	0.31	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.48	+0.61	N/A	+0.42	N/A	N/A	N/A	N/A	+132	+132

Nomenclature: See separate page