

JAKARTA OBSERVATORY, Indonesia

WMO: 967450

Lat: 6.1560S

Lon: 106.8424E

Elev: 26

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	75.0	75.8	65.8	95.3	86.8	67.4	100.8	85.6	15.1	86.4	12.8	84.6	2.4	260	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	11.5	93.5	78.2	92.6	78.3	91.8	78.3	81.0	89.7	80.5	89.2	80.0	88.5	7.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.5	148.0	85.6	78.1	145.9	85.3	77.6	143.5	85.0	44.6	90.5	44.1	89.7	43.6	89.0	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.7	9.6	68.2	96.8	4.5	1.7	65.0	98.1	62.3	99.0	59.8	100.0	56.5	101.2		
(5)			65.1	84.3	2.9	3.3	63.0	86.7	61.3	88.6	59.7	90.4	57.6	92.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	84.1	82.2	81.9	83.5	84.6	85.3	84.6	84.0	84.4	84.9	85.4	84.5	83.5		
	DBStd	2.04	2.31	2.17	1.64	1.80	1.63	1.62	1.50	1.22	1.47	1.69	1.95	1.77		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	12438	1000	894	1038	1037	1094	1038	1055	1066	1046	1098	1035	1037		
	CDD65	6963	535	474	573	587	629	588	590	601	596	633	585	572		
	CDH74	83249	5793	5046	6641	7145	7945	7224	7073	7328	7396	8001	7083	6574		
	CDH80	33730	1873	1549	2438	3002	3580	3060	2862	3057	3229	3664	3000	2416		
(14) Wind	WSAvg	3.2	4.3	3.3	3.6	3.1	2.6	2.7	2.8	3.0	2.9	2.8	3.1	4.0		
(15) Precipitation	PrecAvg	74.9	15.8	12.6	8.9	5.4	4.8	3.6	1.9	2.4	2.2	4.0	5.2	7.7		
	PrecMax	111.4	32.5	33.5	17.8	13.4	10.0	15.5	5.5	8.5	7.4	11.1	11.3	14.9		
	PrecMin	51.0	5.2	3.9	2.0	1.6	0.2	0.0	0.0	0.0	0.0	0.0	1.1	2.8		
	PrecStd	13.1	7.2	6.3	3.9	2.6	2.1	3.5	1.7	2.6	2.1	3.2	2.3	3.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.5	91.0	92.5	93.3	93.5	92.7	92.2	92.7	94.3	94.9	94.6	92.4		
		MCWB	76.7	79.6	78.9	79.8	79.6	78.4	77.1	76.8	76.2	77.4	78.9	78.2		
	2%	DB	89.9	89.4	90.8	91.8	92.3	91.5	90.9	91.6	92.6	93.2	92.8	90.9		
		MCWB	78.0	78.9	79.0	79.6	79.4	78.4	77.0	76.9	76.7	78.0	79.0	78.5		
	5%	DB	88.6	87.9	89.5	90.8	91.3	90.5	90.1	90.6	91.3	91.9	91.4	89.6		
		MCWB	77.9	78.4	78.7	79.4	79.1	78.3	77.0	76.8	77.1	78.1	78.8	78.4		
	10%	DB	87.2	86.5	88.2	89.7	90.2	89.5	89.0	89.5	90.1	90.7	89.9	88.2		
		MCWB	77.6	78.1	78.3	79.1	78.9	78.1	76.9	76.6	77.0	78.0	78.6	78.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.6	81.0	81.7	81.7	80.9	80.1	79.8	80.0	80.6	81.2	80.8		
		MCDB	87.8	88.6	88.5	90.3	90.8	89.4	88.5	88.5	89.9	90.8	90.8	88.7		
	2%	WB	79.3	79.8	80.1	80.7	80.8	80.0	79.2	79.0	79.2	79.8	80.4	79.9		
		MCDB	86.7	87.1	87.8	89.5	89.5	88.3	87.5	88.0	88.8	89.8	90.0	87.9		
	5%	WB	78.9	79.1	79.6	80.1	80.1	79.5	78.6	78.3	78.7	79.2	79.8	79.2		
		MCDB	86.1	85.9	87.1	88.5	88.5	87.6	86.8	87.2	88.1	88.9	89.1	87.1		
	10%	WB	78.3	78.6	79.0	79.6	79.7	79.0	78.1	77.7	78.1	78.8	79.1	78.7		
		MCDB	85.0	85.0	86.3	87.8	87.8	86.9	86.1	86.5	87.2	88.3	88.1	86.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	8.7	9.9	10.7	10.8	10.7	11.1	11.6	11.8	11.5	11.2	9.9		
		MCDBR	11.0	10.7	11.7	12.1	11.8	11.8	12.3	12.7	13.1	13.0	13.1	11.8		
	5% WB	MCWBR	4.0	4.3	4.5	4.3	3.8	3.7	3.8	4.0	4.4	4.5	4.6	4.2		
		MCWBR	9.5	9.7	10.6	11.4	11.0	10.7	11.1	11.4	11.6	11.6	11.8	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.488	0.513	0.518	0.540	0.555	0.554	0.568	0.596	0.622	0.665	0.635	0.533		
		taud	2.244	2.169	2.153	2.083	2.023	2.007	1.966	1.880	1.817	1.729	1.805	2.097		
	Ebn at Noon		272	265	260	246	233	227	227	228	231	225	232	258		
		Edh at Noon	47	50	51	52	53	53	56	63	70	77	72	54		
(44) All-Sky Solar Radiation	RadAvg		1444	1423	1564	1564	1519	1466	1560	1726	1825	1702	1525	1453		
	RadStd		131	115	83	80	79	107	123	86	125	146	95	104		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.86	+1.10	N/A	+0.76	N/A	N/A	N/A	N/A	+238	+238

Nomenclature: See separate page