

JAKARTA OBSERVATORY, Indonesia

WMO: 967450

Lat: 6.1560S

Lon: 106.8424E

Elev: 8

StdP: 101.23

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.9	24.3	18.8	13.6	30.4	19.7	14.4	29.8	6.8	30.2	5.7	29.2	1.1	260	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	6.4	34.2	25.7	33.7	25.7	33.2	25.7	27.2	32.1	26.9	31.8	26.7	31.4	3.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.8	21.1	29.8	25.6	20.8	29.6	25.3	20.5	29.5	85.9	32.5	84.6	32.0	83.6	31.7	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.5	4.8	4.3	20.1	36.0	2.5	0.9	18.3	36.7	16.8	37.2	15.4	37.8	13.6	38.5		
(5)			18.4	29.1	1.6	1.8	17.2	30.4	16.3	31.4	15.4	32.5	14.2	33.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.9	27.9	27.7	28.6	29.2	29.6	29.2	28.9	29.1	29.4	29.7	29.2	28.6		
	DBStd	1.13	1.28	1.21	0.91	1.00	0.91	0.90	0.83	0.68	0.82	0.94	1.08	0.98		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6910	556	497	577	576	608	577	586	592	581	610	575	576		
	CDD18.3	3868	297	263	318	326	349	327	328	334	331	352	325	318		
	CDH23.3	46249	3218	2803	3689	3969	4414	4013	3929	4071	4109	4445	3935	3652		
	CDH26.7	18739	1041	861	1354	1668	1989	1700	1590	1698	1794	2036	1667	1342		
(14) Wind	WSAvg	1.4	1.9	1.5	1.6	1.4	1.2	1.2	1.2	1.3	1.3	1.3	1.4	1.8		
(15) Precipitation	PrecAvg	1903	402	321	226	137	121	92	47	61	57	101	133	196		
	PrecMax	2830	825	850	453	340	255	394	139	217	189	282	286	379		
	PrecMin	1296	133	98	51	40	5	0	0	0	0	27	70			
	PrecStd	332	183	160	99	66	54	89	44	66	54	81	58	91		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	32.8	33.6	34.1	34.2	33.7	33.4	33.7	34.6	35.0	34.8	33.6		
		MCWB	24.8	26.4	26.1	26.6	26.5	25.8	25.1	24.9	24.5	25.2	26.0	25.7		
	2%	DB	32.2	31.9	32.7	33.2	33.5	33.0	32.7	33.1	33.6	34.0	33.8	32.7		
		MCWB	25.6	26.1	26.1	26.5	26.3	25.8	25.0	24.9	24.8	25.6	26.1	25.8		
	5%	DB	31.4	31.1	31.9	32.7	32.9	32.5	32.3	32.6	33.0	33.3	33.0	32.0		
		MCWB	25.5	25.8	25.9	26.3	26.2	25.7	25.0	24.9	25.0	25.6	26.0	25.8		
	10%	DB	30.6	30.3	31.2	32.1	32.3	32.0	31.7	31.9	32.3	32.6	32.2	31.2		
		MCWB	25.4	25.6	25.7	26.2	26.1	25.6	25.0	24.8	25.0	25.6	25.9	25.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	27.0	27.2	27.6	27.6	27.2	26.7	26.6	26.7	27.0	27.3	27.1		
		MCDB	31.0	31.4	31.4	32.4	32.7	31.9	31.4	31.4	32.1	32.7	32.7	31.5		
	2%	WB	26.3	26.6	26.7	27.1	27.1	26.7	26.2	26.1	26.2	26.6	26.9	26.6		
		MCDB	30.4	30.6	31.0	32.0	31.9	31.3	30.8	31.1	31.6	32.1	32.2	31.0		
	5%	WB	26.1	26.2	26.4	26.7	26.7	26.4	25.9	25.7	25.9	26.2	26.5	26.2		
		MCDB	30.0	29.9	30.6	31.4	31.4	30.9	30.5	30.7	31.2	31.6	31.7	30.6		
	10%	WB	25.7	25.9	26.1	26.4	26.5	26.1	25.6	25.4	25.6	26.0	26.2	25.9		
		MCDB	29.5	29.4	30.1	31.0	31.0	30.5	30.1	30.3	30.7	31.3	31.2	30.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	4.9	5.5	6.0	6.0	5.9	6.2	6.4	6.5	6.4	6.2	5.5		
		MCDBR	6.1	5.9	6.5	6.7	6.6	6.6	6.9	7.0	7.3	7.2	7.3	6.5		
	5% WB	MCWBR	2.2	2.4	2.5	2.4	2.1	2.0	2.1	2.2	2.5	2.5	2.6	2.3		
		MCWBR	5.3	5.4	5.9	6.3	6.1	6.0	6.2	6.3	6.4	6.4	6.6	5.8		
(40) Clear-Sky Solar Irradiance	taub		0.488	0.513	0.518	0.540	0.555	0.554	0.568	0.596	0.622	0.665	0.635	0.533		
		taud	2.244	2.169	2.153	2.083	2.023	2.007	1.966	1.880	1.817	1.729	1.805	2.097		
	Ebn at Noon		857	835	819	775	733	717	716	720	727	709	732	814		
		Edh at Noon	147	159	160	165	167	166	175	199	220	244	227	169		
(44) All-Sky Solar Radiation	RadAvg		4.55	4.49	4.93	4.93	4.79	4.62	4.92	5.44	5.75	5.37	4.81	4.58		
	RadStd		0.41	0.36	0.26	0.25	0.25	0.34	0.39	0.27	0.40	0.46	0.30	0.33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.48	+0.61	N/A	+0.42	N/A	N/A	N/A	N/A	+132	+132

Nomenclature: See separate page