

JAKARTA SOEKARNO-HATTA, Indonesia

WMO: 967490

Lat: 6.1255S

Lon: 106.6590E

Elev: 8

StdP: 101.23

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.3	22.9	18.0	12.9	29.0	19.0	13.8	28.3	10.0	28.5	8.6	28.5	1.4	190	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	8.6	34.0	25.4	33.2	25.6	33.0	25.6	27.7	31.3	27.3	31.0	27.0	30.8	4.9	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.6	30.0	26.2	21.7	29.3	26.1	21.5	29.2	88.4	31.5	86.8	31.4	85.4	30.9	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.8	6.8	DB	20.3	35.4	2.0	1.1	18.8	36.2	17.6	36.8	16.5	37.4	15.0	38.2	(4)
(5)			WB	18.4	28.8	1.7	1.0	17.1	29.5	16.1	30.1	15.1	30.7	13.9	31.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	27.2	27.2	27.9	28.3	28.4	28.0	27.7	27.8	28.2	28.5	28.4	27.9	(6)
(7)		DBStd	0.97	1.07	0.97	0.88	0.86	0.81	0.81	0.77	0.79	0.74	0.80	0.95	1.02	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6560	534	482	554	551	571	541	549	552	546	574	552	554	(10)
(11)		CDD18.3	3518	276	248	296	301	312	291	291	294	296	316	302	296	(11)
(12)		CDH23.3	37032	2644	2338	2994	3233	3497	3147	3063	3147	3257	3506	3206	3000	(12)
(13)		CDH26.7	14030	803	673	1039	1254	1401	1218	1161	1231	1381	1513	1291	1067	(13)
(14)	Wind	WSAvg	2.8	3.2	2.8	2.9	2.7	2.5	2.6	2.6	2.8	2.7	2.7	2.8	3.4	(14)
(15)	Precipitation	PrecAvg	2137	379	370	221	189	163	99	87	61	70	125	180	206	(15)
(16)		PrecMax	2690	750	671	336	279	250	241	333	248	318	375	275	475	(16)
(17)		PrecMin	1397	135	183	112	66	83	5	0	0	0	68	59	59	(17)
(18)		PrecStd	371	150	136	63	62	49	60	82	68	74	107	57	91	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	32.4	33.2	34.0	33.8	33.2	33.1	33.2	34.1	34.4	34.4	34.1	(19)
(20)			MCWB	25.4	26.2	26.2	26.2	26.4	25.9	25.0	24.6	24.4	25.0	25.5	25.6	(20)
(21)		2%	DB	32.1	31.7	32.4	33.1	33.0	32.8	32.2	32.7	33.2	33.9	33.8	33.0	(21)
(22)			MCWB	25.7	26.2	26.2	26.3	26.4	25.9	25.1	24.7	24.9	25.2	25.7	25.8	(22)
(23)		5%	DB	31.1	30.9	31.9	32.2	32.2	32.1	31.9	32.1	32.8	33.1	33.0	32.1	(23)
(24)			MCWB	25.9	26.1	26.2	26.4	26.3	25.8	25.1	24.9	25.0	25.2	25.7	25.7	(24)
(25)		10%	DB	30.2	30.0	31.1	31.9	31.9	31.8	31.2	31.4	32.1	32.3	32.1	31.1	(25)
(26)			MCWB	25.8	25.9	26.2	26.3	26.3	25.7	25.1	24.9	25.0	25.3	25.6	25.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	27.5	27.9	28.1	28.1	27.7	27.3	27.2	27.4	27.6	27.5	(27)	
(28)			MCD B	30.4	30.4	31.1	31.6	31.7	31.2	30.9	31.1	31.6	31.5	31.7	31.1	(28)
(29)		2%	WB	26.8	26.8	27.2	27.5	27.6	27.1	26.7	26.5	26.6	26.7	27.0	26.7	(29)
(30)			MCD B	29.8	29.7	30.7	31.2	31.2	30.8	30.3	30.4	31.1	31.1	31.0	30.6	(30)
(31)		5%	WB	26.4	26.5	26.7	27.0	27.1	26.7	26.2	26.1	26.2	26.4	26.5	26.4	(31)
(32)			MCD B	29.4	29.3	30.2	30.9	30.9	30.3	29.8	29.9	30.6	30.8	30.7	30.3	(32)
(33)		10%	WB	26.0	26.1	26.3	26.6	26.7	26.3	25.9	25.6	25.7	26.0	26.1	26.1	(33)
(34)			MCD B	29.0	29.0	29.8	30.3	30.3	29.9	29.4	29.6	30.2	30.5	30.4	29.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	6.2	7.0	7.5	7.6	7.8	8.1	8.4	8.8	8.6	8.0	7.2	(35)
(36)			MCDBR	7.6	7.1	7.9	8.1	8.0	8.3	8.4	8.7	9.3	9.3	9.0	8.4	(36)
(37)			MCWBR	3.4	3.4	3.5	3.4	3.3	3.3	3.3	3.5	3.4	3.4	3.4	3.3	(37)
(38)		5% WB	MCD BR	6.6	6.4	7.3	7.6	7.6	7.8	7.9	8.2	8.6	8.5	8.0	7.4	(38)
(39)			MCWBR	3.4	3.4	3.5	3.5	3.5	3.5	3.5	3.7	3.6	3.5	3.5	3.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.483	0.509	0.514	0.539	0.559	0.559	0.577	0.606	0.632	0.670	0.634	0.527	(40)	
(41)		taud	2.262	2.182	2.164	2.085	2.011	1.993	1.942	1.857	1.794	1.717	1.805	2.117	(41)	
(42)		Ebn at Noon	862	839	822	775	730	713	709	713	720	704	732	819	(42)	
(43)		Edh at Noon	145	157	158	164	169	168	179	204	225	247	227	166	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.58	4.52	4.94	4.93	4.78	4.61	4.91	5.43	5.73	5.34	4.79	4.58	(44)	
(45)		RadStd	0.40	0.35	0.26	0.25	0.26	0.34	0.39	0.27	0.39	0.46	0.29	0.31	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.48	+0.61	N/A	+0.42	N/A	N/A	N/A	N/A	+132	+132
(47) Regional (7 neighbors)		+0.48	+0.61	N/A	+0.42	N/A	N/A	N/A	N/A	+132	+132

Nomenclature: See separate page