

CIREBON JATIWANGI, Indonesia

WMO: 967910

Lat: 6.7343S

Lon: 108.2630E

Elev: 50

StdP: 100.73

Time Zone: 7.00 (E07)

Period: 83-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.0	22.7	15.6	11.2	29.4	16.7	12.0	28.7	5.6	29.2	5.2	29.9	0.5	N/A	0.308

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	9.5	35.7	24.3	34.8	24.5	34.1	24.7	27.4	31.9	27.1	31.5	26.7	31.1	3.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.8	29.4	25.9	21.4	29.0	25.7	21.0	28.8	87.1	31.8	85.5	31.6	84.4	31.4	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.6	3.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.3	27.5	27.4	28.0	28.4	28.5	28.1	27.8	28.2	29.0	29.9	29.2	28.1	
	DBStd	1.19	1.16	1.08	0.80	0.81	0.81	0.81	0.81	0.76	0.97	1.13	1.30	1.01	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD10.0	6689	541	487	559	553	573	542	551	564	569	616	574	562	
	CDD18.3	3648	283	253	301	303	314	292	292	306	319	357	324	303	
	CDH23.3	37432	2501	2151	2778	3088	3367	3038	2991	3278	3569	4255	3554	2863	
	CDH26.7	15111	772	669	1008	1162	1361	1227	1211	1428	1650	2064	1544	1015	
Wind	WSAvg	1.1	1.0	0.9	0.9	0.8	0.9	1.0	1.3	1.7	1.5	1.5	1.1	0.9	
Precipitation	PrecAvg	2701	468	381	396	241	167	84	49	24	47	123	267	429	
	PrecMax	3697	714	736	717	580	476	335	181	105	228	394	542	848	
	PrecMin	1715	222	94	162	38	4	0	0	0	0	0	39	176	
	PrecStd	529	118	150	163	125	119	79	56	37	59	117	140	143	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.4	33.0	33.6	33.7	34.0	33.6	33.5	34.2	35.9	37.0	36.9	34.2	
		MCWB	26.6	26.6	26.3	26.7	26.2	25.7	24.1	23.7	23.4	23.5	26.3	26.7	
	2%	DB	32.3	32.1	32.9	33.1	33.2	33.1	32.9	33.5	34.9	35.9	35.3	33.1	
		MCWB	26.4	26.5	26.2	26.4	26.1	25.5	24.2	23.8	23.6	23.8	25.6	26.4	
	5%	DB	31.4	31.4	32.2	32.4	32.8	32.6	32.4	33.0	34.1	35.1	34.2	32.3	
		MCWB	26.1	26.3	26.2	26.3	26.1	25.5	24.3	23.8	23.7	24.2	25.5	26.1	
	10%	DB	30.4	30.5	31.4	31.7	32.1	31.9	31.8	32.3	33.3	34.2	32.9	31.3	
		MCWB	25.8	26.0	26.1	26.2	26.0	25.5	24.4	23.8	23.9	24.4	25.6	26.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.6	27.6	28.0	27.7	27.2	26.6	26.2	26.5	26.7	27.8	27.5
			MCDB	31.6	31.5	31.7	32.2	31.8	31.7	31.1	30.9	31.7	32.5	34.2	32.4
2%		WB	26.7	26.9	27.0	27.2	27.1	26.7	26.1	25.7	26.0	26.2	26.7	26.9	
		MCDB	30.9	31.0	31.2	31.2	31.5	31.1	30.4	30.3	30.8	32.0	31.8	31.7	
5%		WB	26.4	26.5	26.6	26.8	26.7	26.4	25.7	25.2	25.6	25.7	26.3	26.5	
		MCDB	30.3	30.3	30.7	30.7	31.0	30.8	29.9	30.0	30.6	31.5	31.4	30.9	
10%		WB	26.0	26.1	26.2	26.5	26.4	26.1	25.3	24.9	25.1	25.4	26.0	26.2	
		MCDB	29.7	29.7	30.2	30.3	30.6	30.4	29.4	29.8	30.3	31.1	31.1	30.2	
Mean Daily Temperature Range	5% DB	MDBR	6.5	6.8	7.7	7.5	7.9	8.3	8.8	9.4	9.6	9.5	8.4	7.4	
		MCDBR	7.9	8.0	8.6	8.3	8.7	9.1	9.6	10.0	10.6	10.5	10.0	8.5	
		MCWBR	2.9	3.2	3.1	2.9	3.2	3.7	3.5	3.6	3.3	3.0	3.0	2.9	
	5% WB	MCDBR	7.3	7.6	8.0	7.6	7.8	8.2	8.1	8.7	8.7	9.0	8.7	7.9	
		MCWBR	3.0	3.3	3.2	3.0	3.0	3.5	3.1	3.3	3.2	3.0	3.0	2.9	
Clear-Sky Solar Irradiance	taub		0.517	0.524	0.524	0.529	0.510	0.503	0.496	0.514	0.530	0.593	0.597	0.558	
	taud		2.136	2.122	2.124	2.103	2.143	2.147	2.159	2.086	2.046	1.887	1.891	2.007	
	Ebn at Noon		832	827	814	783	769	758	773	783	797	762	761	794	
	Edh at Noon		164	167	164	161	148	144	144	162	175	209	208	186	
All-Sky Solar Radiation	RadAvg		4.70	4.61	5.08	4.98	4.84	4.62	4.87	5.44	5.75	5.50	5.00	4.74	
	RadStd		0.40	0.46	0.26	0.24	0.23	0.32	0.36	0.27	0.38	0.50	0.34	0.35	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	+0.48	+0.61	N/A	+0.42	N/A	N/A	N/A	N/A	+132	+132

Nomenclature: See separate page