

TEGAL, Indonesia

WMO: 967970

Lat: 6.8681S

Lon: 109.1210E

Elev: 33

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	73.0	73.9	63.5	87.9	80.3	65.1	93.1	79.9	22.1	81.6	18.6	82.4	4.5	200	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	11.9	91.7	77.4	90.8	77.7	90.0	77.9	81.0	87.9	80.7	87.7	80.1	87.1	7.9	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.2	85.5	78.5	148.2	85.0	78.2	146.5	84.6	44.8	88.6	44.3	88.2	43.9	87.7	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	13.6	11.6	DB	70.9	95.2	1.5	2.3	69.8	96.9	68.9	98.2	68.1	99.5	67.0	101.2	(4)
(5)			WB	66.0	82.9	2.3	1.9	64.4	84.2	63.0	85.3	61.8	86.4	60.1	87.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.6	81.7	81.3	82.4	83.4	83.6	82.8	81.8	81.7	82.7	83.8	83.5	82.8
	DBStd	1.63	1.75	1.53	1.44	1.31	1.26	1.34	1.25	1.32	1.30	1.22	1.45	1.67
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11914	983	876	1006	1003	1040	984	986	984	981	1049	1006	1016
	CDD65	6439	518	456	541	553	575	534	521	519	531	584	556	551
	CDH74	69707	5208	4455	5778	6391	6681	5874	5272	5275	5736	6799	6309	5929
CDH80	24963	1499	1230	1906	2396	2599	2207	1929	1943	2200	2685	2363	2006	
Wind	WSAvg	4.7	5.2	4.7	4.0	3.9	4.1	4.4	4.6	5.2	5.4	5.3	4.5	4.5
Precipitation	PrecAvg	70.0	14.4	12.6	9.3	5.4	5.0	3.3	2.0	1.3	1.3	2.0	5.5	10.6
	PrecMax	102.4	25.9	25.6	24.5	15.0	11.1	12.8	8.0	10.0	7.5	8.5	14.7	24.7
	PrecMin	43.9	6.0	2.4	2.2	0.0	0.7	0.0	0.0	0.0	0.0	0.0	0.0	2.2
	PrecStd	15.9	5.4	5.4	5.4	3.7	3.1	3.1	2.1	2.2	1.9	2.3	4.1	5.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.8	89.7	90.9	91.2	91.4	90.9	90.6	90.8	92.6	93.1	92.5	91.9
		MCWB	78.8	79.9	79.4	79.7	79.3	77.5	75.7	75.3	75.6	76.5	77.8	78.9
	2%	DB	89.1	88.1	89.1	89.9	90.3	89.9	89.3	89.5	90.9	91.2	90.8	90.0
		MCWB	79.0	79.4	79.6	79.6	79.2	77.9	76.3	75.6	75.4	76.8	78.3	79.0
	5%	DB	87.6	87.1	88.2	89.1	89.6	89.1	88.4	88.4	89.5	90.0	89.8	89.0
		MCWB	78.9	79.2	79.3	79.5	79.1	78.0	76.4	75.7	75.7	77.2	78.4	79.0
	10%	DB	86.2	86.0	87.2	88.3	88.8	88.2	87.5	87.4	88.4	89.1	88.8	87.8
		MCWB	78.7	79.0	79.1	79.3	78.9	77.8	76.4	75.8	76.0	77.4	78.4	78.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.1	81.8	81.6	81.5	80.8	79.9	79.6	79.8	80.1	80.8	81.0
		MCDB	87.5	87.1	87.7	88.5	88.8	88.0	87.1	86.8	86.8	88.8	88.9	88.0
	2%	WB	80.1	80.1	80.8	80.8	80.8	80.0	79.1	78.7	78.9	79.3	80.0	80.2
		MCDB	86.5	86.1	87.3	88.0	88.1	87.2	86.4	86.1	86.2	88.0	88.1	87.4
	5%	WB	79.6	79.7	80.1	80.1	80.2	79.5	78.4	77.8	78.2	78.9	79.4	79.8
		MCDB	85.8	85.6	86.4	87.1	87.3	86.7	85.7	85.5	85.8	87.6	87.6	86.9
	10%	WB	79.1	79.2	79.5	79.8	79.7	79.0	77.7	77.0	77.4	78.3	78.9	79.2
		MCDB	84.9	84.8	85.7	86.6	86.7	86.0	84.8	85.0	85.2	86.7	87.1	86.1
Mean Daily Temperature Range	5% DB	MDBR	9.4	9.3	10.1	10.4	11.2	11.8	12.9	12.9	13.0	11.9	11.2	10.5
		MCDBR	11.2	10.8	11.2	11.1	11.9	12.7	13.7	13.7	14.3	12.9	12.3	11.9
		MCWBR	4.7	4.8	4.7	4.1	4.5	4.8	5.4	5.5	5.1	4.7	4.7	4.7
	5% WB	MCDBR	10.2	10.1	10.4	10.5	11.0	11.0	11.6	11.6	11.7	11.5	11.2	10.9
		MCWBR	4.8	4.9	4.9	4.4	4.6	4.7	4.9	5.4	5.1	4.8	4.8	4.9
Clear-Sky Solar Irradiance	taub	0.545	0.556	0.550	0.565	0.544	0.535	0.534	0.553	0.581	0.657	0.646	0.583	
	taud	2.061	2.034	2.054	2.001	2.042	2.054	2.047	1.980	1.915	1.743	1.779	1.941	
	Ebn at Noon	257	254	252	239	234	232	235	239	240	226	230	245	
	Edh at Noon	56	58	56	56	52	50	51	57	63	76	74	63	
All-Sky Solar Radiation	RadAvg	1501	1496	1632	1600	1557	1490	1568	1752	1861	1787	1606	1495	
	RadStd	134	136	89	75	81	100	105	75	108	164	130	120	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	+0.58	N/A	N/A	+0.70	+0.63	+0.85	N/A	N/A	N/A	N/A

Nomenclature: See separate page