

CILACAP, Indonesia

WMO: 968050

Lat: 7.7187S

Lon: 109.0149E

Elev: 20

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	71.4	72.9	67.5	101.1	74.7	68.6	105.0	75.8	20.4	79.3	18.6	80.0	1.5	100	0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.0	90.6	79.6	89.8	79.5	89.1	79.3	81.2	88.1	80.8	87.7	80.2	86.9	7.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	151.5	85.5	78.7	149.1	85.0	78.2	146.8	84.5	44.9	88.7	44.4	88.1	43.9	87.6	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	13.9	12.0	68.7	93.0	2.5	0.9	66.9	93.6	65.4	94.1	64.0	94.7	62.2	95.3		
(5)			66.7	83.5	2.7	2.2	64.8	85.1	63.2	86.4	61.6	87.6	59.6	89.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	82.6	82.5	82.7	83.0	82.6	81.0	79.3	78.8	79.7	81.1	81.7	82.1
	DBStd	2.12	1.60	1.44	1.43	1.27	1.40	1.77	1.95	1.79	1.62	1.46	1.62	1.74
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11468	1009	909	1014	990	1011	931	907	894	892	964	952	995
	CDD65	5993	544	489	549	540	546	481	442	429	442	499	502	530
	CDH74	59908	5645	5022	5872	5985	6155	4864	3745	3359	3758	4871	5134	5498
CDH80	17874	1922	1740	2094	2168	2124	1329	734	543	725	1201	1541	1753	
Wind	WSAvg	4.8	3.7	3.4	3.4	3.3	4.7	5.4	6.5	7.4	6.6	5.7	3.8	3.4
Precipitation	PrecAvg	120.9	13.0	9.4	11.3	11.9	10.5	10.2	5.8	4.3	5.4	14.3	16.9	14.4
	PrecMax	212.1	31.7	16.4	23.7	28.4	33.4	29.6	28.6	33.6	34.0	56.7	34.6	27.0
	PrecMin	46.0	3.8	5.0	3.5	3.1	0.1	0.0	0.0	0.0	0.0	0.3	0.2	2.6
	PrecStd	44.6	5.9	2.9	5.2	5.9	7.9	8.1	8.3	7.5	8.6	14.1	9.6	6.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.6	91.5	91.4	90.8	90.1	89.4	88.0	86.9	87.3	88.1	89.4	90.7
		MCWB	79.1	79.3	80.0	80.6	80.3	80.0	79.6	78.7	78.9	78.9	79.1	79.6
	2%	DB	90.0	90.0	90.0	89.7	89.0	87.7	86.2	85.1	85.9	86.9	88.3	89.2
		MCWB	78.9	79.3	79.5	80.2	79.9	79.5	78.3	77.4	77.9	78.4	79.1	79.0
	5%	DB	89.0	89.0	89.1	88.9	88.1	86.5	84.9	83.8	84.7	86.1	87.5	88.2
		MCWB	78.7	79.1	79.3	79.8	79.5	78.7	77.4	76.4	77.1	78.1	79.0	78.8
	10%	DB	87.9	87.9	88.1	88.0	87.3	85.5	83.6	82.8	83.6	85.2	86.5	87.2
		MCWB	78.5	78.8	79.0	79.5	79.2	78.2	76.6	75.8	76.5	77.8	78.8	78.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.2	81.6	81.8	81.8	80.8	80.1	79.4	79.9	80.3	81.0	80.9
		MCDB	88.6	88.7	89.1	88.9	88.2	87.1	86.3	85.4	85.5	86.0	86.6	88.1
	2%	WB	80.1	80.3	80.7	81.0	80.9	79.9	79.1	78.2	78.9	79.6	80.1	80.1
		MCDB	87.5	87.9	88.4	88.0	87.3	86.1	84.9	83.8	84.5	85.2	86.3	87.2
	5%	WB	79.5	79.7	80.0	80.5	80.2	79.3	78.1	77.3	78.0	79.0	79.7	79.5
		MCDB	86.7	87.0	87.3	87.3	86.4	85.1	83.5	82.6	83.3	84.5	85.7	86.3
	10%	WB	78.9	79.1	79.4	79.9	79.7	78.8	77.3	76.5	77.2	78.3	79.1	79.0
		MCDB	85.8	86.1	86.2	86.3	85.7	84.3	82.2	81.6	82.3	83.5	85.0	85.5
Mean Daily Temperature Range	5% DB	MDBR	11.5	11.8	11.5	11.0	9.9	9.1	8.8	8.4	8.4	8.7	9.8	10.2
		MCDBR	12.8	13.1	12.5	11.8	10.7	10.0	9.8	8.9	9.2	9.5	10.8	11.7
		MCWBR	4.2	4.6	4.5	4.3	4.1	4.0	4.4	3.9	3.7	3.7	4.2	4.1
	5% WB	MCDBR	11.8	12.2	11.9	11.3	10.2	9.6	9.3	8.4	8.8	9.0	10.3	11.1
	MCWBR	4.4	4.8	4.7	4.6	4.3	4.1	4.3	3.9	3.8	4.0	4.6	4.4	
Clear-Sky Solar Irradiance	taub	0.484	0.497	0.499	0.516	0.506	0.498	0.493	0.503	0.533	0.598	0.600	0.514	
	taud	2.258	2.223	2.216	2.158	2.169	2.179	2.175	2.131	2.049	1.882	1.895	2.159	
	Ebn at Noon	273	270	265	251	244	241	245	251	252	240	241	264	
	Edh at Noon	46	48	48	48	45	44	45	49	55	67	66	51	
All-Sky Solar Radiation	RadAvg	1603	1596	1643	1592	1537	1471	1513	1702	1779	1702	1563	1551	
	RadStd	127	100	96	85	90	104	118	85	131	197	134	118	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	+0.58	N/A	N/A	+0.70	+0.63	+0.85	N/A	N/A	N/A	N/A

Nomenclature: See separate page