

CILACAP, Indonesia

WMO: 968050

Lat: 7.7187S

Lon: 109.0149E

Elev: 6

StdP: 101.25

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.9	22.7	19.7	14.4	23.7	20.3	15.0	24.3	9.1	26.3	8.3	26.7	0.7	100	0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	6.1	32.6	26.5	32.1	26.4	31.7	26.3	27.3	31.2	27.1	30.9	26.8	30.5	3.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	29.7	25.9	21.3	29.5	25.7	21.0	29.2	86.7	31.5	85.3	31.2	84.2	30.9	31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	6.2	5.4	DB	20.4	33.9	1.4	0.5	19.4	34.2	18.6	34.5	17.8	34.8	16.8	35.2	(4)
(5)			WB	19.3	28.6	1.5	1.2	18.2	29.5	17.3	30.2	16.5	30.9	15.4	31.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	28.1	28.0	28.2	28.3	28.1	27.2	26.3	26.0	26.5	27.3	27.6	27.8	(6)
(7)		DBStd	1.18	0.89	0.80	0.80	0.71	0.78	0.98	1.09	0.99	0.90	0.81	0.90	0.97	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6371	561	505	563	550	562	517	504	497	496	536	529	553	(10)
(11)		CDD18.3	3329	302	272	305	300	303	267	246	238	246	277	279	294	(11)
(12)		CDH23.3	33282	3136	2790	3262	3325	3419	2702	2081	1866	2088	2706	2852	3054	(12)
(13)		CDH26.7	9930	1068	967	1163	1204	1180	738	408	302	403	667	856	974	(13)
(14)	Wind	WSAvg	2.1	1.6	1.5	1.5	1.5	2.1	2.4	2.9	3.3	3.0	2.5	1.7	1.5	(14)
(15)	Precipitation	PrecAvg	3070	330	238	287	302	266	258	148	110	138	363	428	367	(15)
(16)		PrecMax	5387	804	416	601	721	848	752	727	853	863	1441	878	685	(16)
(17)		PrecMin	1169	96	126	89	78	2	0	0	0	0	8	4	67	(17)
(18)		PrecStd	1134	150	74	131	151	201	207	210	190	218	358	245	153	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	33.1	33.0	32.7	32.3	31.9	31.1	30.5	30.7	31.1	31.9	32.6	(19)
(20)			MCWB	26.1	26.3	26.7	27.0	26.9	26.7	26.4	25.9	26.1	26.0	26.2	26.5	(20)
(21)		2%	DB	32.2	32.2	32.2	32.1	31.7	31.0	30.1	29.5	29.9	30.5	31.3	31.8	(21)
(22)			MCWB	26.1	26.3	26.4	26.8	26.6	26.4	25.7	25.2	25.5	25.8	26.2	26.1	(22)
(23)		5%	DB	31.7	31.7	31.7	31.6	31.2	30.3	29.4	28.8	29.3	30.0	30.8	31.2	(23)
(24)			MCWB	26.0	26.2	26.3	26.6	26.4	26.0	25.2	24.7	25.1	25.6	26.1	26.0	(24)
(25)		10%	DB	31.0	31.1	31.2	31.1	30.7	29.7	28.6	28.2	28.7	29.6	30.3	30.7	(25)
(26)			MCWB	25.8	26.0	26.1	26.4	26.2	25.7	24.8	24.3	24.7	25.4	26.0	25.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.3	27.6	27.7	27.7	27.1	26.7	26.4	26.6	26.8	27.2	27.2	(27)
(28)			MCDWB	31.4	31.5	31.7	31.6	31.2	30.6	30.2	29.7	29.7	30.0	30.3	31.2	(28)
(29)		2%	WB	26.7	26.9	27.1	27.2	27.2	26.6	26.2	25.7	26.1	26.4	26.7	26.7	(29)
(30)			MCDWB	30.8	31.1	31.3	31.1	30.7	30.1	29.4	28.8	29.2	29.6	30.2	30.6	(30)
(31)		5%	WB	26.4	26.5	26.7	26.9	26.8	26.3	25.6	25.1	25.6	26.1	26.5	26.4	(31)
(32)			MCDWB	30.4	30.6	30.7	30.7	30.2	29.5	28.6	28.1	28.5	29.2	29.8	30.2	(32)
(33)		10%	WB	26.1	26.2	26.3	26.6	26.5	26.0	25.2	24.7	25.1	25.7	26.2	26.1	(33)
(34)			MCDWB	29.9	30.1	30.1	30.2	29.8	29.1	27.9	27.6	27.9	28.6	29.5	29.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	6.5	6.4	6.1	5.5	5.1	4.9	4.7	4.7	4.8	5.5	5.7	(35)
(36)			MCDBR	7.1	7.3	7.0	6.5	5.9	5.5	5.4	4.9	5.1	5.3	6.0	6.5	(36)
(37)			MCWBR	2.3	2.5	2.5	2.4	2.3	2.2	2.4	2.2	2.1	2.0	2.3	2.3	(37)
(38)		5% WB	MCDBR	6.6	6.8	6.6	6.3	5.6	5.4	5.2	4.6	4.9	5.0	5.7	6.1	(38)
(39)			MCWBR	2.4	2.6	2.6	2.5	2.4	2.3	2.4	2.2	2.1	2.2	2.5	2.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.484	0.497	0.499	0.516	0.506	0.498	0.493	0.503	0.533	0.598	0.600	0.514	(40)	
(41)		taud	2.258	2.223	2.216	2.158	2.169	2.179	2.175	2.131	2.049	1.882	1.895	2.159	(41)	
(42)		Ebn at Noon	862	850	835	792	769	760	773	791	794	758	761	833	(42)	
(43)		Edh at Noon	146	151	150	152	143	138	141	154	174	210	208	160	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.05	5.03	5.18	5.02	4.85	4.64	4.77	5.36	5.61	5.37	4.93	4.89	(44)	
(45)		RadStd	0.40	0.32	0.30	0.27	0.28	0.33	0.37	0.27	0.41	0.62	0.42	0.37	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.32	N/A	N/A	+0.39	+0.35	+0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page