

SANGKAPURA BAWEAN ISLAND, Indonesia

WMO: 969250

Lat: 5.8510S

Lon: 112.6579E

Elev: 10

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	75.0	75.8	68.6	105.2	80.9	69.6	109.0	80.9	23.0	79.5	19.4	81.6	3.9	280	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	9.0	90.6	80.9	89.8	80.4	89.1	80.1	82.3	88.7	81.6	88.0	81.0	87.3	7.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.3	157.5	87.1	79.7	153.9	86.1	79.1	151.1	85.3	46.1	89.0	45.3	88.4	44.7	87.9	88.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	15.6	13.9	68.8	92.4	5.7	1.3	64.7	93.3	61.4	94.1	58.2	94.8	54.0	95.7		
(5)			67.1	83.6	4.5	1.0	63.9	84.4	61.3	84.9	58.8	85.5	55.5	86.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.7	81.6	81.6	82.2	82.8	83.8	83.0	82.4	82.7	83.0	83.9	83.6	82.3
	DBStd	1.81	1.92	1.78	1.45	1.65	1.71	1.76	1.43	0.90	1.17	1.66	2.00	2.06
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11954	981	885	1000	985	1049	989	1003	1013	991	1051	1007	1000
	CDD65	6479	516	465	535	535	584	539	538	548	541	586	557	535
	CDH74	73390	5513	4860	5790	6097	7054	6260	5965	6007	6179	7095	6647	5923
	CDH80	24260	1478	1302	1817	2136	2755	2109	1671	1656	2024	2836	2634	1842
Wind	WSAvg	5.9	6.7	5.5	3.8	3.8	5.8	7.1	8.0	9.0	7.5	6.1	3.6	4.4
Precipitation	PrecAvg	92.2	19.0	10.9	10.6	8.2	7.7	4.1	3.3	0.9	1.9	3.6	9.3	16.7
	PrecMax	139.6	45.1	24.7	19.2	20.1	23.8	15.3	13.7	4.0	13.5	11.9	32.5	39.2
	PrecMin	48.4	7.9	4.0	3.6	0.9	0.6	0.1	0.0	0.0	0.0	0.0	0.0	6.3
	PrecStd	26.0	8.2	4.5	4.7	5.0	5.1	4.0	4.5	1.3	3.1	3.7	7.1	6.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.1	89.4	89.9	89.9	90.0	89.1	87.8	87.6	88.9	90.9	92.0	91.5
		MCWB	82.0	80.7	80.8	80.6	81.1	80.1	78.9	78.5	78.9	80.1	82.0	81.9
	2%	DB	88.2	88.1	89.0	89.1	89.1	88.2	86.7	86.6	88.0	89.9	90.9	89.6
		MCWB	80.2	80.0	80.5	80.4	80.6	79.7	78.1	77.7	78.2	79.6	80.9	80.7
	5%	DB	87.0	87.1	88.2	88.4	88.4	87.3	86.0	86.0	87.3	89.1	90.0	88.4
		MCWB	79.6	79.6	80.1	80.2	80.1	79.2	77.6	77.2	77.8	79.3	80.5	80.2
	10%	DB	85.7	86.0	87.4	87.6	87.6	86.3	85.3	85.4	86.6	88.4	88.9	87.1
		MCWB	79.2	79.2	79.7	79.9	79.6	78.5	77.2	76.9	77.5	79.0	80.0	79.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.2	81.8	82.5	82.1	82.2	81.2	80.0	79.7	80.1	81.1	83.3	82.8
		MCDB	88.9	87.7	88.7	88.2	88.7	87.3	86.0	86.1	87.1	88.8	90.9	89.5
	2%	WB	81.2	80.7	81.5	81.3	81.4	80.4	79.1	78.8	79.3	80.6	81.8	81.6
		MCDB	86.6	86.7	87.6	87.4	87.7	86.7	85.1	85.3	86.3	88.5	89.3	87.9
	5%	WB	80.1	80.0	80.7	80.7	80.7	79.9	78.6	78.2	78.8	80.0	81.0	80.7
		MCDB	85.1	85.6	86.7	86.9	86.9	85.9	84.5	84.6	85.7	87.6	88.3	86.8
	10%	WB	79.5	79.4	80.0	80.1	80.1	79.3	78.1	77.7	78.2	79.5	80.3	80.0
		MCDB	84.3	84.6	85.6	85.9	86.0	85.0	83.9	84.0	85.0	86.8	87.3	85.6
Mean Daily Temperature Range	5% DB	MDBR	7.6	8.1	9.5	9.2	7.5	6.8	6.3	6.1	7.8	9.0	10.2	8.6
		MCDBR	9.4	10.0	11.1	10.0	8.4	7.7	6.8	6.5	8.4	9.8	11.4	10.6
		MCWBR	4.3	4.5	5.2	4.3	3.6	3.4	3.1	3.1	4.0	4.6	5.1	4.8
	5% WB	MCDBR	8.9	9.3	10.5	9.7	8.0	7.7	6.5	6.2	8.0	9.4	11.0	9.8
	MCWBR	4.4	4.5	5.1	4.5	3.6	3.6	3.1	3.3	3.9	4.6	5.3	4.9	
Clear-Sky Solar Irradiance	taub	0.474	0.471	0.452	0.434	0.429	0.427	0.421	0.441	0.456	0.494	0.490	0.483	
	taud	2.324	2.331	2.382	2.439	2.468	2.463	2.470	2.387	2.321	2.213	2.251	2.285	
	Ebn at Noon	276	277	278	275	267	263	267	269	272	267	269	272	
	Edh at Noon	43	43	40	36	34	33	34	38	42	48	46	44	
All-Sky Solar Radiation	RadAvg	1417	1558	1668	1663	1613	1564	1695	1918	2052	1959	1652	1319	
	RadStd	164	182	128	116	110	134	126	61	102	190	205	175	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.43	+1.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page