

NAHA TAHUNA, Indonesia

WMO: 970080

Lat: 3.6859N

Lon: 125.5280E

Elev: 125

StdP: 14.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	72.1	73.2	68.8	106.4	77.9	69.9	110.5	78.5	16.6	82.1	13.4	80.9	0.3	N/A	0.307

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.6	89.5	78.2	88.7	78.4	88.1	78.5	80.7	86.2	80.1	85.7	80.0	85.5	8.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.6	84.1	78.6	149.3	83.8	78.2	147.4	83.4	44.4	86.6	44.0	86.3	43.6	86.0	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.0	11.8	9.9	68.3	93.1	5.2	4.1	64.5	96.1	61.5	98.5	58.5	100.8	54.7	103.8		
(5)			67.2	82.4	4.4	1.3	64.0	83.3	61.4	84.1	59.0	84.8	55.8	85.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.9	80.2	80.2	80.7	81.2	81.5	81.1	80.6	81.1	80.8	81.1	80.8	81.0
	DBStd	1.41	1.44	1.64	1.34	1.33	1.21	1.40	1.35	1.59	1.22	1.27	1.25	1.30
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11264	938	846	952	935	977	932	949	963	924	963	925	960
	CDD65	5789	473	426	487	485	512	482	484	498	474	498	475	495
	CDH74	58780	4546	4119	4975	5100	5521	4876	4773	5185	4877	5088	4667	5053
	CDH80	17686	1090	959	1339	1516	1818	1478	1495	1818	1676	1711	1382	1404
Wind	WSAvg	2.7	2.9	3.1	2.7	2.3	2.4	2.7	3.3	3.6	2.8	2.7	1.9	2.3
Precipitation	PrecAvg	132.1	17.8	12.1	10.8	8.9	10.4	10.2	8.3	6.4	6.3	9.1	14.3	17.5
	PrecMax	174.1	34.1	23.3	28.6	17.2	24.6	16.0	15.5	15.0	14.6	17.4	27.5	31.4
	PrecMin	69.6	5.6	3.1	0.9	1.7	2.8	0.2	0.6	0.4	0.2	1.3	3.4	2.8
	PrecStd	26.0	7.2	5.2	6.4	4.7	4.8	3.6	4.1	3.1	4.0	4.7	5.7	6.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.1	88.0	88.0	88.9	89.7	89.6	89.6	90.5	89.8	89.9	89.2	88.9
		MCWB	78.5	78.4	78.6	78.4	79.0	79.0	78.5	78.4	76.8	78.3	78.9	78.9
	2%	DB	86.7	86.4	86.8	87.6	88.4	88.1	88.1	89.1	88.5	88.4	87.9	87.5
		MCWB	78.4	78.1	78.4	79.1	79.2	79.0	78.1	77.9	77.2	78.5	79.2	79.0
	5%	DB	85.8	85.6	86.0	86.7	87.6	87.3	87.2	88.1	87.7	87.5	87.0	86.5
		MCWB	78.3	78.0	78.2	78.9	79.3	79.0	77.9	77.7	77.6	78.5	79.1	79.0
	10%	DB	84.9	84.6	85.3	86.0	86.8	86.4	86.3	87.1	86.8	86.7	86.1	85.7
		MCWB	78.2	77.8	78.0	78.8	79.3	78.8	77.8	77.5	77.7	78.4	79.0	79.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	79.9	80.1	80.8	81.4	80.9	80.0	80.0	80.1	80.5	80.9	80.9
		MCDB	85.2	85.5	85.3	85.9	86.5	86.4	86.6	87.3	86.2	86.7	86.4	85.5
	2%	WB	79.5	79.1	79.6	80.1	80.7	80.1	79.2	79.2	79.5	79.9	80.1	80.1
		MCDB	84.6	84.4	84.8	85.3	86.2	85.9	85.9	86.5	85.8	86.1	85.6	85.1
	5%	WB	79.0	78.7	79.1	79.7	80.1	79.7	78.8	78.8	79.0	79.4	79.8	79.8
		MCDB	84.2	83.8	84.3	84.9	85.6	85.5	85.5	86.0	85.5	85.7	85.2	84.7
	10%	WB	78.6	78.2	78.6	79.2	79.7	79.1	78.3	78.2	78.5	79.0	79.2	79.3
		MCDB	83.5	83.1	83.8	84.3	85.2	85.0	84.6	85.2	84.9	85.3	84.6	84.2
Mean Daily Temperature Range	5% DB	MDBR	8.9	8.9	9.2	9.6	10.6	10.4	11.4	12.2	12.4	11.9	10.4	9.4
		MCDBR	10.9	10.3	10.2	10.9	12.0	11.8	12.8	13.7	13.8	12.9	11.7	10.8
		MCWBR	4.7	4.3	4.2	4.4	5.2	4.9	5.0	5.0	5.5	5.5	5.1	4.6
	5% WB	MCDBR	9.8	9.2	9.6	9.8	10.7	10.8	11.6	12.6	11.9	11.7	10.6	9.7
		MCWBR	4.6	4.3	4.3	4.5	5.1	5.2	5.1	5.3	5.6	5.4	5.0	4.7
Clear-Sky Solar Irradiance	taub		0.419	0.420	0.414	0.410	0.400	0.403	0.413	0.431	0.433	0.455	0.409	0.413
	taud		2.526	2.505	2.536	2.535	2.562	2.552	2.519	2.453	2.432	2.365	2.520	2.526
	Ebn at Noon		287	289	289	285	281	276	275	275	279	275	288	287
	Edh at Noon		34	36	35	34	32	32	33	36	38	40	34	34
All-Sky Solar Radiation	RadAvg		1529	1725	1836	1894	1767	1556	1633	1789	1827	1777	1648	1574
	RadStd		141	168	174	182	138	114	161	117	114	107	131	133

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page