

MENADO SAM RATULANGI, Indonesia

WMO: 970140

Lat: 1.5458N

Lon: 124.9230E

Elev: 80

StdP: 100.37

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	20.8	21.5	16.0	11.5	28.0	17.3	12.4	27.5	6.3	29.3	5.7	29.5	0.8	30	0.279

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.3	33.9	24.7	33.1	24.7	32.7	24.7	26.7	31.0	26.4	30.6	26.1	30.3	3.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.5	20.8	28.6	25.2	20.5	28.3	25.0	20.3	28.1	84.1	31.4	82.6	30.9	81.4	30.5	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.0	5.0	DB	18.9	34.9	1.9	1.4	17.6	35.9	16.4	36.7	15.4	37.5	14.0	38.5	(4)
(5)			WB	16.9	28.3	1.8	1.1	15.6	29.1	14.5	29.7	13.5	30.3	12.2	31.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.0	26.4	26.4	26.8	27.1	27.4	27.1	27.1	27.4	27.3	27.3	27.0	26.8
	DBStd	0.97	0.91	0.95	0.85	0.84	0.86	0.98	0.98	1.06	0.91	0.86	0.86	0.91
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6208	510	458	520	512	538	513	531	539	519	536	510	522
	CDD18.3	3166	252	224	262	262	280	263	272	281	269	278	260	263
	CDH23.3	28587	2003	1762	2251	2337	2617	2404	2598	2848	2683	2596	2237	2251
	CDH26.7	10318	539	499	737	804	995	893	993	1163	1165	1062	772	695
Wind	WSAvg	1.6	1.4	1.5	1.6	1.3	1.3	1.5	2.3	2.7	2.0	1.5	1.2	1.4
Precipitation	PrecAvg	3143	460	373	332	274	254	214	155	126	174	197	326	361
	PrecMax	4406	1003	810	772	503	469	419	399	378	551	614	629	587
	PrecMin	1938	54	39	64	116	77	4	0	0	0	3	67	75
	PrecStd	617	231	180	188	104	89	107	104	93	153	158	157	145
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	32.1	32.9	33.1	33.9	33.6	33.8	34.2	35.0	34.8	33.2	33.0
		MCWB	25.7	25.5	25.5	25.9	26.4	25.7	25.3	24.4	23.6	24.0	25.4	26.0
	2%	DB	31.0	31.1	31.8	32.1	32.8	32.6	32.6	33.1	33.7	33.2	32.2	31.7
		MCWB	25.4	25.3	25.4	25.6	25.7	25.1	24.6	24.0	23.6	24.5	25.3	25.7
	5%	DB	30.1	30.3	31.0	31.2	32.0	31.9	31.9	32.3	32.8	32.3	31.3	30.8
		MCWB	25.3	25.1	25.3	25.6	25.6	24.9	24.4	23.9	23.9	24.7	25.4	25.7
	10%	DB	29.4	29.7	30.2	30.6	31.2	31.1	31.1	31.7	32.0	31.5	30.5	30.0
		MCWB	25.1	25.0	25.2	25.5	25.5	25.0	24.3	23.9	24.2	24.8	25.4	25.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.3	26.6	26.8	27.2	26.7	26.4	26.2	26.2	26.6	26.7	26.7
		MCDB	30.3	30.2	30.7	31.2	31.7	31.4	31.3	31.4	31.3	31.3	30.8	30.7
	2%	WB	26.0	25.9	26.1	26.3	26.6	26.2	25.8	25.5	25.8	26.1	26.2	26.2
		MCDB	29.6	29.8	30.1	30.4	31.0	30.6	30.4	30.8	30.7	30.8	30.2	29.9
	5%	WB	25.7	25.5	25.7	26.0	26.2	25.7	25.4	25.0	25.4	25.7	25.9	26.0
		MCDB	29.0	29.2	29.6	30.1	30.3	29.9	29.9	30.2	30.3	30.2	29.8	29.5
	10%	WB	25.3	25.2	25.4	25.7	25.8	25.4	24.9	24.6	24.9	25.3	25.6	25.7
		MCDB	28.5	28.6	29.1	29.4	29.8	29.4	29.4	29.6	29.7	29.7	29.3	29.0
Mean Daily Temperature Range	5% DB	MDBR	6.4	6.7	7.4	7.7	8.5	8.5	8.7	9.3	10.2	9.5	8.0	7.0
		MCDBR	7.7	8.0	8.7	8.8	9.6	9.7	9.8	10.5	11.6	10.9	9.1	8.2
		MCWBR	3.1	3.3	3.6	3.6	3.9	3.9	3.9	4.1	4.4	4.1	3.7	3.4
	5% WB	MCDBR	7.0	7.4	7.8	8.1	8.7	8.7	8.8	9.5	9.8	9.2	8.3	7.5
		MCWBR	3.1	3.3	3.5	3.6	3.8	3.7	3.8	4.0	4.0	3.8	3.6	3.4
Clear-Sky Solar Irradiance	taub	0.417	0.422	0.425	0.426	0.420	0.418	0.414	0.424	0.437	0.477	0.440	0.422	
	taud	2.486	2.462	2.450	2.441	2.464	2.483	2.497	2.454	2.402	2.276	2.394	2.464	
	Ebn at Noon	910	910	901	881	864	854	862	871	877	849	882	900	
	Edh at Noon	113	118	119	117	111	106	106	114	123	140	123	114	
All-Sky Solar Radiation	RadAvg	4.87	5.30	5.65	5.67	5.49	5.09	5.39	5.83	6.12	5.89	5.41	5.06	
	RadStd	0.31	0.45	0.47	0.40	0.33	0.32	0.47	0.34	0.38	0.34	0.33	0.37	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.30	N/A	N/A	+0.94	+0.63	+0.45	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		+0.30	N/A	N/A	+0.94	+0.63	+0.45	N/A	N/A	N/A	N/A

Nomenclature: See separate page