

TOLI-TOLI LALOS, Indonesia

WMO: 970280

Lat: 1.1211N

Lon: 120.7942E

Elev: 2

StdP: 101.30

Time Zone: 8.00 (E08)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.5	22.8	20.5	15.2	24.8	21.1	15.8	24.7	5.8	28.1	4.4	29.2	1.0	110	0.290

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.1	32.5	26.3	32.1	26.3	31.7	26.3	27.3	31.0	27.1	30.9	26.9	30.7	2.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	29.7	26.0	21.4	29.6	25.7	21.0	29.4	86.6	31.2	85.5	31.1	84.6	30.9	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
4.4	3.9	3.3	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	26.9	27.0	27.1	27.4	27.6	27.3	27.2	27.3	27.4	27.3	27.3	27.3
	DBStd	0.78	0.88	0.84	0.78	0.63	0.69	0.74	0.81	0.84	0.69	0.68	0.62	0.85
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6297	523	475	531	522	545	519	533	535	522	537	520	535
	CDD18.3	3255	264	242	272	272	287	269	275	277	272	279	270	277
	CDH23.3	32096	2428	2241	2617	2792	3012	2633	2697	2754	2754	2765	2669	2733
	CDH26.7	11039	693	673	859	1006	1097	907	935	1008	1033	1007	931	891
Wind	WSAvg	1.2	1.2	1.1	1.1	1.1	1.1	1.1	1.1	1.3	1.4	1.3	1.2	1.3
Precipitation	PrecAvg	2102	233	165	141	124	158	179	199	142	124	178	171	209
	PrecMax	3712	612	430	370	295	354	432	557	369	355	529	448	454
	PrecMin	1135	32	0	3	0	28	0	0	0	0	0	35	45
	PrecStd	629	137	117	105	69	71	117	126	113	109	137	91	117
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	32.2	32.7	32.7	32.6	32.3	32.3	32.6	32.6	32.8	32.5	32.6
		MCWB	26.3	26.4	26.3	26.5	26.7	26.6	26.2	25.9	25.9	26.1	26.3	26.5
	2%	DB	31.2	31.2	31.7	31.7	31.9	31.7	31.7	31.9	31.9	31.9	31.7	31.7
		MCWB	26.0	26.0	26.1	26.5	26.7	26.5	26.2	26.1	26.2	26.2	26.3	26.2
	5%	DB	30.6	30.7	31.0	31.2	31.5	31.2	31.2	31.5	31.5	31.4	31.2	31.1
		MCWB	25.8	25.8	26.0	26.3	26.6	26.4	26.2	26.1	26.1	26.2	26.3	26.2
	10%	DB	30.0	30.1	30.5	30.8	31.0	30.7	30.7	31.0	31.0	30.9	30.7	30.5
		MCWB	25.7	25.7	25.8	26.2	26.5	26.3	26.1	26.0	26.1	26.2	26.2	26.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.4	27.2	27.3	27.6	27.5	27.2	27.2	27.4	27.2	27.2	27.2
		MCDB	30.6	31.2	31.0	31.1	31.0	31.2	31.0	31.2	31.2	31.0	30.6	31.0
	2%	WB	26.6	26.6	26.7	26.9	27.2	27.0	26.9	26.9	27.0	26.9	26.9	26.8
		MCDB	30.1	30.1	30.5	30.8	30.7	30.8	30.7	30.8	30.8	30.7	30.6	30.5
	5%	WB	26.2	26.2	26.4	26.6	26.9	26.7	26.6	26.6	26.7	26.6	26.6	26.5
		MCDB	29.6	29.7	30.1	30.4	30.6	30.4	30.3	30.5	30.5	30.4	30.3	30.2
	10%	WB	25.9	25.9	26.1	26.4	26.7	26.4	26.3	26.2	26.4	26.3	26.3	26.2
		MCDB	29.2	29.3	29.7	30.1	30.2	30.1	30.0	30.1	30.2	30.1	29.9	29.7
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.4	6.9	7.2	7.1	6.9	7.1	7.5	7.6	7.4	7.1	6.6
		MCDBR	7.1	7.4	7.9	7.8	7.7	7.4	7.7	8.1	8.2	8.2	7.8	7.4
		MCWBR	3.3	3.4	3.7	3.6	3.6	3.6	3.7	3.8	4.0	3.9	3.8	3.5
	5% WB	MCDBR	6.6	6.8	7.3	7.4	7.2	7.1	7.3	7.7	7.6	7.6	7.3	7.0
		MCWBR	3.3	3.4	3.6	3.7	3.6	3.7	3.8	3.9	4.0	3.9	3.8	3.6
Clear-Sky Solar Irradiance	taub	0.405	0.409	0.411	0.409	0.404	0.405	0.404	0.431	0.460	0.502	0.429	0.409	
	taud	2.523	2.503	2.494	2.498	2.523	2.536	2.540	2.439	2.348	2.212	2.436	2.512	
	Ebn at Noon	923	922	914	896	878	864	870	864	857	828	893	914	
	Edh at Noon	109	113	114	110	104	101	102	116	130	149	118	109	
All-Sky Solar Radiation	RadAvg	4.77	5.24	5.64	5.67	5.42	5.00	5.18	5.57	5.80	5.48	5.23	4.85	
	RadStd	0.35	0.42	0.49	0.37	0.24	0.27	0.41	0.30	0.37	0.34	0.29	0.39	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page