

POSO KASIGUNCU, Indonesia

WMO: **970960**Lat: **1.4203S**Lon: **120.6569E**Elev: **7**StdP: **14.69**Time Zone: **8.00 (E08)**Period: **95-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	71.5	72.6	64.9	92.2	81.8	67.0	99.4	81.3	13.4	89.1	12.1	88.1	0.9	N/A	0.304

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	14.0	91.4	78.4	90.7	78.7	90.0	79.0	81.8	88.5	81.1	88.0	80.8	87.7	8.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.9	155.1	85.8	79.2	151.5	85.2	78.9	149.9	85.0	45.5	88.7	44.9	88.4	44.4	88.1	92.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.7	10.8	68.1	94.7	2.4	2.4	66.4	96.5	65.0	97.9	63.7	99.3	62.0	101.0		
(5)			65.7	86.2	3.6	3.2	63.1	88.4	61.0	90.3	59.0	92.1	56.4	94.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	81.2	81.0	81.8	81.8	82.1	81.5	81.3	81.8	81.7	81.7	81.9	81.9
	DBStd	1.37	1.15	1.47	1.10	1.29	1.16	1.43	1.37	1.53	1.58	1.32	1.30	1.25
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11549	966	867	986	953	996	944	971	986	952	983	956	989
	CDD65	6074	501	447	521	503	531	494	506	521	502	518	506	524
	CDH74	61546	4806	4217	5263	5058	5459	4864	4985	5351	5304	5483	5338	5418
CDH80	22642	1561	1403	1882	1788	2060	1738	1823	2070	2163	2189	2011	1954	
Wind	WSAvg	3.0	2.3	2.5	2.8	2.6	2.8	2.8	3.4	4.0	3.9	3.4	3.0	2.5
Precipitation	PrecAvg	90.1	6.4	6.3	8.8	10.8	10.2	8.1	6.6	5.1	5.1	6.4	7.3	7.9
	PrecMax	129.8	16.4	15.3	13.3	18.6	23.7	16.1	16.7	10.5	12.0	18.1	16.5	22.3
	PrecMin	60.4	0.1	0.7	2.9	3.5	4.0	1.1	1.1	0.0	1.8	1.3	2.2	2.2
	PrecStd	18.1	4.1	4.3	2.8	4.0	5.2	3.2	3.7	3.1	2.9	3.8	3.3	4.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.8	90.0	90.8	90.8	91.4	90.9	90.9	91.9	92.8	92.2	91.3	90.9
		MCWB	79.9	79.5	80.2	80.6	80.7	79.5	77.2	75.8	74.9	77.5	79.9	80.3
	2%	DB	88.9	89.1	89.9	89.9	90.4	89.9	89.8	90.5	91.0	90.6	90.0	89.9
		MCWB	79.6	79.3	79.8	80.4	80.5	79.4	78.0	76.6	76.4	78.5	79.9	80.1
	5%	DB	88.0	88.2	89.1	89.1	89.6	89.0	88.9	89.6	89.9	89.7	89.4	89.0
		MCWB	79.4	79.2	79.5	80.1	80.4	79.2	78.2	77.1	77.2	78.9	79.9	80.0
	10%	DB	87.1	87.2	88.0	87.9	88.6	87.8	87.7	88.6	88.9	88.7	88.5	88.0
		MCWB	79.2	79.0	79.3	79.6	80.0	78.9	78.2	77.3	77.4	78.8	79.7	79.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.2	81.5	81.9	81.9	82.5	81.6	81.8	80.9	80.8	81.2	81.8	81.8
		MCDB	87.6	87.2	88.5	88.7	89.2	88.3	87.7	87.8	88.0	88.6	88.6	88.4
	2%	WB	80.7	80.4	80.9	81.0	81.5	80.7	80.0	79.7	79.8	80.5	80.9	81.0
		MCDB	87.0	87.0	87.8	87.9	88.4	87.6	87.1	87.0	87.4	87.9	88.0	87.7
	5%	WB	80.0	79.9	80.3	80.5	80.8	80.0	79.3	79.0	79.1	79.9	80.3	80.6
		MCDB	86.2	86.3	87.1	87.4	87.9	86.7	86.2	86.2	86.7	87.2	87.4	87.4
	10%	WB	79.5	79.2	79.8	79.9	80.2	79.5	78.7	78.3	78.5	79.2	79.9	80.0
		MCDB	85.5	85.6	86.3	86.4	87.0	86.0	85.4	85.3	85.9	86.5	86.7	86.4
Mean Daily Temperature Range	5% DB	MDBR	12.3	12.8	13.2	13.1	13.9	13.5	14.0	14.7	15.9	15.3	14.0	13.1
		MCDBR	13.5	14.1	14.3	14.2	14.8	14.9	15.0	15.6	17.0	16.3	14.7	14.0
		MCWBR	6.2	6.4	6.4	6.5	6.6	6.5	6.6	6.8	7.5	7.2	6.7	6.3
	5% WB	MCDBR	12.7	13.3	13.3	13.6	14.0	13.7	14.0	14.8	15.7	14.8	14.2	13.3
		MCWBR	6.3	6.6	6.4	6.4	6.7	6.5	6.9	7.0	7.4	6.9	6.6	6.3
Clear-Sky Solar Irradiance	taub	0.415	0.422	0.423	0.414	0.410	0.401	0.406	0.431	0.455	0.521	0.466	0.429	
	taud	2.461	2.437	2.441	2.465	2.491	2.536	2.518	2.429	2.355	2.143	2.313	2.428	
	Ebn at Noon	291	289	286	282	276	274	274	273	273	259	274	285	
	Edh at Noon	37	38	38	36	34	32	33	37	41	51	43	38	
All-Sky Solar Radiation	RadAvg	1547	1579	1614	1586	1527	1446	1469	1598	1786	1745	1639	1537	
	RadStd	78	89	69	57	64	92	125	110	93	102	63	84	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.72	+0.47	+1.39	N/A	+0.76	+0.67	N/A	N/A	N/A	N/A

Nomenclature: See separate page