

MAJENE, Indonesia

WMO: 971200

Lat: 3.5504S

Lon: 118.9800E

Elev: 95

StdP: 14.65

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	74.0	74.8	66.7	98.5	82.4	68.0	103.2	81.8	20.5	81.4	18.3	81.1	4.1	0	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	12.2	91.5	78.7	90.7	78.9	90.0	79.0	81.4	88.9	80.9	88.5	80.5	88.0	6.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.1	151.5	87.0	78.5	148.5	86.4	78.1	146.6	86.0	45.2	89.4	44.6	88.8	44.2	88.5	91.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	13.7	11.7	70.6	94.3	2.3	1.3	68.9	95.2	67.6	96.0	66.3	96.8	64.6	97.7		
(5)			67.6	83.6	1.9	2.7	66.2	85.5	65.0	87.1	64.0	88.6	62.5	90.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	82.5	82.3	82.4	82.6	82.7	82.8	82.0	81.6	82.0	83.0	83.3	83.1	82.4	(6)
(7)		DBStd	1.64	1.81	1.67	1.65	1.40	1.34	1.39	1.38	1.48	1.59	1.58	1.54	1.89	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11869	1000	907	1012	982	1017	960	981	992	990	1032	993	1003	(10)
(11)		CDD65	6394	535	487	547	532	552	510	516	527	540	567	543	538	(11)
(12)		CDH74	71580	5823	5331	6123	6056	6411	5568	5447	5667	6197	6705	6343	5909	(12)
(13)		CDH80	25216	2054	1893	2239	2230	2316	1704	1532	1718	2255	2667	2493	2115	(13)
(14)	Wind	WSAvg	4.6	3.6	3.6	3.5	3.5	4.3	5.2	6.9	7.2	6.1	4.3	3.2	3.4	(14)
(15)	Precipitation	PrecAvg	60.3	8.4	4.8	5.0	6.4	5.4	4.3	2.6	1.4	2.0	4.3	6.0	9.7	(15)
(16)		PrecMax	96.5	28.7	11.7	12.2	17.7	10.2	11.1	9.3	8.1	11.9	13.3	12.3	28.7	(16)
(17)		PrecMin	36.3	0.3	1.3	2.4	1.8	0.6	0.4	0.0	0.0	0.0	0.0	2.3	1.3	(17)
(18)		PrecStd	15.2	5.9	2.5	2.8	4.0	2.9	2.8	2.4	1.8	2.5	3.7	3.0	5.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.7	91.7	92.0	91.2	90.1	89.1	88.2	89.1	91.4	92.4	91.8	92.0	(19)
(20)		MCWB	77.5	77.1	78.5	80.0	80.5	79.5	78.4	77.2	77.5	77.7	80.0	79.0	79.0	(20)
(21)		2%	DB	90.3	90.0	90.5	90.0	89.2	88.1	87.3	88.2	90.0	90.8	90.8	90.6	(21)
(22)		MCWB	78.3	78.2	78.9	79.8	80.1	79.1	77.9	77.3	77.5	78.7	79.9	79.9	79.0	(22)
(23)		5%	DB	89.3	89.0	89.4	89.1	88.5	87.3	86.7	87.3	89.0	89.7	89.8	89.4	(23)
(24)		MCWB	78.4	78.5	79.0	79.6	79.7	78.8	77.7	77.2	77.5	79.0	79.7	79.7	78.8	(24)
(25)		10%	DB	88.0	88.0	88.3	88.2	87.7	86.4	85.9	86.5	88.0	88.7	88.8	88.2	(25)
(26)		MCWB	78.1	78.5	78.8	79.2	79.3	78.5	77.4	77.0	77.5	78.8	79.4	78.6	78.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.4	81.1	81.6	81.8	81.8	80.9	80.0	80.1	80.6	81.1	81.7	81.4	(27)
(28)		MCDWB	89.1	88.5	89.4	89.3	88.9	87.3	86.5	86.4	88.2	89.0	89.8	89.0	89.0	(28)
(29)		2%	WB	80.1	80.3	80.6	80.9	80.9	80.0	79.1	79.0	79.6	80.4	80.9	80.5	(29)
(30)		MCDWB	87.7	87.7	88.5	88.5	88.0	86.4	85.8	86.0	87.3	88.5	89.0	88.6	88.6	(30)
(31)		5%	WB	79.5	79.7	79.9	80.2	80.3	79.5	78.5	78.3	79.0	79.9	80.3	79.8	(31)
(32)		MCDWB	86.8	87.0	87.5	87.7	87.2	85.8	85.1	85.3	86.6	87.7	88.3	87.6	87.6	(32)
(33)		10%	WB	78.8	79.0	79.2	79.7	79.7	79.0	77.9	77.7	78.3	79.3	79.8	79.1	(33)
(34)		MCDWB	85.9	86.2	86.6	86.8	86.4	85.2	84.4	84.7	85.9	86.9	87.5	86.6	86.6	(34)
(35)	Mean Daily Temperature Range		MDBR	11.4	11.4	11.4	11.2	10.1	9.3	9.2	10.1	11.4	12.2	11.9	11.4	(35)
(36)		5% DB	MCDBR	12.9	12.6	12.8	12.3	11.0	10.2	9.9	10.8	12.3	13.2	12.9	13.1	(36)
(37)			MCWBR	5.5	5.5	5.5	5.6	5.0	4.6	4.5	4.8	5.5	5.7	5.5	5.5	(37)
(38)			MCDBR	11.8	11.8	11.8	11.6	10.7	9.7	9.5	10.2	11.4	12.4	12.4	12.1	(38)
(39)		5% WB	MCWBR	5.8	5.8	5.7	5.6	5.1	4.7	4.7	5.1	5.5	5.6	5.7	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.409	0.413	0.410	0.407	0.411	0.413	0.413	0.432	0.461	0.505	0.474	0.419	(40)	
(41)		taud	2.500	2.481	2.493	2.512	2.506	2.516	2.510	2.432	2.334	2.186	2.294	2.474	(41)	
(42)		Ebn at Noon	294	293	290	283	274	269	271	272	271	263	273	290	(42)	
(43)		Edh at Noon	36	37	36	34	33	32	33	36	42	49	44	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1582	1657	1705	1730	1673	1553	1637	1830	1967	1919	1747	1538	(44)	
(45)		RadStd	86	83	86	70	77	103	111	108	95	128	86	121	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	+0.43	N/A	N/A	+0.99	+1.30	+1.58	N/A	N/A	N/A	N/A

Nomenclature: See separate page