

MAJENE, Indonesia

WMO: 971200

Lat: 3.5504S

Lon: 118.9800E

Elev: 29

StdP: 100.98

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	23.8	19.3	14.1	28.0	20.0	14.7	27.7	9.1	27.4	8.2	27.3	1.8	0	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	6.8	33.1	26.0	32.6	26.1	32.2	26.1	27.5	31.6	27.2	31.4	26.9	31.1	2.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.6	30.6	25.8	21.2	30.2	25.6	20.9	30.0	87.2	31.9	85.9	31.6	84.8	31.4	32.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.1	5.2	DB	21.5	34.6	1.3	0.7	20.5	35.1	19.8	35.6	19.0	36.0	18.1	36.5	(4)
(5)			WB	19.8	28.7	1.1	1.5	19.0	29.7	18.4	30.6	17.8	31.4	17.0	32.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	27.9	28.0	28.1	28.2	28.2	27.8	27.6	27.8	28.3	28.5	28.4	28.0
	DBStd	0.91	1.01	0.93	0.92	0.78	0.74	0.77	0.76	0.82	0.89	0.88	0.86	1.05
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6594	556	504	562	546	565	533	545	551	550	573	552	557
	CDD18.3	3552	297	271	304	296	307	283	287	293	300	315	302	299
	CDH23.3	39767	3235	2962	3402	3364	3562	3093	3026	3148	3443	3725	3524	3283
CDH26.7	14009	1141	1052	1244	1239	1287	947	851	954	1253	1482	1385	1175	
Wind	WSAvg	2.0	1.6	1.6	1.6	1.6	1.9	2.3	3.1	3.2	2.7	1.9	1.4	1.5
Precipitation	PrecAvg	1531	213	121	128	163	136	108	67	35	51	109	152	247
	PrecMax	2451	729	297	310	450	260	282	236	207	303	339	312	730
	PrecMin	921	7	34	61	45	16	11	1	1	0	0	58	34
	PrecStd	387	149	64	70	101	74	71	62	45	63	95	76	151
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.2	33.2	33.3	32.9	32.3	31.7	31.2	31.7	33.0	33.5	33.2	33.3
		MCWB	25.3	25.0	25.8	26.6	27.0	26.4	25.8	25.1	25.3	25.4	26.7	26.1
	2%	DB	32.4	32.2	32.5	32.2	31.8	31.2	30.7	31.2	32.2	32.6	32.6	32.5
		MCWB	25.7	25.7	26.1	26.6	26.7	26.2	25.5	25.1	25.3	25.9	26.6	26.1
	5%	DB	31.8	31.7	31.9	31.7	31.4	30.7	30.4	30.7	31.7	32.1	32.1	31.9
		MCWB	25.8	25.8	26.1	26.4	26.5	26.0	25.4	25.1	25.3	26.1	26.5	26.0
	10%	DB	31.1	31.1	31.3	31.2	30.9	30.2	30.0	30.3	31.1	31.5	31.6	31.2
		MCWB	25.6	25.8	26.0	26.2	26.3	25.8	25.2	25.0	25.3	26.0	26.4	25.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.4	27.3	27.6	27.7	27.7	27.2	26.7	26.7	27.0	27.3	27.6	27.4
		MCDB	31.7	31.4	31.9	31.8	31.6	30.7	30.3	30.2	31.2	31.7	32.1	31.6
	2%	WB	26.7	26.8	27.0	27.2	27.2	26.7	26.2	26.1	26.5	26.9	27.2	26.9
		MCDB	31.0	31.0	31.4	31.4	31.1	30.2	29.9	30.0	30.7	31.4	31.7	31.4
	5%	WB	26.4	26.5	26.6	26.8	26.8	26.4	25.8	25.7	26.1	26.6	26.8	26.5
		MCDB	30.5	30.6	30.9	30.9	30.7	29.9	29.5	29.6	30.4	31.0	31.3	30.9
	10%	WB	26.0	26.1	26.2	26.5	26.5	26.1	25.5	25.4	25.7	26.3	26.5	26.1
		MCDB	30.0	30.1	30.3	30.5	30.2	29.6	29.1	29.3	29.9	30.5	30.8	30.3
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.3	6.4	6.2	5.6	5.2	5.1	5.6	6.3	6.8	6.6	6.3
		MCDBR	7.1	7.0	7.1	6.8	6.1	5.7	5.5	6.0	6.8	7.3	7.2	7.3
		MCWBR	3.1	3.0	3.1	3.1	2.8	2.5	2.5	2.7	3.0	3.2	3.1	3.0
	5% WB	MCDBR	6.6	6.6	6.5	6.4	5.9	5.4	5.3	5.6	6.3	6.9	6.9	6.7
		MCWBR	3.2	3.2	3.2	3.1	2.8	2.6	2.6	2.8	3.1	3.1	3.2	3.2
Clear-Sky Solar Irradiance	taub	0.409	0.413	0.410	0.407	0.411	0.413	0.413	0.432	0.461	0.505	0.474	0.419	
	taud	2.500	2.481	2.493	2.512	2.506	2.516	2.510	2.432	2.334	2.186	2.294	2.474	
	Ebn at Noon	926	923	914	893	864	849	855	859	855	830	860	913	
	Edh at Noon	113	116	114	108	104	101	103	115	131	154	138	115	
All-Sky Solar Radiation	RadAvg	4.99	5.22	5.38	5.46	5.27	4.90	5.16	5.77	6.20	6.05	5.51	4.85	
	RadStd	0.27	0.26	0.27	0.22	0.24	0.32	0.35	0.34	0.30	0.40	0.27	0.38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.24	N/A	N/A	+0.55	+0.72	+0.88	N/A	N/A	N/A	N/A

Nomenclature: See separate page