

MASAMBA ANDI JEMMA, Indonesia

WMO: 971260

Lat: 2.5547S

Lon: 120.3239E

Elev: 164

StdP: 14.61

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	71.7	72.8	65.2	93.7	79.0	67.0	100.0	78.2	11.3	78.1	9.5	79.4	2.5	10	0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	14.8	92.6	79.1	91.7	79.1	90.9	79.0	81.8	89.2	81.0	88.6	80.6	88.2	4.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.6	154.8	86.7	79.0	151.2	86.0	78.3	147.9	85.4	45.7	89.6	44.9	89.1	44.4	88.4	92.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.3	7.3	68.5	96.0	2.4	1.7	66.8	97.3	65.4	98.2	64.1	99.2	62.3	100.4		
(5)			64.9	84.0	2.0	3.2	63.5	86.3	62.3	88.2	61.2	90.0	59.7	92.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	82.8	82.5	82.5	82.2	81.8	80.9	80.0	80.1	81.4	82.7	83.2	82.8
	DBStd	1.82	1.44	1.43	1.28	1.38	1.61	1.52	1.79	1.82	1.50	1.33	1.38	1.40
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11645	1016	910	1007	966	986	926	930	934	943	1013	996	1018
	CDD65	6170	551	490	542	516	521	476	465	469	493	548	546	553
	CDH74	58190	5385	4600	5046	4842	4937	4178	3816	3935	4667	5673	5655	5456
(13)	CDH80	20847	2063	1710	1820	1668	1636	1252	1092	1202	1742	2323	2259	2080
(14)	Wind	WSAvg	2.5	2.5	2.7	2.5	2.4	2.3	2.2	2.2	2.4	2.6	2.7	2.5
(15) Precipitation	PrecAvg	156.3	13.6	12.7	16.7	18.8	16.5	16.1	10.5	8.8	7.6	8.3	10.7	15.7
	PrecMax	236.0	27.2	24.1	31.5	36.7	25.6	24.9	22.6	27.4	16.3	31.5	30.4	29.3
	PrecMin	84.5	1.4	3.3	7.6	8.3	5.8	5.2	3.3	0.0	0.0	0.0	0.4	8.2
	PrecStd	38.4	5.5	6.1	6.1	5.6	5.7	5.7	5.3	7.0	5.1	8.1	6.9	5.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.8	93.0	92.3	91.6	91.4	90.0	89.5	89.9	91.6	93.1	93.6	93.3
		MCWB	79.1	79.4	80.4	80.0	79.6	78.8	77.8	77.2	76.9	78.0	78.7	79.6
	2%	DB	91.7	91.2	90.8	90.1	89.9	88.7	88.0	88.6	90.3	91.8	92.3	91.7
		MCWB	79.5	79.6	80.0	79.8	79.4	78.6	77.7	77.0	77.9	78.9	79.5	79.5
	5%	DB	90.3	89.9	89.7	89.2	88.8	87.5	86.9	87.4	89.3	90.7	91.0	90.3
		MCWB	79.4	79.4	79.7	79.6	79.2	78.2	77.4	76.8	76.9	78.0	79.0	79.4
	10%	DB	89.0	88.5	88.4	87.9	87.5	86.3	85.7	86.1	88.2	89.6	89.8	89.0
		MCWB	79.3	79.1	79.2	79.2	78.8	78.0	77.2	76.5	76.9	78.0	79.0	79.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.3	82.0	82.3	81.9	81.6	80.8	80.3	79.5	80.5	81.6	82.1	81.9
		MCDB	89.4	89.6	89.7	88.9	88.3	87.1	86.6	86.7	88.7	89.7	90.0	89.8
	2%	WB	81.0	80.9	81.0	80.9	80.4	79.9	79.3	78.5	79.3	80.3	80.9	80.9
		MCDB	88.6	88.5	88.7	88.0	87.4	86.2	85.6	85.6	87.4	88.6	89.1	88.6
	5%	WB	80.2	80.1	80.2	80.2	79.8	79.1	78.5	77.8	78.5	79.5	80.0	80.1
		MCDB	88.0	87.7	87.8	87.2	86.6	85.5	84.7	84.7	86.5	88.0	88.3	87.8
	10%	WB	79.6	79.4	79.5	79.6	79.2	78.5	77.8	77.2	77.9	78.8	79.4	79.5
		MCDB	87.3	86.9	87.0	86.4	85.8	84.6	83.7	83.9	85.5	87.4	87.6	87.2
(35) Mean Daily Temperature Range	5% DB	MDBR	14.6	14.3	14.0	13.2	12.4	11.7	11.5	12.4	14.5	15.5	14.8	14.4
		MCDBR	15.9	15.5	14.9	14.3	13.9	13.3	13.2	14.1	15.9	16.7	16.2	15.7
		MCWBR	7.1	6.7	6.5	6.0	5.7	5.4	5.3	6.3	6.6	6.4	6.5	6.5
		MCDBR	15.1	14.6	14.2	13.6	13.0	12.3	12.1	13.0	14.4	15.2	14.9	14.6
	5% WB	MCWBR	7.4	7.0	6.7	6.3	5.8	5.5	5.6	6.5	6.8	6.7	6.7	6.7
(40) Clear-Sky Solar Irradiance	taub		0.422	0.431	0.429	0.419	0.414	0.407	0.415	0.449	0.471	0.530	0.486	0.436
	taud		2.428	2.403	2.413	2.452	2.473	2.507	2.479	2.364	2.296	2.101	2.243	2.400
	Ebn at Noon		289	287	285	280	274	272	271	268	269	257	269	284
	Edh at Noon		38	40	39	36	34	32	34	39	43	53	46	39
(44) All-Sky Solar Radiation	RadAvg		1586	1626	1665	1631	1534	1404	1418	1547	1792	1822	1729	1584
	RadStd		64	80	57	65	85	102	125	112	88	117	58	81

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.72	+0.47	+1.39	N/A	+0.76	+0.67	N/A	N/A	N/A	N/A

Nomenclature: See separate page