

MASAMBA ANDI JEMMA, IndonesiaWMO: **971260**Lat: **2.5547S**Lon: **120.3239E**Elev: **50**StdP: **100.73**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	22.6	18.4	13.4	26.1	19.5	14.3	25.7	5.1	25.6	4.3	26.3	1.1	10	0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	8.2	33.7	26.1	33.2	26.1	32.7	26.1	27.6	31.8	27.2	31.4	27.0	31.2	2.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.5	22.1	30.4	26.1	21.6	30.0	25.7	21.1	29.7	88.4	32.0	86.6	31.7	85.3	31.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years					
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4.4	3.7	3.2	DB	20.3	35.6	1.3	0.9	19.3	36.3	18.5	36.8	17.8	37.3	16.8	38.0
			WB	18.3	28.9	1.1	1.8	17.5	30.2	16.8	31.2	16.2	32.2	15.4	33.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	28.2	28.0	28.1	27.9	27.7	27.1	26.7	26.7	27.5	28.2	28.4	28.2
	DBStd	1.01	0.80	0.79	0.71	0.77	0.90	0.84	0.99	1.01	0.83	0.74	0.77	0.78
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6469	564	506	559	537	548	514	517	519	524	563	553	566
	CDD18.3	3428	306	272	301	287	289	264	258	261	274	304	303	307
	CDH23.3	32328	2992	2556	2803	2690	2743	2321	2120	2186	2593	3152	3142	3031
	CDH26.7	11582	1146	950	1011	927	909	696	607	668	968	1291	1255	1156
(14) Wind	WSAvg	1.1	1.1	1.2	1.1	1.1	1.1	1.0	1.0	1.1	1.2	1.2	1.2	1.1
(15) Precipitation	PrecAvg	3969	345	323	425	477	418	408	267	224	192	211	271	398
	PrecMax	5994	690	611	799	931	651	633	573	696	413	799	772	743
	PrecMin	2146	35	85	193	210	148	131	84	0	0	0	11	208
	PrecStd	975	139	155	155	142	144	145	134	177	129	207	174	143
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.3	33.9	33.5	33.1	33.0	32.2	31.9	32.2	33.1	33.9	34.2	34.1
		MCWB	26.2	26.3	26.9	26.6	26.5	26.0	25.4	25.1	25.0	25.6	25.9	26.4
	2%	DB	33.2	32.9	32.7	32.3	32.1	31.5	31.1	31.4	32.4	33.2	33.5	33.1
		MCWB	26.4	26.5	26.7	26.6	26.3	25.9	25.4	25.0	25.0	25.5	26.1	26.4
	5%	DB	32.4	32.1	32.1	31.8	31.5	30.9	30.5	30.8	31.8	32.6	32.8	32.4
		MCWB	26.4	26.3	26.5	26.4	26.2	25.7	25.2	24.9	24.9	25.5	26.1	26.3
	10%	DB	31.6	31.4	31.3	31.0	30.8	30.2	29.8	30.0	31.2	32.0	32.1	31.7
		MCWB	26.3	26.2	26.2	26.2	26.0	25.6	25.1	24.7	24.9	25.6	26.1	26.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.9	27.8	27.9	27.7	27.6	27.1	26.9	26.4	26.9	27.5	27.8	27.7
		MCDB	31.9	32.0	32.0	31.6	31.3	30.6	30.3	30.4	31.5	32.0	32.2	32.1
	2%	WB	27.2	27.2	27.2	27.2	26.9	26.6	26.3	25.8	26.3	26.9	27.2	27.1
		MCDB	31.5	31.4	31.5	31.1	30.8	30.1	29.8	29.8	30.8	31.4	31.7	31.5
	5%	WB	26.8	26.7	26.8	26.8	26.6	26.2	25.8	25.5	25.9	26.4	26.7	26.7
		MCDB	31.1	30.9	31.0	30.7	30.3	29.7	29.3	29.3	30.3	31.1	31.3	31.0
	10%	WB	26.4	26.4	26.4	26.4	26.2	25.8	25.4	25.1	25.5	26.0	26.3	26.4
		MCDB	30.7	30.5	30.5	30.2	29.9	29.2	28.7	28.8	29.7	30.8	30.9	30.7
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	7.9	7.8	7.3	6.9	6.5	6.4	6.9	8.1	8.6	8.2	8.0
		MCDBR	8.8	8.6	8.3	8.0	7.7	7.4	7.3	7.8	8.9	9.3	9.0	8.7
		MCWBR	4.0	3.7	3.6	3.3	3.1	3.0	3.0	2.9	3.5	3.7	3.6	3.6
	5% WB	MCDBR	8.4	8.1	7.9	7.6	7.2	6.8	6.7	7.2	8.0	8.5	8.3	8.1
		MCWBR	4.1	3.9	3.7	3.5	3.2	3.1	3.1	3.2	3.6	3.8	3.7	3.7
(40) Clear-Sky Solar Irradiance	taub		0.422	0.431	0.429	0.419	0.414	0.407	0.415	0.449	0.471	0.530	0.486	0.436
	taud		2.428	2.403	2.413	2.452	2.473	2.507	2.479	2.364	2.296	2.101	2.243	2.400
	Ebn at Noon		912	905	897	884	863	856	854	845	847	809	847	894
	Edh at Noon		121	126	123	115	108	102	107	124	137	168	145	124
(44) All-Sky Solar Radiation	RadAvg		5.00	5.12	5.25	5.14	4.84	4.42	4.47	4.88	5.65	5.75	5.45	5.00
	RadStd		0.20	0.25	0.18	0.21	0.27	0.32	0.40	0.35	0.28	0.37	0.18	0.26

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.40	+0.26	+0.77	N/A	+0.42	+0.37	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page