

UJANG PANDANG PAOTERE, Indonesia

WMO: 971820

Lat: 5.1103S

Lon: 119.4197E

Elev: 6

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	74.2	75.0	63.9	89.0	78.4	65.8	95.1	79.1	33.5	79.4	24.7	80.8	4.0	130	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	12.8	92.2	81.0	91.5	81.0	90.8	80.7	83.8	89.7	83.2	89.3	82.6	89.0	8.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.2	167.9	88.9	81.4	163.4	88.3	80.7	159.6	87.8	48.0	89.9	47.1	89.5	46.5	89.2	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	14.4	12.0	71.0	95.3	3.7	3.6	68.4	97.9	66.2	100.0	64.2	102.0	61.5	104.7		
(5)			65.5	85.9	2.2	1.1	64.0	86.7	62.7	87.3	61.4	87.9	59.8	88.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	83.0	81.4	81.7	82.5	83.6	84.2	83.2	82.5	82.7	83.4	84.4	84.1	82.1	(6)
(7)		DBStd	1.97	2.37	2.02	2.14	1.65	1.40	1.50	1.38	1.24	1.32	1.34	1.52	2.35	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	12046	975	888	1008	1009	1060	996	1006	1015	1003	1067	1023	996	(10)
(11)		CDD65	6571	510	468	543	559	595	546	541	550	553	602	573	531	(11)
(12)		CDH74	76189	5248	4892	5969	6584	7291	6344	6149	6579	6893	7660	6928	5652	(12)
(13)		CDH80	28979	1524	1471	2051	2582	3049	2430	2276	2602	2904	3423	2854	1813	(13)
(14)	Wind	WSAvg	4.9	6.2	6.1	4.8	4.3	4.1	4.0	4.2	4.6	4.7	4.9	4.8	5.7	(14)
(15)	Precipitation	PrecAvg	124.8	28.8	21.9	15.4	8.9	4.8	3.1	1.7	0.7	1.4	4.1	10.0	24.1	(15)
(16)		PrecMax	198.9	50.5	44.3	28.2	22.2	10.3	7.7	11.4	4.3	12.2	16.6	28.8	38.5	(16)
(17)		PrecMin	86.9	5.2	3.0	6.7	1.9	1.1	0.3	0.0	0.2	0.4	0.2	2.2	6.9	(17)
(18)		PrecStd	27.6	9.0	9.4	6.6	4.2	2.5	2.4	2.5	0.9	2.3	3.8	6.1	8.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.9	90.6	91.4	92.0	92.5	91.7	90.9	90.9	92.1	93.3	92.7	91.3	(19)
(20)		MCWB	82.2	81.8	82.5	82.5	81.8	80.6	79.4	78.5	79.5	80.6	81.7	82.5	(20)	
(21)		2%	DB	89.5	89.3	90.2	91.0	91.4	90.6	89.8	90.0	90.9	92.1	91.5	90.0	(21)
(22)		MCWB	81.7	81.4	82.0	81.8	81.5	80.1	78.8	78.3	79.1	80.3	81.7	82.1	(22)	
(23)		5%	DB	88.1	88.2	89.3	90.2	90.6	89.7	89.0	89.1	90.1	91.2	90.6	88.9	(23)
(24)		MCWB	81.0	81.0	81.5	81.4	81.2	79.7	78.4	78.0	78.8	80.1	81.5	81.6	(24)	
(25)		10%	DB	86.5	86.7	88.1	89.3	89.8	88.8	88.2	88.5	89.4	90.3	89.7	87.4	(25)
(26)		MCWB	80.3	80.5	81.0	81.1	80.9	79.4	78.0	77.7	78.6	79.8	81.3	80.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.6	83.4	84.2	84.5	84.0	82.9	81.8	81.7	82.8	82.8	84.6	84.1	(27)
(28)		MCD B	89.2	89.2	89.7	90.5	90.4	89.1	88.6	88.5	88.9	90.5	89.8	89.6	(28)	
(29)		2%	WB	82.4	82.4	83.1	83.3	82.8	81.8	80.6	80.4	81.2	82.0	83.5	82.8	(29)
(30)		MCD B	88.3	87.8	88.8	89.6	89.7	88.7	88.1	87.8	88.4	89.9	89.4	88.7	(30)	
(31)		5%	WB	81.4	81.5	82.3	82.3	82.1	80.9	79.7	79.6	80.4	81.3	82.5	81.9	(31)
(32)		MCD B	87.0	86.8	88.1	88.9	89.2	87.9	87.3	87.3	88.0	89.3	89.2	87.8	(32)	
(33)		10%	WB	80.4	80.7	81.4	81.5	81.3	80.1	78.9	78.9	79.6	80.6	81.7	81.0	(33)
(34)		MCD B	85.7	85.8	87.0	87.9	88.4	87.0	86.5	86.8	87.5	88.7	88.4	86.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	8.7	9.3	10.1	11.3	11.5	11.5	12.0	12.3	12.7	12.8	11.4	9.4	(35)	
(36)		5% DB	MCD BR	11.1	11.6	12.0	12.3	12.4	12.7	12.9	12.9	13.3	13.6	12.5	11.7	(36)
(37)		MCWBR	6.2	6.5	6.7	6.6	6.6	6.5	6.7	7.4	8.0	7.7	7.1	6.6	(37)	
(38)		MCD BR	10.6	10.7	11.3	11.7	11.8	11.5	11.9	12.0	12.6	12.9	11.9	11.2	(38)	
(39)		5% WB	MCWBR	6.4	6.5	6.9	7.0	6.7	6.5	6.8	7.7	8.2	7.8	7.3	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.434	0.434	0.425	0.416	0.414	0.415	0.405	0.414	0.434	0.474	0.473	0.440	(40)	
(41)		taud	2.435	2.417	2.448	2.489	2.497	2.496	2.516	2.462	2.382	2.259	2.289	2.417	(41)	
(42)		Ebn at Noon	287	286	285	280	272	267	272	277	279	272	274	284	(42)	
(43)		Edh at Noon	38	39	38	35	33	32	32	35	40	46	44	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1444	1533	1676	1716	1663	1552	1677	1927	2096	2065	1821	1461	(44)	
(45)		RadStd	145	137	114	105	82	125	117	96	105	167	145	138	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.43	N/A	N/A	+0.99	+1.30	+1.58	N/A	N/A	N/A	N/A

Nomenclature: See separate page