

PRAYA LOMBOK, Indonesia

WMO: 972400

Lat: 8.7658S

Lon: 116.2791E

Elev: 351

StdP: 14.51

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	67.6	68.7	62.8	86.5	76.8	64.4	91.7	76.2	18.9	82.9	18.0	82.5	1.0	40	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	13.8	91.7	78.3	91.0	78.3	89.9	78.3	81.3	87.9	80.6	87.5	80.0	86.8	9.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	153.7	84.9	78.9	151.7	84.4	78.2	148.6	83.8	45.4	88.6	44.6	87.6	44.0	87.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	15.3	13.7	64.0	95.4	3.0	2.8	61.9	97.4	60.1	99.0	58.4	100.6	56.2	102.6
			62.3	84.3	2.2	1.7	60.7	85.5	59.4	86.5	58.1	87.4	56.5	88.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.0	81.7	81.7	81.9	82.1	81.3	79.7	78.3	78.5	80.0	82.1	82.7	82.1
	DBStd	2.23	1.71	1.57	1.56	1.25	1.60	1.95	1.94	1.98	1.93	1.41	1.57	1.72
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11313	981	886	988	964	969	890	877	883	901	997	982	995
	CDD65	5838	516	466	523	514	504	440	412	418	451	532	532	530
	CDH74	56259	5133	4583	5118	5217	4911	3883	3330	3466	4080	5530	5691	5317
	CDH80	19285	1623	1494	1774	1928	1781	1295	994	1071	1358	2070	2149	1748
Wind	WSAvg	5.2	5.5	5.0	4.1	3.7	4.8	5.4	6.2	6.7	6.3	5.8	4.7	4.4
Precipitation	PrecAvg	68.4	10.7	10.8	8.8	6.7	3.3	2.1	1.5	0.5	1.6	4.1	7.2	11.2
	PrecMax	104.1	20.1	36.1	14.0	12.1	9.8	8.2	10.3	2.7	16.3	15.2	14.2	20.3
	PrecMin	47.5	4.3	2.5	2.5	2.9	0.0	0.1	0.1	0.0	0.0	0.0	1.6	1.8
	PrecStd	13.3	4.8	6.6	3.3	2.7	2.4	1.9	2.4	0.6	3.7	5.0	3.7	3.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.2	90.9	91.7	91.7	91.4	90.0	89.3	89.5	90.6	92.8	93.4	93.0
		MCWB	79.2	79.4	79.1	78.9	78.9	77.4	76.6	75.4	75.8	76.1	77.9	79.3
	2%	DB	89.5	89.6	90.0	90.6	89.8	88.8	87.6	87.8	89.3	91.0	91.6	90.4
		MCWB	78.9	79.3	79.0	78.7	78.5	77.1	75.4	74.5	75.8	76.6	78.4	79.3
	5%	DB	88.1	88.4	89.2	89.6	89.0	87.7	86.2	86.4	87.9	89.7	90.2	89.0
		MCWB	78.6	79.0	78.9	78.7	78.2	76.8	75.0	74.3	75.5	77.0	78.4	79.2
	10%	DB	87.1	87.4	87.8	88.4	87.9	86.3	85.2	85.6	86.7	88.5	89.0	87.6
		MCWB	78.4	78.7	78.7	78.6	77.8	76.2	74.6	74.1	75.1	76.9	78.4	79.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.5	81.6	82.1	81.7	79.9	79.3	78.4	79.2	80.7	81.9	82.0
		MCDB	87.2	87.8	88.4	88.2	87.8	86.8	85.8	85.6	86.0	88.2	89.4	87.9
	2%	WB	80.0	80.2	80.4	80.6	80.1	78.9	78.1	77.0	78.1	79.4	80.4	80.7
		MCDB	86.6	87.1	87.3	87.5	86.8	85.9	84.5	83.8	84.8	86.8	87.6	87.3
	5%	WB	79.3	79.6	79.7	79.8	79.4	78.1	77.0	76.1	77.2	78.7	79.7	80.0
		MCDB	85.7	86.3	86.3	86.6	85.9	84.9	83.1	83.1	84.0	86.0	86.6	86.3
	10%	WB	78.8	79.0	79.1	79.2	78.8	77.4	76.0	75.3	76.3	78.0	79.0	79.2
		MCDB	85.0	85.4	85.5	85.7	85.3	83.8	81.8	82.5	83.1	85.0	85.8	85.3
Mean Daily Temperature Range	5% DB	MDBR	11.3	12.2	13.0	14.1	14.6	14.9	15.1	15.5	14.8	14.6	13.8	12.3
		MCDBR	12.8	13.7	14.6	15.1	15.5	16.0	16.1	16.1	15.6	16.0	15.3	14.0
		MCWBR	5.0	5.7	6.0	6.1	6.3	6.6	6.5	6.2	5.2	5.2	5.3	5.5
	5% WB	MCDBR	11.9	12.9	13.7	14.1	14.0	14.6	14.0	14.7	14.1	14.1	13.9	13.0
		MCWBR	5.3	5.8	6.1	6.2	6.3	6.7	6.7	6.5	5.7	5.7	5.8	5.8
Clear-Sky Solar Irradiance	taub	0.468	0.470	0.440	0.432	0.425	0.416	0.409	0.422	0.446	0.488	0.493	0.474	
	taud	2.311	2.307	2.395	2.427	2.437	2.458	2.467	2.405	2.329	2.200	2.213	2.290	
	Ebn at Noon	279	277	281	274	266	264	269	273	275	269	269	276	
	Edh at Noon	44	44	40	37	35	33	33	37	42	49	48	45	
All-Sky Solar Radiation	RadAvg	1668	1717	1751	1780	1691	1605	1667	1856	2046	2102	1947	1689	
	RadStd	183	169	162	134	104	69	53	44	82	102	152	167	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	+1.12	N/A	-0.31	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page