

PRAYA LOMBOK, Indonesia

WMO: 972400

Lat: 8.7658S

Lon: 116.2791E

Elev: 107

StdP: 100.05

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	20.4	17.1	12.4	24.9	18.0	13.1	24.6	8.4	28.3	8.0	28.0	0.4	40	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	7.7	33.2	25.7	32.8	25.7	32.2	25.7	27.4	31.1	27.0	30.8	26.7	30.4	4.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	22.0	29.4	26.0	21.7	29.1	25.7	21.2	28.8	87.7	31.4	85.9	30.9	84.4	30.7	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
7.8	6.8	6.1	DB	17.8	35.2	1.7	1.6	16.6	36.3	15.6	37.2	14.7	38.1	13.5	39.2	
			WB	16.8	29.0	1.2	0.9	15.9	29.7	15.2	30.3	14.5	30.8	13.6	31.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.2	27.6	27.6	27.7	27.8	27.4	26.5	25.7	25.8	26.7	27.9	28.2	27.8
	DBStd	1.24	0.95	0.87	0.87	0.69	0.89	1.08	1.08	1.10	1.07	0.79	0.87	0.96
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6285	545	492	549	536	538	494	487	491	501	554	546	553
	CDD18.3	3243	287	259	291	286	280	244	229	232	251	296	296	294
	CDH23.3	31255	2852	2546	2843	2898	2728	2157	1850	1926	2267	3072	3162	2954
CDH26.7	10714	902	830	986	1071	989	719	552	595	754	1150	1194	971	
Wind	WSAvg	2.3	2.4	2.2	1.8	1.6	2.1	2.4	2.8	3.0	2.8	2.6	2.1	2.0
Precipitation	PrecAvg	1738	272	274	224	169	83	54	38	12	40	104	184	285
	PrecMax	2643	511	917	356	307	249	209	262	68	415	386	361	515
	PrecMin	1206	108	63	63	74	0	3	2	0	0	0	40	45
	PrecStd	339	121	167	83	68	61	49	62	15	94	126	94	96
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	32.7	33.1	33.2	33.0	32.2	31.9	31.9	32.6	33.8	34.1	33.9
		MCWB	26.2	26.3	26.2	26.0	26.0	25.2	24.8	24.1	24.3	24.5	25.5	26.3
	2%	DB	31.9	32.0	32.2	32.6	32.1	31.6	30.9	31.0	31.8	32.8	33.1	32.5
		MCWB	26.0	26.3	26.1	26.0	25.8	25.1	24.1	23.6	24.4	24.8	25.8	26.3
	5%	DB	31.2	31.4	31.8	32.0	31.7	30.9	30.1	30.2	31.1	32.1	32.4	31.7
		MCWB	25.9	26.1	26.1	25.9	25.7	24.9	23.9	23.5	24.2	25.0	25.8	26.2
	10%	DB	30.6	30.8	31.0	31.3	31.0	30.2	29.6	29.8	30.4	31.4	31.7	30.9
		MCWB	25.8	25.9	25.9	25.9	25.4	24.6	23.7	23.4	23.9	24.9	25.8	26.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.5	27.6	27.8	27.6	26.6	26.3	25.8	26.2	27.1	27.7	27.8
		MCDB	30.7	31.0	31.3	31.2	31.0	30.4	29.9	29.8	30.0	31.2	31.9	31.1
	2%	WB	26.7	26.8	26.9	27.0	26.7	26.1	25.6	25.0	25.6	26.3	26.9	27.1
		MCDB	30.4	30.6	30.7	30.9	30.4	30.0	29.1	28.8	29.3	30.4	30.9	30.7
	5%	WB	26.3	26.5	26.5	26.6	26.4	25.6	25.0	24.5	25.1	25.9	26.5	26.6
		MCDB	29.8	30.2	30.2	30.3	30.0	29.4	28.4	28.4	28.9	30.0	30.3	30.2
	10%	WB	26.0	26.1	26.1	26.2	26.0	25.2	24.5	24.0	24.6	25.6	26.1	26.2
		MCDB	29.5	29.7	29.7	29.9	29.6	28.8	27.7	28.1	28.4	29.4	29.9	29.6
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.8	7.2	7.8	8.1	8.3	8.4	8.6	8.2	8.1	7.7	6.8
		MCDBR	7.1	7.6	8.1	8.4	8.6	8.9	8.9	9.0	8.7	8.9	8.5	7.8
		MCWBR	2.8	3.1	3.3	3.4	3.5	3.7	3.6	3.4	2.9	2.9	2.9	3.1
	5% WB	MCDBR	6.6	7.2	7.6	7.8	7.8	8.1	7.8	8.2	7.8	7.9	7.7	7.2
MCWBR		2.9	3.2	3.4	3.4	3.5	3.7	3.7	3.6	3.2	3.1	3.2	3.2	
Clear-Sky Solar Irradiance	taub		0.468	0.470	0.440	0.432	0.425	0.416	0.409	0.422	0.446	0.488	0.493	0.474
	taud		2.311	2.307	2.395	2.427	2.437	2.458	2.467	2.405	2.329	2.200	2.213	2.290
	Ebn at Noon		878	873	885	863	840	833	847	860	866	847	849	869
	Edh at Noon		138	139	125	116	109	104	105	117	132	153	152	141
All-Sky Solar Radiation	RadAvg		5.26	5.41	5.52	5.61	5.33	5.06	5.26	5.85	6.45	6.62	6.14	5.33
	RadStd		0.58	0.53	0.51	0.42	0.33	0.22	0.17	0.14	0.26	0.32	0.48	0.53

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	+0.62	N/A	-0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page