

SUMBAWA BESAR BRANGBIJI, Indonesia

WMO: 972600

Lat: 8.4884S

Lon: 117.4135E

Elev: 10

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	68.4	69.6	58.6	73.5	81.6	60.8	79.7	80.4	17.3	86.3	15.1	87.1	3.8	140	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	15.3	94.1	76.1	92.7	76.5	91.7	76.8	81.2	88.2	80.7	87.7	80.1	87.0	8.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	151.5	85.3	78.7	149.2	84.8	78.2	146.7	84.3	44.9	88.8	44.3	88.2	43.9	87.4	91.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.0	13.3	11.8	DB	65.0	98.3	4.1	2.3	62.0	100.0	59.7	101.3	57.4	102.7	54.4	104.4
			WB	60.4	83.7	2.0	3.1	59.0	85.9	57.8	87.6	56.7	89.4	55.3	91.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	80.7	80.5	81.1	82.2	82.0	80.9	80.1	80.4	82.3	83.7	83.7	81.8	(6)
(7)		DBStd	2.00	1.47	1.38	1.41	1.58	1.59	1.74	1.62	1.71	1.74	1.67	1.81	1.58	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11536	951	855	964	967	992	926	932	941	968	1045	1010	985	(10)
(11)		CDD65	6061	486	435	499	517	527	476	467	476	518	580	560	520	(11)
(12)		CDH74	61595	4601	4047	4846	5388	5394	4570	4308	4585	5513	6681	6411	5251	(12)
(13)		CDH80	24108	1330	1141	1604	2128	2222	1870	1764	1966	2510	3038	2761	1774	(13)
(14)	Wind	WSAvg	4.8	4.1	4.3	3.9	3.9	4.8	5.5	5.9	6.1	5.6	5.5	4.7	3.8	(14)
(15)	Precipitation	PrecAvg	52.3	10.5	10.4	9.0	4.3	2.0	1.0	0.3	0.2	0.3	1.3	4.8	8.1	(15)
(16)		PrecMax	81.0	29.3	20.9	15.7	10.0	8.0	7.7	3.4	2.2	1.7	7.3	16.7	17.5	(16)
(17)		PrecMin	31.7	1.3	2.6	3.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	1.6	(17)
(18)		PrecStd	13.5	5.9	4.9	3.5	2.8	2.3	1.8	0.7	0.6	0.5	1.6	3.9	3.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.3	89.7	91.2	92.7	92.6	91.8	91.0	92.1	95.0	96.1	95.9	92.1	(19)
(20)			MCWB	79.4	79.5	79.6	78.5	77.9	76.8	74.5	74.1	73.2	75.6	77.2	79.8	(20)
(21)		2%	DB	88.6	88.2	89.6	91.4	91.3	90.5	89.9	90.8	93.3	94.1	93.5	90.1	(21)
(22)			MCWB	79.1	79.4	79.3	78.3	77.7	76.4	74.5	73.9	73.9	76.1	77.9	79.5	(22)
(23)		5%	DB	87.2	87.0	88.4	90.3	90.2	89.5	89.0	89.8	91.8	92.7	91.8	88.8	(23)
(24)			MCWB	78.8	79.1	79.2	78.6	77.6	76.1	74.3	73.6	74.3	76.5	78.5	79.3	(24)
(25)		10%	DB	86.0	85.7	87.1	89.1	89.1	88.4	87.9	88.7	90.5	91.2	90.4	87.5	(25)
(26)			MCWB	78.7	78.8	79.0	78.8	77.4	75.9	74.1	73.3	74.6	76.9	78.6	79.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.0	81.6	81.5	81.5	80.1	79.5	78.3	79.6	81.1	81.8	81.6	(27)
(28)			MCDWB	87.5	86.9	88.4	88.6	88.5	87.7	86.4	86.7	88.3	89.3	89.1	89.1	(28)
(29)		2%	WB	80.1	80.2	80.6	80.7	80.4	79.0	78.2	77.0	78.2	79.9	80.8	80.7	(29)
(30)			MCDWB	85.9	85.7	86.9	88.2	87.7	86.8	85.7	86.5	87.3	88.5	88.7	87.8	(30)
(31)		5%	WB	79.7	79.8	80.0	80.0	79.6	78.2	77.1	76.0	77.3	79.0	80.0	80.0	(31)
(32)			MCDWB	85.3	85.2	86.1	87.4	87.1	86.2	85.2	86.0	86.7	88.1	88.2	86.8	(32)
(33)		10%	WB	79.1	79.2	79.4	79.5	78.8	77.3	76.0	75.0	76.4	78.3	79.4	79.5	(33)
(34)			MCDWB	84.5	84.4	85.4	86.8	86.4	85.5	84.4	85.5	86.0	87.5	87.7	85.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.1	11.0	12.5	14.7	15.6	16.5	17.5	18.6	19.1	17.6	15.3	12.4	(35)
(36)			MCDBR	13.1	12.9	14.5	16.5	16.8	17.4	18.3	19.3	20.2	19.0	16.9	14.1	(36)
(37)			MCWBR	6.3	6.2	7.1	6.9	6.7	6.7	6.8	6.9	6.9	7.1	6.5	6.2	(37)
(38)		5% WB	MCDWB	11.5	11.3	12.9	14.3	14.7	15.2	15.4	17.8	17.9	17.2	15.2	12.8	(38)
(39)			MCWBR	6.0	5.9	6.7	6.8	6.9	6.7	6.8	7.3	7.1	7.3	6.7	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.471	0.478	0.445	0.433	0.430	0.425	0.420	0.433	0.455	0.496	0.502	0.479	(40)	
(41)		taud	2.287	2.270	2.361	2.403	2.406	2.422	2.421	2.363	2.290	2.162	2.174	2.263	(41)	
(42)		Ebn at Noon	277	275	279	273	265	262	266	270	272	266	267	274	(42)	
(43)		Edh at Noon	45	46	41	38	36	34	35	39	43	50	50	46	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1604	1638	1694	1729	1664	1582	1629	1822	2021	2078	1930	1652	(44)	
(45)		RadStd	173	151	158	135	104	75	59	54	81	118	144	150	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page