

BIMA SALAHUDDIN, IndonesiaWMO: **972700**Lat: **8.5428S**Lon: **118.6930E**Elev: **2**StdP: **101.30**Time Zone: **8.00 (E08)**Period: **99-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	21.1	17.2	12.3	28.5	18.1	13.0	27.4	9.3	29.7	8.5	29.9	0.1	130	0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	8.9	35.1	25.4	34.4	25.5	33.7	25.5	27.8	32.0	27.4	31.6	27.1	31.2	5.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.3	30.2	26.2	21.7	29.6	25.9	21.3	29.2	88.8	32.2	86.8	31.8	85.3	31.4	
															29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.3	7.5	6.8	18.7	36.8	1.9	1.0	17.4	37.6	16.3	38.2	15.3	38.8	13.9	39.5
			17.8	28.7	1.5	0.6	16.8	29.2	15.9	29.5	15.0	29.9	13.9	30.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	28.2	27.9	28.1	28.2	27.9	26.9	26.5	26.9	28.1	29.4	29.7	28.7
	DBStd	1.30	0.88	0.82	0.76	0.77	0.88	1.14	0.94	0.96	0.97	0.83	1.04	1.05
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6583	564	502	561	547	555	508	512	522	543	600	591	579
	CDD18.3	3541	306	268	302	297	297	258	254	264	293	342	341	321
	CDH23.3	36377	3102	2633	3017	3118	3017	2360	2211	2415	3044	4014	4051	3394
CDH26.7	14139	1040	839	1053	1209	1149	833	784	963	1319	1844	1858	1249	
Wind	WSAvg	2.0	1.0	1.1	1.1	1.3	1.8	2.3	2.6	3.0	3.1	2.9	2.0	1.2
Precipitation	PrecAvg	1369	266	234	190	108	93	35	30	6	10	38	129	230
	PrecMax	1776	451	377	427	301	209	131	154	17	137	175	294	389
	PrecMin	886	46	105	43	20	51	17	14	3	0	4	17	129
	PrecStd	245	88	71	77	71	43	28	36	4	29	41	80	66
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	33.2	33.5	33.8	33.4	32.7	32.3	33.1	34.7	36.0	36.5	35.1
		MCWB	26.5	26.6	26.6	26.5	26.4	26.0	24.8	24.6	24.3	24.6	25.5	26.3
	2%	DB	33.0	32.3	32.7	33.1	32.7	31.9	31.5	32.3	33.8	35.0	35.4	33.7
		MCWB	26.3	26.5	26.5	26.3	26.1	25.6	24.4	24.3	24.4	24.9	25.6	26.6
	5%	DB	32.1	31.7	32.0	32.5	32.1	31.2	31.0	31.7	33.1	34.2	34.6	32.7
		MCWB	26.3	26.4	26.4	26.2	25.9	25.1	24.1	24.1	24.4	25.0	25.7	26.5
	10%	DB	31.2	30.9	31.3	31.9	31.5	30.6	30.4	31.1	32.4	33.5	33.7	31.7
		MCWB	26.2	26.2	26.3	26.0	25.6	24.7	23.9	23.8	24.2	25.0	25.7	26.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.0	28.1	28.2	28.2	28.0	27.3	26.9	26.8	26.9	27.1	27.8	28.0
		MCDB	32.3	31.6	31.9	32.2	31.8	31.5	30.6	31.6	32.3	33.0	33.4	32.9
	2%	WB	27.2	27.2	27.3	27.4	27.1	26.5	25.9	25.5	26.1	26.5	27.1	27.4
		MCDB	31.2	30.9	31.1	31.4	31.0	30.6	29.6	30.4	31.2	32.2	32.2	31.8
	5%	WB	26.7	26.7	26.8	26.8	26.6	25.8	25.2	24.8	25.4	26.1	26.7	27.0
		MCDB	30.4	30.3	30.6	30.8	30.5	29.8	29.1	30.0	30.4	31.6	31.5	31.1
	10%	WB	26.4	26.3	26.5	26.5	26.1	25.3	24.7	24.3	24.9	25.7	26.3	26.6
		MCDB	29.8	29.6	30.0	30.3	30.1	29.2	28.6	29.4	29.8	31.0	30.9	30.4
Mean Daily Temperature Range	5% DB	MDBR	6.7	6.5	7.2	8.0	8.0	8.3	8.7	9.6	9.9	9.6	8.9	7.2
		MCDBR	7.7	7.6	8.2	8.8	8.6	8.8	9.2	10.0	10.4	10.2	9.8	8.2
		MCWBR	2.6	2.8	3.0	3.0	2.9	3.3	3.4	3.4	2.9	2.5	2.4	2.6
	5% WB	MCDBR	6.9	6.9	7.5	7.8	7.6	7.8	8.0	9.5	9.5	9.3	8.8	7.6
		MCWBR	2.8	2.9	3.0	3.1	2.9	3.2	3.4	3.7	3.3	2.9	2.8	2.7
Clear-Sky Solar Irradiance	taub		0.451	0.455	0.428	0.425	0.427	0.423	0.419	0.429	0.449	0.484	0.484	0.460
	taud		2.349	2.335	2.403	2.420	2.412	2.426	2.422	2.374	2.308	2.197	2.229	2.320
	Ebn at Noon		893	887	895	870	839	826	838	854	863	850	857	881
	Edh at Noon		133	135	124	117	112	108	110	120	134	153	149	136
All-Sky Solar Radiation	RadAvg		5.30	5.36	5.58	5.56	5.24	4.92	5.09	5.68	6.36	6.54	6.23	5.42
	RadStd		0.53	0.41	0.48	0.36	0.26	0.25	0.18	0.14	0.23	0.30	0.40	0.43

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page