

MAUMERE WAI OTI, Indonesia

WMO: 973000

Lat: 8.6355S

Lon: 122.2380E

Elev: 10

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	71.2	72.4	61.4	81.3	81.0	63.1	86.6	80.2	20.4	80.4	18.2	83.1	3.4	210	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	13.2	93.1	78.6	92.0	78.6	91.2	78.5	81.9	89.0	81.3	88.3	80.7	87.9	8.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.0	155.9	87.0	79.2	151.5	85.9	78.7	148.9	85.3	45.8	89.4	45.0	88.8	44.4	88.2	91.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	14.4	12.2	66.4	97.5	3.9	4.1	63.6	100.4	61.3	102.8	59.1	105.1	56.3	108.1
			62.9	85.3	1.6	2.7	61.8	87.2	60.8	88.8	59.9	90.3	58.7	92.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.3	81.7	81.2	81.9	83.0	82.8	81.5	80.6	80.8	82.4	84.0	84.8	83.1
	DBStd	2.08	1.57	1.59	1.45	1.42	1.63	1.85	1.73	1.75	1.71	1.59	1.74	2.14
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11796	984	874	988	991	1016	944	950	955	971	1053	1044	1026
	CDD65	6321	519	454	523	541	551	494	485	490	521	588	594	561
	CDH74	67889	5462	4556	5527	6115	5982	4829	4387	4558	5551	7026	7439	6457
CDH80	24780	1642	1297	1835	2335	2163	1584	1395	1589	2154	3010	3339	2437	
Wind	WSAvg	4.9	3.6	3.5	3.1	3.7	5.3	6.2	6.7	6.9	6.3	5.5	4.4	3.5
Precipitation	PrecAvg	40.5	7.4	7.7	5.8	4.0	1.4	0.6	0.5	0.2	0.3	1.3	3.1	7.2
	PrecMax	57.9	15.8	14.0	14.6	9.5	6.4	3.1	4.2	1.5	3.4	8.7	7.0	16.9
	PrecMin	24.5	2.0	1.9	0.5	0.7	0.0	0.0	0.0	0.0	0.0	0.1	0.4	2.1
	PrecStd	8.8	3.8	3.4	3.5	2.7	1.6	0.9	1.0	0.4	0.7	1.9	2.1	3.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.8	90.8	91.4	92.4	91.8	90.9	90.1	90.8	92.5	94.3	95.2	93.4
		MCWB	80.5	79.8	79.5	78.8	78.9	77.2	75.5	73.5	74.4	76.5	78.5	80.7
	2%	DB	89.3	88.8	89.8	90.9	90.5	89.6	88.7	89.3	91.0	92.7	93.3	91.8
		MCWB	80.1	79.7	79.3	79.1	78.7	76.8	75.0	73.9	75.5	77.5	79.2	80.8
	5%	DB	87.9	87.5	88.5	89.9	89.4	88.3	87.6	88.3	89.9	91.5	92.1	90.5
		MCWB	79.9	79.7	79.4	79.1	78.4	76.3	74.6	73.8	75.7	77.7	79.2	80.4
	10%	DB	86.6	86.1	87.3	88.9	88.3	87.2	86.4	87.2	88.8	90.4	90.9	88.9
		MCWB	79.4	79.3	79.3	79.0	77.9	75.9	74.3	73.6	75.6	77.7	79.1	79.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	81.6	81.9	82.5	81.9	79.9	78.6	78.3	79.5	81.0	82.5	83.5
		MCDB	87.7	87.6	87.9	88.9	88.4	87.3	86.1	86.2	88.0	90.1	91.0	90.8
	2%	WB	80.9	80.8	81.0	81.0	80.7	78.8	77.4	76.9	78.3	79.9	81.2	81.9
		MCDB	87.2	86.8	87.1	88.0	87.9	86.6	85.3	85.2	87.4	89.2	89.8	89.5
	5%	WB	80.3	80.1	80.4	80.4	79.7	77.9	76.4	75.9	77.6	79.2	80.5	80.9
		MCDB	86.4	85.9	86.5	87.5	86.9	85.6	84.5	84.8	86.6	88.3	89.1	88.3
	10%	WB	79.7	79.5	79.8	79.7	78.8	77.0	75.5	74.9	76.8	78.5	79.9	80.1
		MCDB	85.5	85.1	85.7	86.8	86.0	84.8	83.5	84.1	85.8	87.5	88.2	87.1
Mean Daily Temperature Range	5% DB	MDBR	9.7	9.9	11.3	12.4	12.1	12.5	12.9	14.3	14.6	14.3	13.2	11.1
		MCDBR	11.5	12.0	13.1	13.7	13.0	13.4	13.6	15.1	15.1	15.1	14.6	13.4
		MCWBR	5.3	5.4	5.8	5.8	5.3	5.2	5.1	5.4	5.4	5.7	5.6	5.6
	5% WB	MCDBR	10.7	10.8	11.6	12.5	12.3	12.1	12.6	13.7	14.1	14.1	13.1	12.1
MCWBR		5.3	5.5	5.8	6.0	5.7	5.6	5.8	5.8	6.2	6.4	5.9	5.7	
Clear-Sky Solar Irradiance	taub	0.452	0.453	0.434	0.422	0.426	0.424	0.413	0.416	0.445	0.487	0.483	0.467	
	taud	2.369	2.364	2.408	2.447	2.436	2.439	2.456	2.428	2.342	2.210	2.248	2.314	
	Ebn at Noon	283	282	283	277	266	262	268	274	275	269	272	278	
	Edh at Noon	42	42	39	36	35	34	34	36	41	48	46	43	
All-Sky Solar Radiation	RadAvg	1728	1797	1841	1853	1728	1611	1687	1907	2093	2151	2053	1773	
	RadStd	183	174	153	128	98	84	46	51	60	98	121	130	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page