

MAUMERE WAI OTI, Indonesia

WMO: 973000

Lat: 8.6355S

Lon: 122.2380E

Elev: 3

StdP: 101.29

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.8	22.5	16.3	11.6	27.2	17.3	12.4	26.8	9.1	26.9	8.1	28.4	1.5	210	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	7.4	34.0	25.9	33.4	25.9	32.9	25.8	27.7	31.7	27.4	31.3	27.1	31.0	3.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	30.5	26.2	21.6	30.0	25.9	21.3	29.6	88.7	31.9	86.7	31.6	85.3	31.2	33.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
7.8	6.4	5.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			19.1	36.4	2.2	2.3	17.5	38.0	16.3	39.3	15.1	40.6	13.5	42.3
			17.2	29.6	0.9	1.5	16.5	30.7	16.0	31.5	15.5	32.4	14.9	33.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	27.6	27.3	27.7	28.4	28.2	27.5	27.0	27.1	28.0	28.9	29.3	28.4	(6)
(7)		DBStd	1.16	0.87	0.88	0.81	0.79	0.91	1.03	0.96	0.97	0.95	0.88	0.97	1.19	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6553	547	486	549	551	564	524	528	531	539	585	580	570	(10)
(11)		CDD18.3	3512	288	252	291	301	306	274	269	272	289	327	330	312	(11)
(12)		CDH23.3	37716	3034	2531	3071	3397	3323	2683	2437	2532	3084	3903	4133	3587	(12)
(13)	CDH26.7	13767	912	721	1019	1297	1202	880	775	883	1197	1672	1855	1354	(13)	
(14)	Wind	WSAvg	2.2	1.6	1.6	1.4	1.7	2.4	2.8	3.0	3.1	2.8	2.5	2.0	1.6	(14)
(15)	Precipitation	PrecAvg	1029	188	195	147	102	36	15	13	6	7	34	78	184	(15)
(16)		PrecMax	1470	402	356	370	241	162	78	106	38	87	221	179	430	(16)
(17)		PrecMin	622	50	47	13	18	1	0	0	0	3	10	53	53	(17)
(18)		PrecStd	223	97	86	89	68	40	24	26	11	19	49	53	89	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	32.6	32.7	33.0	33.6	33.2	32.7	32.3	32.6	33.6	34.6	35.1	34.1	(19)	
(20)		MCWB	26.9	26.5	26.4	26.0	26.1	25.1	24.2	23.0	23.6	24.7	25.9	27.1	(20)	
(21)		DB	31.8	31.5	32.1	32.7	32.5	32.0	31.5	31.9	32.8	33.7	34.1	33.2	(21)	
(22)		MCWB	26.7	26.5	26.3	26.2	25.9	24.9	23.9	23.3	24.2	25.3	26.2	27.1	(22)	
(23)		DB	31.1	30.8	31.4	32.1	31.9	31.3	30.9	31.3	32.2	33.1	33.4	32.5	(23)	
(24)		MCWB	26.6	26.5	26.3	26.2	25.8	24.6	23.7	23.2	24.3	25.4	26.2	26.9	(24)	
(25)		DB	30.3	30.1	30.7	31.6	31.3	30.7	30.2	30.7	31.6	32.4	32.7	31.6	(25)	
(26)		MCWB	26.4	26.3	26.3	26.1	25.5	24.4	23.5	23.1	24.2	25.4	26.2	26.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	27.7	27.6	27.7	28.1	27.7	26.6	25.9	25.7	26.4	27.2	28.1	28.6	(27)	
(28)		MCDWB	31.0	30.9	31.0	31.6	31.3	30.7	30.1	30.1	31.1	32.3	32.8	32.7	(28)	
(29)		WB	27.2	27.1	27.2	27.2	27.0	26.0	25.2	24.9	25.7	26.6	27.4	27.7	(29)	
(30)		MCDWB	30.7	30.4	30.6	31.1	31.0	30.3	29.6	29.6	30.8	31.8	32.1	31.9	(30)	
(31)		WB	26.8	26.7	26.9	26.9	26.5	25.5	24.7	24.4	25.3	26.2	27.0	27.2	(31)	
(32)		MCDWB	30.2	29.9	30.3	30.8	30.5	29.8	29.2	29.3	30.3	31.3	31.7	31.3	(32)	
(33)		WB	26.5	26.4	26.5	26.5	26.0	25.0	24.2	23.9	24.9	25.8	26.6	26.7	(33)	
(34)		MCDWB	29.7	29.5	29.8	30.4	30.0	29.3	28.6	28.9	29.9	30.8	31.2	30.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	5.4	5.5	6.3	6.9	6.7	6.9	7.2	8.0	8.1	7.9	7.4	6.2	(35)	
(36)		MCDBR	6.4	6.7	7.3	7.6	7.2	7.4	7.6	8.4	8.4	8.4	8.1	7.5	(36)	
(37)		MCWBR	3.0	3.0	3.2	3.2	2.9	2.9	2.8	3.0	3.0	3.2	3.1	3.1	(37)	
(38)		MCDBR	5.9	6.0	6.4	7.0	6.9	6.7	7.0	7.6	7.8	7.8	7.3	6.7	(38)	
(39)		MCWBR	2.9	3.0	3.2	3.3	3.1	3.1	3.2	3.2	3.4	3.5	3.3	3.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.452	0.453	0.434	0.422	0.426	0.424	0.413	0.416	0.445	0.487	0.483	0.467	(40)	
(41)		taud	2.369	2.364	2.408	2.447	2.436	2.439	2.456	2.428	2.342	2.210	2.248	2.314	(41)	
(42)		Ebn at Noon	892	888	891	872	839	825	844	865	867	848	858	875	(42)	
(43)		Edh at Noon	131	131	123	114	109	106	106	114	130	151	146	137	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.45	5.67	5.80	5.84	5.45	5.08	5.32	6.01	6.60	6.78	6.47	5.59	(44)	
(45)		RadStd	0.58	0.55	0.48	0.41	0.31	0.27	0.14	0.16	0.19	0.31	0.38	0.41	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page