

ALOR MALI KALABAH, Indonesia

WMO: 973200

Lat: 8.1371S

Lon: 124.5930E

Elev: 39

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	68.8	70.3	63.1	86.6	75.2	64.6	91.5	76.2	21.9	84.6	18.8	85.2	0.4	N/A	0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	12.4	91.7	79.7	90.9	79.5	90.2	79.3	81.8	88.6	81.1	88.0	80.8	87.7	8.5	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.8	155.0	86.1	79.2	151.6	85.7	78.8	149.7	85.4	45.5	88.9	44.9	88.5	44.5	88.0	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	14.0	11.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			61.6	84.0	2.9	1.9	59.5	85.4	57.8	86.5	56.2	87.6	54.1	89.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	81.9	81.2	81.8	81.9	81.7	80.1	79.1	78.7	80.1	82.5	84.4	83.8	(6)
(7)		DBStd	2.34	1.60	1.55	1.33	1.31	1.40	1.85	1.73	1.66	2.08	1.83	1.41	1.91	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11470	990	874	985	958	982	904	901	888	902	1007	1031	1048	(10)
(11)		CDD65	5995	525	454	520	508	517	454	436	423	452	542	581	583	(11)
(12)		CDH74	68244	5751	4794	5688	5846	5814	4736	4325	4248	5081	6866	7833	7262	(12)
(13)	CDH80	25599	1832	1454	1934	2248	2220	1638	1376	1339	1872	2953	3670	3063	(13)	
(14)	Wind	WSAvg	4.0	4.6	3.7	3.5	3.0	3.6	3.8	4.3	4.6	4.3	4.3	3.9	3.9	(14)
(15)	Precipitation	PrecAvg	45.9	11.2	10.2	5.4	3.3	2.2	1.1	0.4	0.2	0.2	0.8	2.5	8.0	(15)
(16)		PrecMax	67.2	21.5	19.6	13.7	10.1	9.2	5.7	2.6	1.1	1.6	3.9	9.3	14.0	(16)
(17)		PrecMin	29.6	3.5	3.9	0.2	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.2	2.1	(17)
(18)		PrecStd	9.4	4.9	4.1	3.0	2.5	2.2	1.3	0.5	0.3	0.4	1.1	2.0	3.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.6	90.0	90.2	90.6	90.5	89.7	88.3	88.0	89.8	91.9	92.9	92.7	(19)
(20)			MCWB	80.5	79.9	80.5	79.3	79.1	77.9	76.1	75.6	77.1	78.4	79.2	81.2	(20)
(21)		2%	DB	89.1	88.5	89.0	89.8	89.6	88.6	87.5	87.0	88.8	90.8	91.8	91.7	(21)
(22)			MCWB	80.3	80.0	80.2	79.3	78.8	77.5	75.9	75.3	76.8	78.4	79.3	80.8	(22)
(23)		5%	DB	87.9	87.6	88.1	89.0	88.9	87.6	86.7	86.3	88.0	90.0	91.1	90.5	(23)
(24)			MCWB	80.0	80.0	79.9	79.2	78.5	77.1	75.6	75.0	76.4	78.3	79.3	80.5	(24)
(25)		10%	DB	86.8	86.4	87.3	88.2	88.0	86.8	85.8	85.6	87.1	89.0	90.3	89.3	(25)
(26)			MCWB	79.7	79.6	79.7	79.0	78.2	76.9	75.3	74.7	75.9	77.9	79.2	80.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	81.6	81.9	81.8	81.3	80.2	79.1	78.2	79.4	80.4	81.8	82.6	(27)
(28)			MCDWB	88.1	87.5	87.8	88.2	87.7	86.3	85.1	85.3	87.0	89.0	89.4	90.6	(28)
(29)		2%	WB	81.0	80.9	81.1	80.8	80.4	79.4	78.0	77.1	78.6	79.7	81.0	81.7	(29)
(30)			MCDWB	87.1	86.8	87.2	87.5	87.2	85.9	84.6	85.0	86.8	88.4	89.1	89.5	(30)
(31)		5%	WB	80.5	80.3	80.6	80.1	79.7	78.8	77.2	76.3	77.8	79.1	80.4	81.0	(31)
(32)			MCDWB	86.5	86.1	86.9	86.9	86.5	85.5	84.0	84.4	86.1	87.9	88.8	88.6	(32)
(33)		10%	WB	79.9	79.8	80.0	79.7	79.1	78.0	76.5	75.6	77.0	78.6	79.9	80.6	(33)
(34)			MCDWB	85.6	85.4	86.0	86.4	85.8	84.7	83.4	83.7	85.4	87.3	88.2	88.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.8	10.2	11.3	12.9	13.4	13.9	14.5	14.6	14.6	13.6	12.4	11.0	(35)
(36)			MCDBR	11.3	11.9	12.3	13.5	13.8	14.2	14.8	14.8	14.4	13.5	13.0	12.2	(36)
(37)			MCWBR	5.1	5.3	5.7	5.3	5.4	5.8	6.3	6.3	6.0	5.3	4.8	4.9	(37)
(38)		5% WB	MCDWB	10.5	10.9	11.4	12.5	13.0	12.3	13.4	13.6	13.4	13.2	12.1	11.5	(38)
(39)			MCWBR	5.1	5.4	5.7	5.6	5.5	5.7	6.3	6.3	6.1	5.5	5.0	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.473	0.476	0.452	0.435	0.442	0.443	0.428	0.436	0.467	0.514	0.512	0.489	(40)	
(41)		taud	2.310	2.298	2.366	2.430	2.405	2.377	2.421	2.376	2.276	2.124	2.159	2.251	(41)	
(42)		Ebn at Noon	277	275	277	273	262	257	264	269	269	262	264	271	(42)	
(43)		Edh at Noon	44	44	41	37	36	36	35	38	44	52	51	46	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1736	1788	1861	1895	1733	1643	1734	1976	2154	2195	2112	1797	(44)	
(45)		RadStd	160	173	145	121	100	83	71	45	56	109	117	141	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page