

TERNATE BABULLAH, Indonesia

WMO: 974300

Lat: 0.8293N

Lon: 127.3814E

Elev: 23

StdP: 101.05

Time Zone: 9.00 (E09)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	23.3	19.1	13.9	27.7	19.9	14.7	27.3	9.3	27.9	8.1	28.4	1.3	250	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.1	32.2	25.8	31.7	25.7	31.4	25.7	27.2	30.5	26.8	30.2	26.6	30.0	4.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	29.4	25.8	21.1	29.1	25.6	20.9	28.9	85.8	30.6	84.4	30.4	83.4	30.2	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	6.8	5.8	DB	21.2	34.0	1.3	1.8	20.3	35.3	19.5	36.4	18.7	37.4	17.8	38.7	(4)
(5)			WB	19.6	29.2	1.3	1.3	18.6	30.1	17.9	30.8	17.1	31.5	16.2	32.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	27.4	27.4	27.7	27.6	27.7	27.3	27.2	27.4	27.3	27.5	27.5	(6)	
(7)		DBStd	0.85	0.77	0.80	0.91	0.84	0.82	0.90	0.97	1.01	0.77	0.74	0.71	0.80	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6374	541	487	548	529	548	520	534	539	519	543	524	543	(10)
(11)		CDD18.3	3333	282	253	289	279	289	270	276	281	269	285	274	284	(11)
(12)		CDH23.3	34528	2898	2598	3053	2951	3073	2734	2789	2874	2731	2992	2849	2984	(12)
(13)		CDH26.7	10615	782	729	948	932	1016	839	823	872	855	1013	915	891	(13)
(14)	Wind	WSAvg	2.3	2.9	2.7	2.7	2.1	1.8	1.9	2.2	2.3	2.1	2.0	2.0	2.3	(14)
(15)	Precipitation	PrecAvg	2425	235	174	188	215	267	229	168	128	119	169	191	256	(15)
(16)		PrecMax	3714	523	437	397	441	533	393	415	309	403	633	544	621	(16)
(17)		PrecMin	1364	61	6	16	56	90	74	36	26	26	9	0	11	(17)
(18)		PrecStd	641	116	109	99	91	85	85	94	92	84	150	130	156	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.7	31.8	32.3	32.2	32.4	32.1	31.9	32.3	32.0	32.5	32.1	32.0	(19)
(20)			MCWB	26.4	26.0	26.3	26.5	26.2	25.8	24.9	24.9	24.9	25.7	25.7	26.3	(20)
(21)		2%	DB	30.9	31.0	31.5	31.4	31.7	31.4	31.2	31.5	31.3	31.6	31.4	31.2	(21)
(22)			MCWB	26.0	25.8	26.0	26.3	26.1	25.7	24.9	24.8	25.0	25.6	25.8	26.3	(22)
(23)		5%	DB	30.3	30.4	30.9	30.9	31.1	30.8	30.6	30.8	30.8	31.1	30.9	30.7	(23)
(24)			MCWB	25.9	25.7	25.8	26.1	26.1	25.6	24.9	24.8	25.1	25.6	25.8	26.2	(24)
(25)		10%	DB	29.7	29.9	30.3	30.3	30.6	30.2	30.0	30.2	30.2	30.5	30.3	30.1	(25)
(26)			MCWB	25.8	25.6	25.7	26.0	26.0	25.6	24.9	24.7	25.1	25.6	25.9	26.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	26.9	27.1	27.2	27.3	27.1	26.7	26.4	26.5	27.0	27.2	27.5	(27)
(28)			MCD B	30.5	30.5	30.7	30.8	30.7	30.5	30.3	29.9	29.9	30.4	30.3	30.3	(28)
(29)		2%	WB	26.6	26.3	26.6	26.8	26.9	26.6	26.1	26.0	26.1	26.5	26.7	26.8	(29)
(30)			MCD B	29.8	29.7	30.2	30.2	30.4	30.0	29.7	29.8	29.7	30.1	29.9	30.0	(30)
(31)		5%	WB	26.2	26.1	26.2	26.6	26.6	26.2	25.8	25.6	25.8	26.2	26.4	26.5	(31)
(32)			MCD B	29.3	29.4	29.7	29.9	30.0	29.6	29.2	29.3	29.4	29.9	29.7	29.7	(32)
(33)		10%	WB	26.0	25.8	26.0	26.2	26.4	26.0	25.5	25.3	25.5	26.0	26.1	26.2	(33)
(34)			MCD B	29.0	29.0	29.4	29.5	29.7	29.4	28.9	28.9	29.1	29.7	29.5	29.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.1	5.5	5.7	5.8	6.1	5.9	5.7	6.2	6.4	6.1	5.5	(35)	
(36)			MCDBR	5.8	6.1	6.3	6.4	6.7	6.6	6.3	6.4	6.9	7.0	6.8	6.2	(36)
(37)			MCWBR	2.6	2.6	2.7	2.7	3.0	2.9	2.7	2.6	3.0	3.1	3.0	2.8	(37)
(38)		5% WB	MCDBR	5.3	5.6	5.9	6.1	6.2	6.1	5.9	6.0	6.3	6.5	6.1	5.6	(38)
(39)			MCWBR	2.7	2.7	2.7	2.9	3.0	3.0	2.8	2.8	3.0	3.2	3.0	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.422	0.429	0.427	0.427	0.414	0.408	0.408	0.416	0.427	0.466	0.439	0.432	(40)	
(41)		taud	2.480	2.448	2.453	2.448	2.502	2.530	2.537	2.497	2.452	2.319	2.405	2.442	(41)	
(42)		Ebn at Noon	907	904	899	879	868	861	867	878	885	859	884	892	(42)	
(43)		Edh at Noon	114	119	119	116	106	101	102	109	117	134	122	117	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.23	5.54	5.73	5.61	5.37	4.82	5.02	5.34	5.69	5.87	5.49	5.28	(44)	
(45)		RadStd	0.27	0.46	0.52	0.40	0.32	0.34	0.55	0.60	0.56	0.43	0.37	0.40	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page