

SORONG DEO, Indonesia

WMO: 975020

Lat: 0.8911S

Lon: 131.2858E

Elev: 3

StdP: 101.29

Time Zone: 9.00 (E09)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.8	23.1	21.5	16.2	26.3	22.0	16.7	26.1	7.6	28.0	6.8	28.6	1.0	100	0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.2	32.3	26.3	32.0	26.3	31.6	26.3	27.5	30.8	27.2	30.5	27.0	30.4	3.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.0	29.6	26.2	21.6	29.2	26.0	21.4	29.0	87.1	30.9	85.9	30.8	85.0	30.5	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.5	5.0	DB	21.3	33.1	2.2	0.3	19.7	33.3	18.4	33.5	17.1	33.6	15.5	33.8	(4)
(5)			WB	20.8	28.5	2.1	0.6	19.3	28.9	18.1	29.2	16.9	29.5	15.4	29.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	27.6	27.7	27.7	27.7	27.7	27.0	26.6	26.6	27.0	27.6	27.7	27.8	(6)	
	DBStd	0.91	0.78	0.93	0.87	0.81	0.75	0.85	0.90	0.81	0.81	0.71	0.66	0.81	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6349	547	496	549	531	548	511	515	516	511	544	531	551	(10)	
	CDD18.3	3307	288	262	291	281	289	261	257	258	261	286	281	292	(11)	
	CDH23.3	32347	3006	2764	3076	2912	2933	2337	2131	2107	2341	2817	2860	3064	(12)	
(13)	CDH26.7	9907	983	906	1025	942	920	611	496	496	634	918	939	1037	(13)	
(14)	Wind	WSAvg	1.8	1.7	2.0	1.8	1.7	1.6	1.8	2.1	2.2	2.1	1.9	1.6	1.7	(14)
(15) Precipitation	PrecAvg	3218	211	188	254	227	311	352	369	288	264	190	208	223	(15)	
	PrecMax	5309	366	311	576	367	659	655	1037	856	482	443	357	418	(16)	
	PrecMin	1476	66	50	79	88	82	20	19	7	16	3	27	52	(17)	
	PrecStd	896	86	76	123	82	161	143	226	228	153	136	88	94	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.3	32.5	32.5	32.5	31.7	31.2	31.5	32.0	32.7	32.4	32.6	(19)	
		MCWB	26.1	26.0	25.8	26.6	26.5	26.6	26.1	26.2	26.3	26.5	26.5	26.7	(20)	
	2%	DB	31.7	31.7	31.9	31.9	31.7	31.0	30.5	30.7	31.2	31.9	31.7	31.9	(21)	
		MCWB	26.1	26.0	25.9	26.4	26.7	26.4	25.9	26.0	26.2	26.4	26.4	26.4	(22)	
	5%	DB	31.1	31.1	31.3	31.2	31.1	30.4	29.9	30.0	30.5	31.3	31.2	31.3	(23)	
		MCWB	26.0	25.9	25.9	26.4	26.6	26.2	25.7	25.8	26.1	26.2	26.4	26.4	(24)	
	10%	DB	30.6	30.6	30.6	30.6	30.5	29.7	29.2	29.3	29.8	30.6	30.6	30.7	(25)	
		MCWB	25.9	25.8	25.9	26.4	26.5	26.1	25.6	25.6	25.9	26.1	26.3	26.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.1	27.2	27.6	27.7	27.4	27.0	27.0	27.2	27.6	27.5	27.7	(27)	
		MCDB	30.6	30.9	30.5	31.0	30.9	30.5	30.2	30.2	30.3	31.3	30.9	31.2	(28)	
	2%	WB	26.8	26.7	26.7	27.1	27.2	27.0	26.5	26.5	26.7	27.1	27.1	27.2	(29)	
		MCDB	30.1	30.2	30.1	30.6	30.4	29.9	29.4	29.6	29.8	30.6	30.6	30.7	(30)	
	5%	WB	26.5	26.4	26.5	26.8	27.0	26.6	26.1	26.1	26.4	26.7	26.8	26.8	(31)	
		MCDB	29.8	29.8	29.8	30.1	30.1	29.4	28.9	29.2	29.4	30.1	30.2	30.3	(32)	
	10%	WB	26.2	26.1	26.2	26.5	26.7	26.3	25.8	25.7	26.1	26.4	26.6	26.6	(33)	
		MCDB	29.4	29.4	29.4	29.6	29.6	28.9	28.3	28.5	29.0	29.6	29.7	29.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.0	6.1	6.2	6.1	5.7	5.6	5.7	5.9	6.6	6.5	6.2	(35)	
		MCDBR	6.8	6.6	6.8	6.9	6.9	6.6	6.4	6.6	6.9	7.5	7.2	7.0	(36)	
	5% WB	MCWBR	2.4	2.2	2.2	2.6	2.8	2.7	2.5	2.6	2.8	2.9	2.8	2.6	(37)	
		MCWBR	6.5	6.2	6.2	6.4	6.1	6.0	5.8	6.1	6.2	6.8	6.6	6.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.404	0.404	0.404	0.399	0.398	0.408	0.412	0.422	0.427	0.449	0.421	0.410	(40)	
		taud	2.522	2.515	2.518	2.530	2.547	2.531	2.516	2.475	2.457	2.364	2.456	2.499	(41)	
	Ebn at Noon		927	929	920	904	881	859	860	871	885	876	905	917	(42)	
		Edh at Noon	110	112	111	107	101	101	103	111	116	129	117	111	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.21	5.39	5.55	5.37	5.24	4.70	4.77	5.13	5.30	5.60	5.34	5.11	(44)	
	RadStd		0.19	0.33	0.32	0.26	0.22	0.32	0.38	0.43	0.37	0.41	0.34	0.35	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page