

BIAK FRANS KAISIEPO, Indonesia

WMO: 975600

Lat: 1.1905S

Lon: 136.1040E

Elev: 46

StdP: 14.67

Time Zone: 9.00 (E09)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	73.9	74.5	71.9	118.2	77.6	72.7	121.3	77.7	20.1	83.4	17.6	83.8	3.6	330	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	9.3	88.8	80.2	88.1	80.1	87.7	80.0	81.9	86.6	81.3	86.2	80.9	85.9	9.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.5	158.8	85.8	79.9	155.4	85.1	79.2	152.0	84.5	45.8	86.9	45.1	86.6	44.6	86.6	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.1	14.2	12.3	DB	70.9	90.5	4.7	1.0	67.5	91.3	64.8	91.9	62.1	92.4	58.7	93.2
			WB	71.0	82.7	1.1	0.7	70.2	83.2	69.6	83.6	68.9	84.0	68.1	84.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.1	81.1	80.8	80.9	81.3	81.5	80.8	80.6	80.7	81.0	81.3	81.4	81.4	(6)
	DBStd	1.53	1.39	1.49	1.39	1.43	1.33	1.50	1.67	1.75	1.60	1.64	1.51	1.34	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	11345	965	864	959	938	976	925	949	953	931	970	941	974	(10)
	CDD65	5870	500	444	494	488	511	475	484	488	481	505	491	509	(11)
	CDH74	58849	5007	4335	4870	4962	5266	4670	4704	4810	4854	5199	5007	5165	(12)
	CDH80	16033	1361	1121	1281	1348	1485	1210	1197	1285	1357	1530	1425	1433	(13)
(14) Wind	WSAvg	4.6	4.9	4.9	5.0	4.7	4.2	4.3	4.8	4.7	4.6	4.5	4.5	4.7	(14)
(15) Precipitation	PrecAvg	110.6	10.0	9.9	10.2	8.0	10.0	8.4	10.2	9.2	8.8	8.1	8.1	9.3	(15)
	PrecMax	130.3	18.7	16.0	15.4	13.7	16.8	14.5	18.7	16.2	20.7	16.6	17.0	22.6	(16)
	PrecMin	73.3	2.2	5.3	4.6	3.1	4.3	3.4	3.0	1.0	1.9	1.9	2.8	3.1	(17)
	PrecStd	13.9	4.1	2.8	2.8	2.9	3.2	3.1	3.9	3.6	4.6	4.1	3.6	3.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.4	88.5	88.2	88.5	88.9	88.2	88.1	88.4	88.9	89.3	89.1	89.0	(19)
		MCWB	80.1	79.7	80.0	80.3	80.6	80.3	79.7	80.1	80.1	80.2	80.4	80.3	(20)
	2%	DB	87.7	87.6	87.3	87.6	87.9	87.3	86.9	87.5	87.8	88.1	88.0	88.0	(21)
		MCWB	80.0	79.6	79.8	80.2	80.5	80.1	79.5	79.9	79.8	79.8	80.1	80.3	(22)
	5%	DB	86.7	86.4	86.4	86.6	87.0	86.3	86.1	86.4	86.7	87.4	87.3	87.2	(23)
		MCWB	79.7	79.4	79.5	80.0	80.2	79.8	79.3	79.3	79.4	79.6	79.8	80.1	(24)
	10%	DB	85.9	85.6	85.7	85.8	86.1	85.5	85.2	85.7	85.9	86.3	86.2	86.1	(25)
		MCWB	79.5	79.1	79.3	79.8	80.0	79.5	79.0	78.9	79.1	79.4	79.5	79.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.6	81.3	81.9	82.1	82.6	81.7	81.0	81.9	81.4	82.0	81.7	82.2	(27)
		MCDB	86.6	86.1	86.5	86.3	86.9	86.2	85.6	87.0	87.1	87.0	87.1	86.9	(28)
	2%	WB	80.8	80.5	80.9	81.1	81.6	80.8	80.4	80.6	80.7	80.9	80.9	81.1	(29)
		MCDB	86.0	85.7	85.7	85.7	86.1	85.6	85.3	86.2	86.3	86.3	86.4	86.2	(30)
	5%	WB	80.1	79.9	80.1	80.6	80.8	80.2	79.8	79.8	80.0	80.3	80.4	80.6	(31)
		MCDB	85.2	84.9	85.0	85.4	85.6	84.9	84.6	85.1	85.4	85.6	85.8	85.8	(32)
	10%	WB	79.6	79.3	79.5	80.0	80.2	79.7	79.2	79.1	79.4	79.7	79.8	80.0	(33)
		MCDB	84.5	84.1	84.3	84.5	84.8	84.2	83.8	84.2	84.5	84.9	84.9	84.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	9.3	9.4	9.2	9.3	8.8	8.7	9.1	9.4	9.8	9.6	9.6	(35)
		MCDBR	10.9	10.5	10.4	10.3	10.4	10.1	9.9	10.4	10.5	11.3	11.0	11.0	(36)
	5% WB	MCWBR	5.1	4.9	5.0	4.9	5.0	4.8	4.7	4.7	4.8	5.1	5.2	5.2	(37)
		MCWBR	10.1	9.9	9.8	9.7	9.7	9.5	9.4	9.9	10.0	10.3	10.2	10.2	(38)
(40) Clear-Sky Solar Irradiance	taub	0.396	0.397	0.397	0.394	0.392	0.396	0.397	0.402	0.404	0.431	0.413	0.404	0.404	(40)
		2.574	2.565	2.568	2.583	2.584	2.574	2.569	2.543	2.538	2.442	2.510	2.545	2.545	(41)
	Ebn at Noon	297	297	294	288	281	276	277	282	287	283	289	293	293	(42)
		33	34	34	32	31	30	31	33	34	38	35	34	34	(43)
(44) All-Sky Solar Radiation	RadAvg	1503	1584	1616	1594	1536	1379	1414	1546	1607	1634	1494	1441	1441	(44)
	RadStd	98	120	121	107	81	99	131	113	119	107	111	91	91	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page