

BIAK FRANS KAISIEPO, Indonesia

WMO: 975600

Lat: 1.1905S

Lon: 136.1040E

Elev: 14

StdP: 101.16

Time Zone: 9.00 (E09)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	23.6	22.2	16.9	25.4	22.6	17.3	25.4	9.0	28.6	7.9	28.8	1.6	330	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	5.2	31.5	26.8	31.2	26.7	31.0	26.7	27.7	30.3	27.4	30.1	27.2	30.0	4.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.7	29.9	26.6	22.2	29.5	26.2	21.7	29.2	88.6	30.5	87.0	30.3	85.9	30.4	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
(a)	(b)	(c)		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
7.7	6.4	5.5	DB	21.6	32.5	2.6	0.6	19.7	32.9	18.2	33.3	16.7	33.6	14.8	34.0	
			WB	21.7	28.2	0.6	0.4	21.2	28.4	20.9	28.7	20.5	28.9	20.1	29.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	27.3	27.1	27.2	27.4	27.5	27.1	27.0	27.1	27.2	27.4	27.4	27.4
	DBStd	0.85	0.77	0.83	0.77	0.80	0.74	0.83	0.93	0.97	0.89	0.91	0.84	0.74
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6303	536	480	533	521	542	514	527	529	517	539	523	541
	CDD18.3	3261	278	247	274	271	284	264	269	271	267	281	273	283
	CDH23.3	32694	2782	2408	2706	2757	2926	2594	2613	2672	2697	2888	2782	2869
(13) Wind	WSAvg	2.1	2.2	2.2	2.3	2.1	1.9	1.9	2.2	2.1	2.1	2.0	2.0	2.1
	PrecAvg	2810	254	251	260	204	255	213	260	233	224	207	205	235
	PrecMax	3310	474	406	392	349	426	369	476	411	526	422	432	575
	PrecMin	1863	55	134	116	79	109	86	76	26	48	47	70	78
	PrecStd	354	103	71	71	73	81	78	100	92	117	103	91	98
	DB	31.3	31.4	31.2	31.4	31.6	31.2	31.1	31.3	31.6	31.8	31.7	31.7	31.7
	MCWB	26.7	26.5	26.6	26.8	27.0	26.8	26.5	26.7	26.7	26.8	26.9	26.9	26.9
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	30.9	30.9	30.7	30.9	31.0	30.7	30.5	30.8	31.0	31.2	31.1	31.1	31.1
	2% MCWB	26.7	26.5	26.5	26.8	26.9	26.7	26.4	26.6	26.6	26.6	26.7	26.7	26.9
	5% DB	30.4	30.2	30.2	30.3	30.6	30.2	30.0	30.2	30.4	30.8	30.7	30.6	30.6
	5% MCWB	26.5	26.3	26.4	26.7	26.8	26.6	26.3	26.3	26.3	26.3	26.5	26.6	26.7
	10% DB	29.9	29.8	29.8	29.9	30.1	29.7	29.5	29.8	30.0	30.2	30.1	30.1	30.1
	10% MCWB	26.4	26.2	26.3	26.6	26.6	26.4	26.1	26.1	26.2	26.3	26.4	26.4	26.5
	WB	27.6	27.4	27.7	27.9	28.1	27.6	27.2	27.7	27.4	27.8	27.6	27.6	27.9
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	30.3	30.0	30.3	30.2	30.5	30.1	29.8	30.5	30.6	30.6	30.6	30.6	30.5
	2% WB	27.1	26.9	27.1	27.3	27.5	27.1	26.9	27.0	27.0	27.2	27.2	27.2	27.3
	2% MCDB	30.0	29.8	29.8	29.9	30.1	29.8	29.6	30.1	30.2	30.1	30.2	30.1	30.1
	5% WB	26.7	26.6	26.7	27.0	27.1	26.8	26.6	26.6	26.7	26.8	26.9	26.9	27.0
	5% MCDB	29.5	29.4	29.4	29.7	29.8	29.4	29.2	29.5	29.7	29.8	29.9	29.9	29.9
	10% WB	26.5	26.3	26.4	26.7	26.8	26.5	26.2	26.2	26.3	26.5	26.6	26.6	26.7
	10% MCDB	29.1	29.0	29.0	29.2	29.3	29.0	28.8	29.0	29.2	29.4	29.4	29.4	29.3
(35) Mean Daily Temperature Range	MDBR	5.3	5.1	5.2	5.1	5.2	4.9	4.8	5.1	5.2	5.4	5.3	5.3	5.3
	5% DB	6.0	5.8	5.8	5.7	5.8	5.6	5.5	5.8	5.8	6.3	6.1	6.1	6.1
	5% MCWBR	2.8	2.7	2.8	2.7	2.8	2.7	2.6	2.6	2.7	2.9	2.9	2.9	2.9
	5% WB	5.6	5.5	5.4	5.4	5.4	5.3	5.2	5.5	5.6	5.7	5.7	5.7	5.7
	5% MCWBR	2.9	2.8	2.9	2.8	2.9	2.7	2.7	2.8	2.8	2.9	2.9	2.9	2.9
(40) Clear-Sky Solar Irradiance	taub	0.396	0.397	0.397	0.394	0.392	0.396	0.397	0.402	0.404	0.431	0.413	0.404	0.404
	taud	2.574	2.565	2.568	2.583	2.584	2.574	2.569	2.543	2.538	2.442	2.510	2.545	2.545
	Ebn at Noon	935	936	926	908	886	869	874	888	906	893	912	924	924
	Edh at Noon	105	107	106	101	97	96	98	104	107	119	111	107	107
(44) All-Sky Solar Radiation	RadAvg	4.74	4.99	5.09	5.03	4.84	4.35	4.46	4.87	5.07	5.15	4.71	4.54	4.54
	RadStd	0.31	0.38	0.38	0.34	0.26	0.31	0.41	0.36	0.38	0.34	0.35	0.29	0.29

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page