

FAK-FAK TOREA, Indonesia

WMO: 976300

Lat: 2.9194S

Lon: 132.2650E

Elev: 427

StdP: 14.47

Time Zone: 9.00 (E09)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	71.0	71.9	67.7	103.5	74.4	69.0	108.4	75.0	19.5	77.0	18.0	77.2	5.8	20	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.3	88.7	77.8	87.6	78.2	86.7	78.2	80.1	85.6	79.7	85.1	79.2	84.6	8.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.4	149.6	83.3	78.0	147.8	83.1	77.4	145.0	82.7	44.0	86.1	43.5	85.5	43.1	85.0	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.1	12.3	10.7	67.9	92.3	1.9	3.3	66.5	94.6	65.4	96.5	64.4	98.3	63.0	100.7		
(5)			66.5	82.5	2.0	1.6	65.1	83.6	64.0	84.6	62.8	85.5	61.4	86.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.9	80.2	80.0	79.8	79.5	79.2	78.0	76.9	76.6	77.6	78.8	79.8	80.3
	DBStd	1.86	1.51	1.46	1.44	1.17	1.24	1.44	1.40	1.47	1.53	1.26	1.13	1.45
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10540	936	839	923	886	904	841	833	825	827	894	894	938
	CDD65	5065	471	419	458	436	439	391	368	360	377	429	444	473
	CDH74	40415	4250	3686	3860	3729	3651	2753	2134	1992	2532	3514	3982	4332
	CDH80	9071	1273	1069	1036	880	755	373	159	119	291	703	1104	1309
Wind	WSAvg	5.1	5.3	5.3	5.1	4.9	4.7	4.9	5.0	5.3	5.1	5.4	5.2	5.2
Precipitation	PrecAvg	136.9	9.8	8.6	10.7	12.2	12.9	14.6	15.4	12.1	11.4	9.8	8.5	8.7
	PrecMax	194.0	22.6	16.5	20.0	32.0	27.2	45.5	38.3	27.9	25.2	22.8	16.5	14.6
	PrecMin	21.3	2.6	0.7	0.9	1.1	1.1	1.3	0.8	0.0	0.3	0.9	0.6	1.5
	PrecStd	39.1	4.3	4.1	4.3	6.8	6.3	10.0	8.8	7.2	7.4	5.4	4.2	3.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.0	89.9	89.0	87.4	86.3	85.3	83.7	83.6	84.7	86.4	87.9	90.0
		MCWB	77.5	76.0	77.9	78.4	78.5	77.9	77.2	77.0	77.8	78.1	78.9	77.7
	2%	DB	88.3	88.0	87.3	86.2	85.4	84.1	82.7	82.4	83.7	85.4	86.9	88.3
		MCWB	77.8	77.8	78.1	78.4	78.4	77.6	76.7	76.6	77.4	78.0	78.5	78.4
	5%	DB	87.1	86.7	86.2	85.4	84.6	83.2	81.8	81.4	82.7	84.5	86.0	87.1
		MCWB	77.9	77.8	78.1	78.2	78.1	77.3	76.3	76.3	77.0	77.6	78.3	78.5
	10%	DB	85.9	85.5	85.0	84.5	83.8	82.3	80.8	80.4	81.8	83.6	85.1	85.9
		MCWB	77.9	77.6	77.8	78.0	77.9	77.0	75.9	76.0	76.6	77.3	78.0	78.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.8	80.4	80.0	80.0	80.1	79.1	78.3	78.7	79.1	79.8	80.4	80.7
		MCDB	86.2	86.6	85.8	84.8	84.2	82.9	81.9	80.9	82.9	84.6	85.9	87.0
	2%	WB	79.7	79.2	79.2	79.2	79.4	78.3	77.5	77.6	78.3	79.0	79.5	79.8
		MCDB	85.7	85.4	85.1	84.2	83.7	82.3	81.0	80.4	82.2	83.8	85.1	86.1
	5%	WB	79.0	78.7	78.8	78.8	78.9	77.9	77.0	77.0	77.6	78.3	79.0	79.1
		MCDB	85.2	84.8	84.7	84.0	83.3	81.9	80.6	80.2	81.5	83.0	84.6	85.3
	10%	WB	78.3	78.1	78.1	78.3	78.3	77.4	76.4	76.4	77.1	77.8	78.3	78.6
		MCDB	84.4	84.0	83.8	83.2	82.6	81.2	79.7	79.3	80.8	82.3	83.8	84.6
Mean Daily Temperature Range	5% DB	MDBR	11.5	11.4	10.9	9.9	9.5	8.4	7.6	7.3	8.3	9.9	11.0	11.3
		MCDBR	13.3	13.1	12.5	11.3	10.5	9.6	9.0	8.7	9.5	10.9	12.2	13.3
		MCWBR	6.0	5.9	6.0	5.6	5.5	4.9	4.6	4.7	5.0	5.5	6.1	6.3
	5% WB	MCDBR	12.0	11.7	11.3	10.3	9.8	9.1	8.2	7.8	8.9	10.1	11.3	11.8
		MCWBR	6.5	6.3	6.0	5.6	5.5	4.9	4.6	4.8	5.0	5.4	6.0	6.4
Clear-Sky Solar Irradiance	taub	0.414	0.417	0.413	0.404	0.407	0.416	0.416	0.425	0.435	0.462	0.441	0.425	
	taud	2.502	2.484	2.498	2.534	2.528	2.513	2.509	2.474	2.440	2.328	2.402	2.460	
	Ebn at Noon	292	291	289	284	276	269	271	275	279	275	282	287	
	Edh at Noon	36	37	36	34	32	32	33	35	37	43	39	37	
All-Sky Solar Radiation	RadAvg	1586	1670	1643	1615	1599	1450	1453	1556	1666	1760	1715	1580	
	RadStd	92	103	88	80	78	102	104	116	108	126	88	105	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page