

NAMLEA BURU, Indonesia

WMO: 977000

Lat: 3.2388S

Lon: 127.0997E

Elev: 66

StdP: 14.66

Time Zone: 9.00 (E09)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	71.0	72.4	65.9	95.9	76.2	67.4	101.0	76.4	23.0	83.9	21.4	83.4	5.8	220	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	12.8	90.1	79.6	89.5	79.6	88.8	79.5	81.9	87.4	81.5	87.1	80.9	86.8	10.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.4	158.4	86.2	79.8	155.1	85.6	79.2	151.8	85.0	45.9	87.8	45.3	87.3	44.7	87.1	89.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.5	17.4	14.7	DB	65.3	92.8	4.4	2.6	62.1	94.7	59.5	96.2	57.0	97.7	53.8	99.6	(4)
(5)			WB	63.7	83.5	3.6	1.4	61.1	84.5	58.9	85.3	56.9	86.1	54.3	87.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.0	80.9	80.8	80.9	81.6	81.5	80.3	79.4	79.6	80.4	81.9	82.5	81.8
	DBStd	1.69	1.55	1.17	1.48	1.14	1.31	1.65	1.67	1.58	1.43	1.45	1.20	1.32
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11305	958	863	957	948	978	910	911	917	913	989	974	987
	CDD65	5830	493	443	492	498	513	460	446	452	463	524	524	522
	CDH74	56899	4727	4146	4591	4863	5197	4223	3760	3943	4513	5744	5862	5330
	CDH80	17073	1260	1067	1244	1499	1624	1088	810	981	1425	2150	2244	1681
Wind	WSAvg	6.2	5.1	5.5	5.1	5.0	5.7	6.8	7.5	8.3	7.0	6.6	5.9	5.3
Precipitation	PrecAvg	68.8	10.9	10.8	8.3	5.9	4.1	5.0	4.7	3.1	1.5	2.1	3.2	8.5
	PrecMax	123.5	22.9	25.5	17.0	15.3	11.1	10.5	18.7	20.8	5.0	6.3	20.7	39.6
	PrecMin	36.1	2.1	3.3	3.1	1.2	0.5	0.2	0.2	0.0	0.1	0.0	0.1	1.9
	PrecStd	22.4	5.2	4.6	3.5	3.3	2.7	3.3	4.3	4.9	1.5	1.9	3.9	6.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.2	88.1	88.3	89.9	89.7	89.3	87.3	88.5	89.9	91.0	91.4	90.6
		MCWB	80.3	80.3	80.5	80.6	80.6	79.7	78.9	78.0	78.0	79.1	79.4	80.1
	2%	DB	87.5	87.2	87.5	88.7	88.6	87.9	86.2	87.1	88.5	89.9	90.1	89.1
		MCWB	80.0	80.0	80.3	80.5	80.2	79.4	77.8	77.4	77.7	79.1	79.6	80.1
	5%	DB	86.7	86.4	86.8	87.8	87.8	86.6	85.3	86.1	87.6	89.1	89.4	88.0
		MCWB	79.8	79.6	80.0	80.3	79.9	78.9	77.4	77.0	77.4	79.0	79.7	80.1
	10%	DB	85.8	85.5	85.9	86.8	86.9	85.4	84.3	84.9	86.6	88.2	88.5	87.0
		MCWB	79.6	79.3	79.5	80.1	79.6	78.4	76.9	76.5	77.2	78.7	79.5	79.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	81.9	81.9	82.7	82.0	81.0	80.0	79.7	80.5	82.5	82.5	82.0
		MCDB	86.1	86.5	86.8	87.7	87.6	87.3	85.9	86.3	87.7	89.1	88.0	87.4
	2%	WB	81.0	80.9	81.0	81.8	81.1	80.0	79.1	78.7	79.6	81.2	81.2	81.1
		MCDB	85.9	85.8	86.2	87.2	87.0	86.1	84.8	85.4	86.7	88.0	87.9	87.0
	5%	WB	80.3	80.1	80.4	81.0	80.6	79.5	78.3	78.0	78.7	80.1	80.4	80.6
		MCDB	85.5	84.9	85.7	86.5	86.7	85.3	83.6	84.3	85.8	87.1	87.6	86.8
	10%	WB	79.8	79.6	79.8	80.3	80.0	78.8	77.5	77.2	78.0	79.3	79.8	80.0
		MCDB	84.7	84.1	84.8	85.8	85.7	84.3	82.4	83.2	84.7	86.3	86.8	85.8
Mean Daily Temperature Range	5% DB	MDBR	10.1	9.7	10.5	11.1	11.2	10.3	10.0	11.2	13.0	13.6	12.8	11.0
		MCDBR	11.1	10.9	11.3	11.9	12.3	12.0	11.3	12.7	14.3	14.4	13.8	12.2
		MCWBR	5.4	5.4	5.6	5.9	5.6	5.3	5.2	5.7	6.4	6.4	5.8	5.5
	5% WB	MCDBR	10.5	10.4	10.8	11.4	11.4	10.9	10.5	11.5	12.8	13.5	12.9	11.6
MCWBR		5.6	5.5	5.7	6.1	5.6	5.3	5.1	5.5	6.0	6.8	5.9	5.7	
Clear-Sky Solar Irradiance	taub		0.416	0.422	0.417	0.405	0.413	0.422	0.417	0.417	0.426	0.454	0.439	0.424
	taud		2.488	2.462	2.477	2.529	2.515	2.487	2.497	2.483	2.442	2.344	2.394	2.454
	Ebn at Noon		292	290	288	284	274	266	270	277	281	277	283	288
	Edh at Noon		36	38	37	34	33	33	33	35	37	42	40	37
All-Sky Solar Radiation	RadAvg		1599	1675	1719	1702	1591	1394	1455	1664	1816	1952	1897	1656
	RadStd		121	122	98	78	117	152	178	206	157	112	100	134

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page