

AMAHAI, Indonesia

WMO: 977220

Lat: 3.3464S

Lon: 128.9281E

Elev: 33

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	71.3	72.4	69.1	107.0	74.6	70.0	110.5	75.6	18.3	78.8	16.0	79.1	0.8	N/A	0.288

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.1	90.5	79.4	89.6	79.4	88.7	79.2	81.6	87.1	80.7	86.8	80.1	86.2	6.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.0	155.7	85.4	78.9	150.3	84.5	78.3	147.0	83.9	45.3	87.3	44.3	87.1	43.8	86.7	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.5	11.1	9.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB	7.8	84.5	1.6	2.6	66.6	86.4	65.6	87.9	64.7	89.4	63.5	91.3
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	82.3	82.2	82.0	81.3	80.4	78.7	77.3	77.3	78.3	80.1	81.6	82.5	(6)
	DBStd	2.39	1.58	1.66	1.58	1.16	1.25	1.74	1.65	1.54	1.63	1.18	1.08	1.35	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	11069	1000	901	993	940	943	860	848	845	849	934	949	1007	(10)
	CDD65	5594	535	481	528	490	478	410	383	380	399	469	499	542	(11)
	CDH74	52958	5693	5131	5534	4957	4599	3251	2456	2440	3126	4493	5308	5970	(12)
	CDH80	15003	2009	1782	1901	1496	1198	525	212	211	481	1178	1817	2193	(13)
(14) Wind	WSAvg	2.7	2.9	3.4	2.7	2.3	2.2	2.4	3.1	3.3	2.7	2.5	2.5	2.9	(14)
(15) Precipitation	PrecAvg	101.8	5.1	4.7	6.7	9.0	11.3	14.6	16.3	11.3	7.9	5.1	4.1	5.7	(15)
	PrecMax	193.3	11.3	8.8	11.3	18.1	32.0	42.8	44.9	54.1	19.0	14.7	10.0	10.3	(16)
	PrecMin	49.2	1.7	1.5	3.6	4.4	2.4	1.0	1.5	0.0	0.0	0.8	1.1	1.3	(17)
	PrecStd	37.8	2.3	1.7	1.9	3.0	7.4	9.8	10.3	12.2	5.4	3.6	2.1	2.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.1	91.7	91.9	89.0	87.5	86.1	84.2	84.4	85.7	87.5	89.7	91.8	(19)
		MCWB	78.9	78.9	78.8	79.6	79.7	78.9	77.9	77.8	78.6	78.6	79.6	80.5	(20)
	2%	DB	89.8	89.9	89.8	87.8	86.8	85.0	83.1	83.3	84.7	86.5	88.7	90.1	(21)
		MCWB	79.1	78.7	79.0	79.4	79.4	78.7	77.3	77.2	78.2	78.6	79.4	80.3	(22)
	5%	DB	88.9	88.7	88.3	87.1	86.0	84.1	82.3	82.2	83.7	85.8	87.9	89.1	(23)
		MCWB	78.9	78.6	78.8	79.2	79.1	78.4	76.9	76.6	77.8	78.5	79.2	80.0	(24)
	10%	DB	87.8	87.6	87.3	86.3	85.2	83.1	81.3	81.1	82.8	85.0	87.0	88.1	(25)
		MCWB	78.6	78.5	78.6	79.0	78.9	77.9	76.4	76.1	77.2	78.3	79.1	79.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	80.9	81.0	81.2	80.8	80.0	79.0	78.7	79.6	80.5	81.9	85.9	(27)
		MCDB	88.3	87.7	87.8	86.6	86.0	84.1	82.7	83.0	84.4	85.1	87.1	89.4	(28)
	2%	WB	80.1	80.0	80.1	80.3	80.1	79.2	78.1	77.9	78.8	79.7	80.8	82.9	(29)
		MCDB	87.3	87.3	86.9	86.1	85.1	83.4	81.8	81.9	83.7	84.7	86.8	87.3	(30)
	5%	WB	79.7	79.5	79.6	79.8	79.7	78.8	77.4	77.2	78.2	79.1	80.0	80.6	(31)
		MCDB	86.9	86.8	86.4	85.6	84.7	83.1	80.9	81.0	82.7	84.4	86.2	87.2	(32)
	10%	WB	79.1	78.9	79.0	79.3	79.2	78.2	76.9	76.5	77.6	78.7	79.5	79.8	(33)
		MCDB	86.4	86.2	85.9	84.9	84.1	82.1	80.2	80.0	81.7	84.0	85.7	86.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	11.6	11.7	10.5	9.5	7.9	7.2	7.2	8.7	10.2	11.5	12.1	(35)
		MCDBR	12.8	12.4	12.4	11.2	10.5	9.3	8.7	8.8	9.8	11.1	12.2	13.1	(36)
	5% WB	MCWBR	5.6	5.3	5.3	5.2	5.1	4.6	4.2	4.0	4.8	5.1	5.5	6.0	(37)
		MCWBR	12.2	12.0	11.8	10.9	9.8	8.6	7.7	7.9	9.3	10.4	11.8	12.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.416	0.419	0.417	0.411	0.419	0.430	0.423	0.424	0.434	0.458	0.445	0.427	(40)
		taud	2.487	2.464	2.477	2.508	2.489	2.469	2.486	2.466	2.429	2.339	2.382	2.444	(41)
	Ebn at Noon		292	291	288	282	272	265	268	275	279	276	281	287	(42)
		Edh at Noon	36	37	37	34	34	34	34	36	38	42	40	38	(43)
(44) All-Sky Solar Radiation	RadAvg		1620	1695	1701	1622	1482	1248	1276	1475	1616	1820	1803	1657	(44)
	RadStd		107	113	103	82	141	154	161	210	174	133	95	117	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page