

AMBON PATTIMURA, Indonesia

WMO: 977240

Lat: 3.7111S

Lon: 128.0853E

Elev: 39

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	71.5	72.7	67.9	102.8	77.2	69.0	106.6	77.4	14.4	78.2	13.0	79.0	3.3	340	0.303

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.6	91.6	78.7	90.4	78.7	89.4	78.6	80.8	87.6	80.2	87.0	79.9	86.7	8.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	150.5	84.9	78.3	147.2	84.4	77.9	145.2	84.0	44.5	88.0	44.0	87.7	43.5	87.1	88.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.9	11.6	10.2	67.0	94.0	4.2	2.1	64.0	95.5	61.5	96.7	59.1	97.9	56.0	99.4		
(5)			64.0	83.5	4.2	2.1	61.0	85.0	58.6	86.3	56.2	87.4	53.2	89.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.5	82.1	81.9	81.9	81.4	80.5	78.9	77.8	77.8	78.8	80.5	81.7	82.3	(6)
(7)		DBStd	2.26	1.68	1.75	1.83	1.44	1.51	1.56	1.56	1.57	1.49	1.30	1.37	1.63	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11120	995	893	990	943	945	867	863	862	863	947	952	1000	(10)
(11)		CDD65	5645	530	473	525	493	480	417	398	397	413	482	502	535	(11)
(12)		CDH74	52911	5608	4952	5522	4911	4403	3237	2724	2708	3291	4594	5254	5707	(12)
(13)		CDH80	15468	2046	1793	2012	1544	1134	522	244	278	591	1308	1860	2136	(13)
(14)	Wind	WSAvg	4.7	4.9	4.9	4.7	4.3	4.1	4.4	4.9	5.2	4.7	4.6	4.7	4.9	(14)
(15)	Precipitation	PrecAvg	117.2	6.5	5.1	6.1	8.1	14.8	19.2	18.9	11.5	7.6	4.8	3.7	6.2	(15)
(16)		PrecMax	218.6	11.8	12.6	11.7	20.6	48.7	52.5	69.1	49.7	26.5	10.7	7.0	11.7	(16)
(17)		PrecMin	48.7	0.9	1.5	2.9	2.5	2.1	2.6	2.8	0.0	0.0	0.4	0.7	2.0	(17)
(18)		PrecStd	42.2	2.5	2.8	2.2	3.7	9.4	12.1	14.6	11.6	6.5	2.7	1.9	2.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.3	92.8	92.2	90.7	89.1	87.0	85.6	87.3	88.9	91.6	93.2	(19)	
(20)			MCWB	78.4	78.1	78.2	79.1	79.8	78.2	77.6	77.5	78.8	79.3	79.9	79.6	(20)
(21)		2%	DB	90.6	90.9	90.6	88.9	87.5	85.6	84.0	84.2	85.5	87.6	89.8	91.2	(21)
(22)			MCWB	78.3	78.2	78.3	79.1	79.5	78.0	77.1	76.8	77.7	78.6	79.3	79.1	(22)
(23)		5%	DB	89.4	89.3	89.2	87.8	86.3	84.4	82.5	82.7	84.3	86.4	88.5	89.6	(23)
(24)			MCWB	78.3	78.1	78.2	79.0	79.0	77.7	76.3	76.0	77.0	78.3	79.0	79.0	(24)
(25)		10%	DB	88.0	87.9	87.9	86.7	85.4	83.1	81.3	81.5	83.3	85.7	87.5	88.2	(25)
(26)			MCWB	78.3	78.1	78.2	78.8	78.6	77.3	75.8	75.4	76.6	78.1	78.7	78.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.0	81.0	80.9	80.9	79.9	78.9	78.6	80.0	80.5	81.0	81.4	(27)
(28)			MCD B	87.8	87.7	87.6	87.6	86.5	84.6	83.2	83.5	86.0	86.7	88.5	88.9	(28)
(29)		2%	WB	80.0	79.9	80.0	80.1	80.1	79.0	78.0	77.6	78.8	79.7	80.2	80.3	(29)
(30)			MCD B	87.4	87.2	87.1	86.5	85.6	83.5	81.9	82.1	83.9	85.8	87.5	88.2	(30)
(31)		5%	WB	79.3	79.1	79.2	79.7	79.6	78.3	77.3	77.0	78.0	79.1	79.8	79.8	(31)
(32)			MCD B	86.8	86.7	86.5	86.0	84.9	82.4	80.8	81.0	82.7	85.1	86.9	87.5	(32)
(33)		10%	WB	78.8	78.5	78.8	79.1	79.0	77.8	76.6	76.3	77.2	78.5	79.2	79.2	(33)
(34)			MCD B	86.4	86.1	86.2	85.3	84.1	81.7	79.8	80.0	81.7	84.4	86.1	86.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.2	12.3	12.3	11.0	9.6	7.9	6.8	7.4	9.2	10.7	12.2	12.6	(35)
(36)			MCDBR	14.1	14.5	14.0	12.6	11.1	10.3	8.8	9.6	10.9	11.7	13.7	14.6	(36)
(37)			MCWBR	5.2	5.3	5.2	5.2	5.0	4.6	4.0	4.1	4.8	5.3	5.9	5.7	(37)
(38)		5% WB	MCDBR	13.0	13.0	12.6	11.5	10.2	8.8	7.6	8.2	9.9	10.9	12.5	13.3	(38)
(39)			MCWBR	5.6	5.7	5.7	5.4	5.0	4.3	3.9	4.0	5.0	5.4	5.9	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.416	0.419	0.413	0.405	0.421	0.435	0.428	0.426	0.431	0.451	0.436	0.421	(40)	
(41)		taud	2.502	2.484	2.502	2.543	2.504	2.460	2.477	2.471	2.446	2.369	2.415	2.475	(41)	
(42)		Ebn at Noon	292	291	289	284	271	263	267	274	279	278	284	289	(42)	
(43)		Edh at Noon	36	37	36	33	33	34	34	35	37	41	39	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1650	1740	1757	1667	1501	1279	1337	1566	1733	1924	1905	1695	(44)	
(45)		RadStd	129	128	106	84	143	164	170	217	167	123	95	127	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page