

GESER, Indonesia

WMO: 977480

Lat: 3.8869S

Lon: 130.8954E

Elev: 3

StdP: 101.29

Time Zone: 9.00 (E09)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	23.9	24.4	21.7	16.4	26.2	22.0	16.7	26.1	9.9	26.2	9.1	26.1	3.8	110	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	4.4	32.0	26.9	31.6	26.8	31.3	26.7	27.6	30.7	27.3	30.4	27.2	30.2	2.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	29.6	26.5	22.0	29.4	26.2	21.6	29.1	87.9	31.0	86.7	30.8	85.7	30.5	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 9.3	8.1	6.9	DB	18.2	34.2	3.0	2.4	16.1	35.9	14.3	37.3	12.7	38.6	10.5	40.4	(4)
(5)			WB	20.3	28.6	2.1	0.6	18.8	29.1	17.6	29.4	16.4	29.8	14.8	30.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	28.5	28.5	28.4	28.3	28.0	27.3	26.8	26.6	27.0	27.9	28.6	28.7
	DBStd	1.19	0.89	0.88	0.84	0.94	1.00	1.16	0.97	0.87	0.81	0.89	0.87	1.05
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6527	572	517	571	548	557	519	521	515	509	556	559	581
	CDD18.3	3485	314	283	313	298	299	269	263	257	259	298	309	323
	CDH23.3	38841	3723	3349	3721	3518	3426	2824	2437	2269	2473	3317	3801	3983
	CDH26.7	11570	1317	1176	1311	1199	1045	608	339	269	374	931	1450	1550
Wind	WSAvg	3.1	2.9	2.6	2.7	2.5	2.6	3.8	4.0	4.1	3.6	3.0	2.3	2.7
Precipitation	PrecAvg	2144	186	162	190	266	299	232	181	107	101	122	113	185
	PrecMax	3828	350	259	356	622	702	648	953	463	300	336	283	394
	PrecMin	1182	53	66	63	133	77	11	13	0	0	1	21	88
	PrecStd	686	82	59	68	117	152	177	201	113	79	105	70	74
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.1	31.9	32.2	31.6	30.9	30.2	30.0	30.2	31.1	32.1	32.5
		MCWB	26.9	26.7	26.8	26.9	27.0	27.0	26.4	26.1	26.2	26.6	26.9	27.0
	2%	DB	31.6	31.5	31.4	31.4	30.9	30.2	29.5	29.2	29.6	30.5	31.6	32.0
		MCWB	26.7	26.5	26.7	26.8	26.8	26.6	26.0	25.7	25.9	26.4	26.7	27.0
	5%	DB	31.1	31.0	31.0	30.9	30.4	29.7	28.9	28.6	29.0	30.1	31.2	31.5
		MCWB	26.6	26.4	26.6	26.6	26.7	26.4	25.7	25.4	25.7	26.3	26.6	26.9
	10%	DB	30.7	30.6	30.5	30.3	29.9	29.1	28.3	28.1	28.4	29.6	30.7	31.0
		MCWB	26.5	26.3	26.4	26.5	26.5	26.1	25.4	25.1	25.5	26.1	26.5	26.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	27.6	27.5	27.7	27.7	27.4	26.7	26.6	27.0	27.5	27.7	27.7
		MCDB	30.8	30.9	30.7	30.8	30.4	29.8	29.3	29.3	29.3	30.0	30.9	31.2
	2%	WB	27.3	27.1	27.1	27.2	27.3	26.9	26.3	26.1	26.4	27.0	27.3	27.5
		MCDB	30.5	30.4	30.4	30.2	29.8	29.6	28.6	28.5	28.6	29.5	30.4	30.9
	5%	WB	27.0	26.8	26.8	27.0	27.0	26.6	26.0	25.7	26.1	26.6	27.0	27.2
		MCDB	30.3	30.0	30.0	29.9	29.5	29.0	28.2	28.0	28.2	29.1	30.2	30.6
	10%	WB	26.7	26.6	26.6	26.7	26.7	26.2	25.7	25.4	25.7	26.4	26.7	26.9
		MCDB	29.8	29.7	29.7	29.5	29.1	28.4	27.8	27.6	27.8	28.8	29.8	30.2
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.4	4.3	4.0	3.6	3.2	3.0	3.0	3.1	3.3	4.2	4.4
		MCDBR	4.9	4.9	4.8	4.6	4.1	3.8	3.5	3.4	3.5	3.8	4.6	4.9
		MCWBR	2.1	2.1	2.1	1.8	1.7	1.8	1.6	1.5	1.6	1.6	1.8	2.0
	5% WB	MCDBR	4.7	4.5	4.5	4.3	3.7	3.4	3.2	3.3	3.2	3.5	4.3	4.5
		MCWBR	2.1	2.2	2.1	2.0	1.8	1.8	1.6	1.5	1.6	1.7	1.9	2.1
Clear-Sky Solar Irradiance	taub	0.414	0.418	0.410	0.404	0.419	0.434	0.431	0.434	0.439	0.456	0.435	0.420	
	taud	2.521	2.502	2.527	2.561	2.521	2.469	2.476	2.459	2.436	2.366	2.433	2.491	
	Ebn at Noon	922	918	914	896	856	828	838	857	874	872	895	913	
	Edh at Noon	111	114	110	103	103	106	106	112	119	129	120	114	
All-Sky Solar Radiation	RadAvg	5.01	5.30	5.29	4.96	4.62	4.30	4.50	5.00	5.30	5.66	5.56	5.06	
	RadStd	0.39	0.42	0.37	0.28	0.41	0.46	0.44	0.52	0.45	0.48	0.37	0.41	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page