

MERAUKE MOPAH, Indonesia

WMO: 979800

Lat: 8.5183S

Lon: 140.4140E

Elev: 10

StdP: 14.69

Time Zone: 9.00 (E09)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	69.3	70.7	64.7	91.6	75.8	65.9	95.6	75.5	22.3	81.6	20.3	81.9	2.8	120	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.8	90.9	79.2	90.0	79.2	89.2	79.0	81.2	87.7	80.8	87.3	80.3	86.7	8.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.5	153.1	84.8	79.0	150.4	84.4	78.4	147.4	83.9	45.0	88.2	44.4	87.8	44.0	87.3	89.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	16.8	14.3	66.7	93.9	1.8	0.8	65.5	94.5	64.4	95.0	63.4	95.4	62.1	96.0
			65.2	83.3	1.8	1.9	63.9	84.7	62.8	85.8	61.8	86.9	60.5	88.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.8	82.1	82.0	81.8	81.8	81.0	79.3	78.1	77.8	78.9	80.9	82.5	82.9
	DBStd	2.39	1.71	1.63	1.54	1.53	1.59	1.71	1.75	1.85	1.96	1.88	1.33	1.58
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11224	994	897	985	955	960	880	871	862	867	958	974	1021
	CDD65	5749	529	477	520	505	495	430	406	397	417	493	524	556
	CDH74	56698	5627	5042	5383	5297	4822	3599	2919	2964	3664	5067	5923	6391
	CDH80	17035	1912	1656	1672	1664	1297	663	448	508	884	1643	2219	2469
(14) Wind	WSAvg	6.2	5.7	5.7	5.1	4.7	6.0	6.8	7.1	7.6	7.7	7.0	6.1	4.9
(15) Precipitation	PrecAvg	51.3	9.2	9.5	10.0	6.3	3.9	1.3	0.9	0.9	1.4	1.3	2.3	7.0
	PrecMax	80.6	18.1	19.8	23.9	20.1	14.3	3.5	3.7	3.7	5.3	4.6	7.9	21.8
	PrecMin	20.0	2.0	0.7	1.3	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	1.5
	PrecStd	13.7	4.4	4.7	5.3	4.7	3.4	1.0	0.9	0.9	1.5	1.5	2.6	4.6
	PrecStd	13.7	4.4	4.7	5.3	4.7	3.4	1.0	0.9	0.9	1.5	1.5	2.6	4.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.4	90.5	90.4	90.6	90.0	88.0	87.1	87.2	89.1	91.4	91.7	92.1
		MCWB	79.9	80.1	79.5	78.8	79.0	77.6	75.8	74.7	76.2	77.7	78.9	79.5
	2%	DB	89.9	89.1	89.0	89.1	88.1	86.2	85.1	85.3	86.8	89.2	90.0	90.7
		MCWB	79.8	79.6	79.4	78.5	78.4	77.6	75.6	75.4	76.9	77.9	79.1	79.5
	5%	DB	88.8	88.3	87.9	88.0	86.8	84.8	83.7	83.9	85.4	87.7	89.0	89.8
		MCWB	79.6	79.4	79.2	78.7	78.2	77.2	75.4	75.3	76.6	77.9	78.8	79.3
	10%	DB	87.6	87.2	86.8	86.8	85.6	83.5	82.5	82.7	84.3	86.5	88.1	88.8
		MCWB	79.2	79.2	79.0	78.6	78.0	76.7	75.2	74.9	76.0	77.5	78.4	79.1
	0.4%	WB	81.6	81.5	81.7	81.6	81.2	80.0	78.8	78.8	80.0	80.5	81.6	81.6
		MCDB	88.5	88.1	87.3	87.1	86.6	84.6	83.4	84.0	85.6	87.3	88.7	89.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	80.7	80.7	80.8	80.6	80.1	79.0	77.6	77.6	78.8	79.6	80.6	80.8
		MCDB	87.9	87.2	86.4	86.6	85.5	83.7	82.3	82.7	84.8	86.6	87.9	88.4
	5%	WB	80.1	80.1	80.0	80.0	79.4	78.2	76.8	76.7	77.8	78.9	79.9	80.2
		MCDB	86.9	86.3	85.6	85.5	84.7	82.9	81.6	81.8	83.5	86.0	87.0	87.5
	10%	WB	79.5	79.5	79.4	79.3	78.8	77.5	76.1	75.9	76.9	78.2	79.2	79.7
		MCDB	86.1	85.5	84.9	84.5	84.0	82.0	80.8	81.0	82.5	85.0	86.1	86.7
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	10.7	10.4	10.6	10.1	9.1	9.9	11.0	11.9	12.3	12.3	11.8
		MCDBR	12.8	11.9	11.9	12.4	11.9	10.6	11.5	12.4	13.1	13.5	13.4	13.4
		MCWBR	4.9	4.5	4.3	4.3	4.5	4.2	4.7	5.2	5.7	5.4	5.1	5.0
	5% WB	MCDBR	11.8	11.3	10.9	10.7	10.3	9.4	9.2	9.9	11.3	12.3	12.3	12.2
		MCWBR	5.0	4.7	4.5	4.3	4.6	4.2	4.5	4.9	5.4	5.4	5.2	5.0
(40) Clear-Sky Solar Irradiance	taub	0.418	0.414	0.406	0.421	0.432	0.428	0.421	0.426	0.440	0.466	0.462	0.445	(40)
	taud	2.495	2.502	2.531	2.481	2.438	2.446	2.465	2.443	2.398	2.296	2.320	2.394	(41)
	Ebn at Noon	293	293	291	277	265	261	266	272	277	275	278	284	(42)
	Edh at Noon	36	36	35	35	35	34	33	36	39	44	43	40	(43)
	RadAvg	1627	1654	1594	1554	1461	1323	1361	1559	1764	1925	1890	1736	(44)
(45) All-Sky Solar Radiation	RadStd	121	136	84	132	110	97	85	145	144	137	130	145	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page